

#### Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926

2023 Chemical Monitoring for Community Systems

System Name: City of Bradenton		PWS-ID No. 6410182		
MONITORING & REPORTS		DUE	COMMENTS	
Microbiological ("Bacteriological")		Monthly	Disinfectant residuals must be reported.	
Nitrate and Nitrite		2023	Sample at each POE every year. *	
Primary Inorganics		2023	Sample at each POE every year.	
Secondaries		2023	Sample at each POE every three years.	
Radiologicals	Gross Alpha	2031	Sample at each POE every three, six or nine years.	
	Uranium	2031	Sample at each POE every three, six or nine years.	
	Radium-226	2031	Sample at each POE every three, six or nine years.	
	Radium-228		Sample at each POE every three, six or nine years.	
Volatile Organic Contaminants (VOCs)		2023	Sample at each POE every three years.	
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2023	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.	
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		Quarterly	Sample according to approved Stage 2 D/DBPR Monitoring Plan.	
Asbestos		2029	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.	
Lead & Copper		June – Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.	
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2023	CCR must be delivered by July 1, 2023. The CCR Certification of Delivery must be submitted to the Department by August 10, 2023. Use Form 62- 555.900(alternate 19), F.A.C.	
Cross Connection C	Control Annual Report	March 31, 2023	Complete and submit DEP form 62-555.900(13)	

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- > It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.

Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary



CD 1

# FLORIDA DEPARTMENT OF Environmental Protection

#### Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for Community Systems

System Name: City of Palmetto	PW	S-ID No. 6410322
MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)	Quarterly	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2029	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper	Jan – June 2023 & July – Dec 2023	Sample from sites approved on the Lead and Copper Sampling Plan biannually for 2023.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2023	CCR must be delivered by July 1, 2023. The CCR Certification of Delivery must be submitted to the Department by August 10, 2023. Use Form 62- 555.900(alternate 19), F.A.C.
Cross Connection Control Annual Report	March 31, 2023	Complete and submit DEP form 62-555.900(13)

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, retests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



#### Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926

Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for Community Systems

System Name: Town of Longboat Key	PWS-ID No. 6411098		
MONITORING & REPORTS	DUE	COMMENTS	
Microbiological ("Bacteriological")	Monthly	Disinfectant residuals must be reported.	
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)	Quarterly	Sample according to approved Stage 2 D/DBPR Monitoring Plan.	
Asbestos	2023	Sample annually according to approved Asbestos Monitoring Plan. Use Form 62-555.900(10), F.A.C.	
Lead & Copper	June – Sept 2023	Sample from sites approved on the Lead and Copper Sampling Plan every three years.	
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2023	CCR must be delivered by July 1, 2023. The CCR Certification of Delivery must be submitted to the Department by August 10, 2023. Use Form 62- 555.900(alternate 19), F.A.C.	

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, retests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Governor Jeanette Nuñez

**Ron DeSantis** 

Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for Community Systems

System Name: Manatee County Utilities Dept.		t.	PWS-ID No. 6411132		
MONITORING & REPORTS		DUE	COMMENTS		
Microbiological ("Bacteriological")		Monthly	Disinfectant residuals must be reported.		
Nitrate and Nitrite		2023	Sample at each POE every year. *		
Primary Inorganics		2023	Sample at each POE every year.		
Secondaries		2023	Sample at each POE every three years.		
Radiologicals	Gross Alpha	2031	Sample at each POE every three, six or nine years.		
	Uranium	2031	Sample at each POE every three, six or nine years.		
	Radium-226	2031	Sample at each POE every three, six or nine years.		
	Radium-228	2031	Sample at each POE every three, six or nine years.		
Volatile Organic Contaminants (VOCs)		2023	Sample at each POE every three years.		
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2023	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.		
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		Quarterly	Sample according to approved Stage 2 D/DBPR Monitoring Plan.		
Asbestos		2029	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.		
Lead & Copper		June – Sept 2023	Sample from sites approved on the Lead and Copper Sampling Plan every three years.		
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2023	CCR must be delivered by July 1, 2023. The CCR Certification of Delivery must be submitted to the Department by August 10, 2023. Use Form 62-555.900(alternate 19), F.A.C.		
Cross Connection Control Annual Report		March 31, 2023	Complete and submit DEP form 62-555.900(13)		

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, retests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



#### Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926

Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for Community Systems

System Name: Sunny Shores Water Company	PWS-ID No. 6412418	
MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)	Quarterly	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2029	Sample annually according to approved Asbestos Monitoring Plan. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June – Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2023	CCR must be delivered by July 1, 2023. The CCR Certification of Delivery must be submitted to the Department by August 10, 2023. Use Form 62- 555.900(alternate 19), F.A.C.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, retests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Water System: Duette Elementary School

## FLORIDA DEPARTMENT OF Environmental Protection

Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

water System. Ductic Elementary School			W 5-ID 100. 0412425
<b>MONITORING &amp; REPORTS</b>		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.
Distribution Microbi	ological ("Bacteriological")	Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.
Nitrate and Nitrite		2023	Sample at each POE every year. *
Primary Inorganics		2025	Sample at each POE every three years.
Radiologicals	Gross Alpha	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-226	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-228	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
Volatile Organic Cor	ntaminants (VOCs)	2025	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Dalapon (2031)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Hexachlorocyclopentadiene (2042)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
2, 4-D (2105)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		July - Sept 2025	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2031	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Meter(s) Calibration		Last Calibration: Feb 28, 2022	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.
		1 . 1 DOT (1	

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- > It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

MONITORING & REPORTS		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.
Nitrate and Nitrite	Nitrate and Nitrite		Sample at each POE every year. *
Primary Inorganics		2025	Sample at each POE every three years.
Radiologicals	Gross Alpha	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-226	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-228	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
Volatile Organic Contaminants (VOCs)		2025	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Dalapon (2031)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Di(2-ethylhexyl)phthalate (2039)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		Quarterly in 2022	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2031	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2024	Sample from sites approved on the Lead and Copper Sampling Plan every three years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

Water System: Whisenant Farms		PWS-ID No. 6412432	
MONITORING & REPORTS		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.
Nitrate and Nitrite	2	2023	Sample at each POE every year. *
Primary Inorganic	25	2025	Sample at each POE every three years.
Radiologicals	Gross Alpha	2025	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Uranium	2025	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-226	2025	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-228	2025	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
Volatile Organic Contaminants (VOCs)		2025	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Dalapon (2031)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
1,2-Dibromoethane (EDB) (2946)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		July – Sept 2025	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2031	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Meter(s) Calibration		Last Calibration: June 4, 2021	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

MENTAL		51 North Telecon ole Terrace, Floric		
2023 Chemical Monitoring for NTNC				
Water System: Flor	ida Power and Light – Manat		PWS-ID No. 6412448	
	RING & REPORTS	DUE	COMMENTS	
Raw Water Microbio	ological ("Bacteriological")	Quarterly	1 Raw Water Sample per well.	
Distribution Microb	iological ("Bacteriological")	Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.	
Nitrate and Nitrite		2023	Sample at each POE every year. *	
Primary Inorganics		2025	Sample at each POE every three years.	
Radiologicals	Gross Alpha	2023	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Radium-226	2031	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Radium-228	2031	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
Volatile Organic Contaminants (VOCs)		2025	Sample at each POE every three years.	
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.	
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		July – Sept 2025	Sample according to approved Stage 2 D/DBPR Monitoring Plan.	
Asbestos		2029	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.	
Lead & Copper		June - Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.	
Tank(s) Inspection & cleaning		Last 5-year Inspection: Jan 2016	Pursuant to 62-555.350(2) F.A.C. all finished drinking water storage tanks with access manholes shall be inspected and cleaned at a maximum interval of every 5 years.	
Meter(s) Calibration		Last Calibration: Unknown	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.	

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

Water System: Myakka United Methodist Church		h	PWS-ID No. 6412522	
MONITORING & REPORTS		DUE	COMMENTS	
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.	
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.	
Nitrate and Nitrite	2	2023	Sample at each POE every year. *	
Primary Inorganic	'S	2025	Sample at each POE every three years.	
Radiologicals	Gross Alpha	Quarterly	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Uranium	Quarterly	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Radium-226	Quarterly	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Radium-228	Quarterly	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
Volatile Organic C	Contaminants (VOCs)	2025	Sample at each POE every three years.	
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.	
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		July - Sept 2025	Sample according to approved Stage 2 D/DBPR Monitoring Plan.	
Asbestos		2029	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.	
Lead & Copper		June - Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.	
Meter(s) Calibration		Last Calibration: Unknown	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.	

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

Water System: Myakka Park			PWS-ID No. 6412525
MONITORING & REPORTS		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.
Nitrate and Nitrite		2023	Sample at each POE every year. *
Primary Inorganic	CS	2025	Sample at each POE every three years.
Radiologicals	Gross Alpha	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-226	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-228	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
Volatile Organic C	Contaminants (VOCs)	2024	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Toxaphene (2020)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Chlordane (2959)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		July – Sept 2025	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2031	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Meter(s) Calibration		Last Calibration: Unknown	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

Water System: Mosaic – Wingate Creek Mine			PWS-ID No. 6412526
MONITORING & REPORTS		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.
Nitrate and Nitrite		2023	Sample at each POE every year. *
Primary Inorganics		2025	Sample at each POE every three years.
Radiologicals	Gross Alpha	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-226	2024	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-228	2024	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
Volatile Organic Contaminants (VOCs)		2025	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Dalapon (2031)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Di(2-ethylhexyl)phthalate (2039)		Annually in Q2 April - Jun	Sample at each POE, annually in Quarter 2 (Q2).
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		July – Sept 2025	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2028	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Meter(s) Calibration		Last Calibration: Unknown	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

Water System: Increasing Joy Ministries		PWS-ID No. 6412532	
MONITORING & REPORTS		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.
Nitrate and Nitrite		2023	Sample at each POE every year. *
Primary Inorganics		2025	Sample at each POE every three years.
Radiologicals	Gross Alpha	2028	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-226	2028	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-228	2028	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
Volatile Organic Contaminants (VOCs)		2025	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs)		July - Sept	Sample according to approved Stage 2 D/DBPR Monitoring
Total Trihalomethanes & Haloacetic Acids (5)		2025	Plan.
Asbestos		2031	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2025	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Meter(s) Calibration		Last Calibration: Nov 19, 2020	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



#### Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926

Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for Community Systems

System Name: Heather Hills Estates	PWS-ID No. 6412533	
MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)	Quarterly	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2029	Sample annually according to approved Asbestos Monitoring Plan. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June – Sept 2023	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2023	CCR must be delivered by July 1, 2023. The CCR Certification of Delivery must be submitted to the Department by August 10, 2023. Use Form 62- 555.900(alternate 19), F.A.C.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, retests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for NTNC

Water System: My	akka Early Learning Center		PWS-ID No. 6412534
MONITORING & REPORTS		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.
Nitrate and Nitrite		2023	Sample at each POE every year. *
Primary Inorganics		2025	Sample at each POE every three years.
Radiologicals	Gross Alpha	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-226	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
	Radium-228	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)
Volatile Organic Co	Volatile Organic Contaminants (VOCs)		Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs)		July - Sept	Sample according to approved Stage 2 D/DBPR Monitoring
Total Trihalomethanes & Haloacetic Acids (5)		2025	Plan. Certification or results due every nine years.
Asbestos		2031	Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2024	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Meter(s) Calibration		Last Calibration: Unknown	Pursuant to 62-555.350(2) F.A.C. requires that water systems maintain and calibrate master meters in accordance to manufacturer specifications at no less than interval of every 5 years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

Temple Terrace, Florida 33637-0926				
2023 Chemical Monitoring for NTNC Water System: Southeastern Industrial Fabricators, LLC PWS-ID No. 6412536				
MONITORING & REPORTS		COMMENTS		
Raw Water Microbiological ("Bacteriological")		1 Raw Water Sample per well.		
Distribution Microbiological ("Bacteriological")		1 Distribution Sample per quarter. Disinfectant residuals must be reported.		
	2023	Sample at each POE every year. *		
S	2025	Sample at each POE every three years.		
Gross Alpha	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)		
Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)		
Radium-226	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)		
Radium-228	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)		
Volatile Organic Contaminants (VOCs)		Sample at each POE every three years.		
Total Xylenes (2955)		Sample at each POE, annually in Quarter 2 (Q2).		
Ethylbenzene (2992)		Sample at each POE, annually in Quarter 2 (Q2).		
Synthetic Organic Contaminants (SOCs)		Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.		
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		Sample according to approved Stage 2 D/DBPR Monitoring Plan.		
Asbestos		Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.		
Lead & Copper		Sample from sites approved on the Lead and Copper Sampling Plan every three years.		
	2023 autheastern Industrial Fabricato PRING & REPORTS piological ("Bacteriological") piological ("Bacteriological ") piological ("Bacteriological ") piological ("Bacteriological ") piological ("Bacteriological ") piological ("Bacteriological ") piological ("Bacteriological ") piological ") piological ("Bacteriological ") piological ") p	2023 Chemical Monitor         RING & REPORTS       DUE         piological ("Bacteriological")       Quarterly         gacteriological ("Bacteriological")       Quarterly         Quarterly       Waived         waived       Waived         contaminants (VOCs)       2025         piological (DBPs)       July - Sept 2025         piological (DBPs)       2029         pione - Sept 2025       2025		

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- > It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926 Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

		23 Chemical Monitoring		
Water System: E	ast Coast Migrant Head Start	PWS-I	D No. 6412543	
<b>MONITORING &amp; REPORTS</b>		DUE	COMMENTS	
Raw Water Microbiological ("Bacteriological")		Quarterly	1 Raw Water Sample per well.	
Distribution Microbiological ("Bacteriological")		Quarterly	1 Distribution Sample per quarter. Disinfectant residuals must be reported.	
Nitrate and Nitrite		2023	Sample at each POE every year. *	
Primary Inorgani	CS	2025	Sample at each POE every three years.	
Radiologicals	Gross Alpha	2024	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Uranium	Waived	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Radium-226	2031	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
	Radium-228	2031	Sample at each POE every quarterly, six, nine years, or Waived use of Grandfather Data (date of sample)	
Volatile Organic	Contaminants (VOCs)	2025	Sample at each POE every three years.	
Synthetic Organic Contaminants (SOCs)		2025	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.	
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)		July – Sept 2025	Sample according to approved Stage 2 D/DBPR Monitoring Plan.	
Asbestos		2029	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.	
Lead & Copper		January – June 2023 & July – December 2023	Sample from sites approved on the Lead and Copper Sampling Plan biannually for 2023.	

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- > It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, re-tests, and/or corrections.
- Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.



#### Southwest District Office 13051 North Telecom Parkway #101 Temple Terrace, Florida 33637-0926

Ron DeSantis Governor

Jeanette Nuñez Lt. Governor

Shawn Hamilton Secretary

2023 Chemical Monitoring for Community Systems

System Name: Harbour Isles Master Associate MONITORING & REPORTS	DUE	PWS-ID No. 6412551 COMMENTS
Microbiological ("Bacteriological")	Monthly	Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)	Quarterly	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2029	Sample annually according to approved Asbestos Monitoring Plan. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June – Sept 2023	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2023	CCR must be delivered by July 1, 2023. The CCR Certification of Delivery must be submitted to the Department by August 10, 2023. Use Form 62- 555.900(alternate 19), F.A.C.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2023 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by <u>9/30/2023</u> to provide time for revisions, retests, and/or corrections.
- > Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.