



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

Belleair Water Plant

PWS-ID No. 6520135

MONITORING & REPORTS		DUE	COMMENTS
Microbiological ("Bacteriological")		Monthly	Disinfectant residuals must be reported.
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2020	Sample at each POE every three, six or nine years.
	Uranium	2020	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>		July - Sept 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

Clearwater Water System (Systemwide)

PWS-ID No. 6520336

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	100 Distribution samples per month. Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June - Sept 2020	Sample from sites approved on the Lead & Copper Sampling Plan every three years.
Water Quality Parameters (WQP)	June - Sept 2019	Sample from sites approved on the Lead & Copper Sampling Plan annually.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.
Cross-Connection Control Annual Report	March 31, 2019	Complete and submit DEP form 62-555.900(13).

Clearwater Water System (WTP #1 – Palmetto Street)

PWS-ID No. 652-0336

MONITORING & REPORTS	DUE	COMMENTS	
Nitrate and Nitrite	2019	Sample at each POE every year. *	
Primary Inorganics	2020	Sample at each POE every three years.	
Secondaries	2020	Sample at each POE every three years.	
Radiologicals	Gross Alpha	2026	Sample at each POE every three, six or nine years.
	Uranium	2026	Sample at each POE every three, six or nine years.
	Radium-226	2023	Sample at each POE every three, six or nine years.
	Radium-228	2023	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)	2020	Sample at each POE every three years.	
Cis-1,2-Dichloroethylene (2380)	2019	Sample at POE annually.	
Synthetic Organic Contaminants (SOCs)	2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.	
Di(2-Ethylhexyl) Phthalate (2039)	2019	Sample at POE annually.	

MONITORING & REPORTS		DUE	COMMENTS
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2023	Sample at each POE every three, six or nine years.
	Uranium	2026	Sample at each POE every three, six or nine years.
	Radium-226	2023	Sample at each POE every three, six or nine years.
	Radium-228	2023	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

MONITORING & REPORTS		DUE	COMMENTS
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2026	Sample at each POE every three, six or nine years.
	Uranium	2026	Sample at each POE every three, six or nine years.
	Radium-226	2023	Sample at each POE every three, six or nine years.
	Radium-228	2023	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

Dunedin Water System

PWS-ID No. 6520486

MONITORING & REPORTS		DUE	COMMENTS
Microbiological ("Bacteriological")		Monthly	50 Distribution samples per month. Disinfectant residuals must be reported.
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2020	Sample at each POE every three, six or nine years.
	Uranium	2023	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>		Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report		March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

2019 Chemical Monitoring for Community Systems

Gulfport Water System

PWS-ID No. 6520705

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	10 Distribution samples per month. Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report	March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

Lake Tarpon Mobile Home Village

PWS-ID No. 6521000

MONITORING & REPORTS		DUE	COMMENTS
Microbiological ("Bacteriological")		Monthly	1 Raw water sample per well. 2 Distribution samples per month. Disinfectant residuals must be reported.
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2021	Sample at each POE every three years.
Secondaries		2021	Sample at each POE every three years.
Radiologicals	Gross Alpha	2024	Sample at each POE every three, six or nine years.
	Uranium	2021	Sample at each POE every three, six or nine years.
	Radium-226	2021	Sample at each POE every three, six or nine years.
	Radium-228	2021	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2021	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2021	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>		July - Sept 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2021	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2021	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

Pinellas County Utilities

PWS-ID No. 6521405

MONITORING & REPORTS		DUE	COMMENTS
Microbiological ("Bacteriological")		Monthly	180 Distribution samples per month. Disinfectant residuals must be reported.
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2020	Sample at each POE every three, six or nine years.
	Uranium	2020	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Dalapon (2031)		July - Sept 2019	Sample at the Keller Plant POE in 2019.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>		Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Water Quality Parameters (WQPs)		June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report		March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

2019 Chemical Monitoring for Community Systems

Pinellas Park Water Department

PWS-ID No. 6521406

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	50 Distribution samples per month. Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June-Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report	March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

2019 Chemical Monitoring for Community Systems

Oldsmar Water System

PWS-ID No. 6521405

MONITORING & REPORTS		DUE	COMMENTS
Microbiological ("Bacteriological")		Monthly	11 Raw samples and 15 Distribution samples per month. Disinfectant residuals must be reported.
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2023	Sample at each POE every three, six or nine years.
	Uranium	2023	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>		July - Sept 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report		March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

2019 Chemical Monitoring for Community Systems

Safety Harbor Water Department

PWS-ID No. 6521576

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	15 Distribution samples per month. Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report	March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valensteln
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

Southern Comfort MHP

PWS-ID No. 6521680

MONITORING & REPORTS		DUE	COMMENTS
Raw Water Microbiological ("Bacteriological")		Monthly	1 Raw Water Sample per well.
Distribution Microbiological ("Bacteriological")		Monthly	1 Distribution Samples per month. Disinfectant residuals must be reported.
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2021	Sample at each POE every three years.
Secondaries		2021	Sample at each POE every three years.
Radiologicals	Gross Alpha	2021	Sample at each POE every three, six or nine years.
	Uranium	2024	Sample at each POE every three, six or nine years.
	Radium-226	2021	Sample at each POE every three, six or nine years.
	Radium-228	2021	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2021	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2021	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>		July - Sept 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2021	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June - Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

City of St. Petersburg

PWS-ID No. 6521715

MONITORING & REPORTS		DUE	COMMENTS
Microbiological ("Bacteriological")		Monthly	150 Distribution samples per month. Disinfectant residuals must be reported.
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2020	Sample at each POE every three, six or nine years.
	Uranium	2020	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>		Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos		2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper		June – Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Water Quality Parameters (WQPs)		June – Sept 2020	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report		March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery		July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

2019 Chemical Monitoring for Community Systems

Tarpon Springs Water System (Systemwide)

PWS-ID No. 6521784

MONITORING & REPORTS	DUE	COMMENTS
Distribution Microbiological ("Bacteriological")	Monthly	30 Distribution samples per month. Disinfectant residuals must be reported.
Raw Water Microbiological ("Bacteriological")	Monthly	Sample active wells that are not connected to a 4-log approved WTP each month.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July - Sept 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June - Sept 2019	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Cross-Connection Control Annual Report	March 31, 2019	Complete and submit DEP form 62-555.900(13).
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

Tarpon Springs Water System (RO WTP)

PWS-ID No. 652-1784

MONITORING & REPORTS	DUE	COMMENTS	
Nitrate and Nitrite	2019	Sample at each POE every year. *	
Primary Inorganics	2020	Sample at each POE every three years.	
Secondaries	2020	Sample at each POE every three years.	
Radiologicals	Gross Alpha	2026	Sample at each POE every three, six or nine years.
	Uranium	2026	Sample at each POE every three, six or nine years.
	Radium-226	2026	Sample at each POE every three, six or nine years.
	Radium-228	2026	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)	2020	Sample at each POE every three years.	
Synthetic Organic Contaminants (SOCs)	2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.	
Dinoseb (2041)	Quarterly 2019	Sample at RO WTP quarterly.	

MONITORING & REPORTS		DUE	COMMENTS
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2023	Sample at each POE every three, six or nine years.
	Uranium	2023	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.

MONITORING & REPORTS		DUE	COMMENTS
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2020	Sample at each POE every three, six or nine years.
	Uranium	2020	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.

MONITORING & REPORTS		DUE	COMMENTS
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2023	Sample at each POE every three, six or nine years.
	Uranium	2020	Sample at each POE every three, six or nine years.
	Radium-226	2020	Sample at each POE every three, six or nine years.
	Radium-228	2020	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.

MONITORING & REPORTS		DUE	COMMENTS
Nitrate and Nitrite		2019	Sample at each POE every year. *
Primary Inorganics		2020	Sample at each POE every three years.
Secondaries		2020	Sample at each POE every three years.
Radiologicals	Gross Alpha	2020	Sample at each POE every three, six or nine years.
	Uranium	2020	Sample at each POE every three, six or nine years.
	Radium-226	2023	Sample at each POE every three, six or nine years.
	Radium-228	2023	Sample at each POE every three, six or nine years.
Volatile Organic Contaminants (VOCs)		2020	Sample at each POE every three years.
Synthetic Organic Contaminants (SOCs)		2 Quarters in 2020	Sample at each POE every three years, or submit SOC reduced monitoring waiver, if applicable. Use Form 62-560.545(2), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**



FLORIDA DEPARTMENT OF Environmental Protection

Southwest District Office
13051 North Telecom Parkway #101
Temple Terrace, Florida 33637-0926

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

2019 Chemical Monitoring for Community Systems

Innisbrook Resort and Golf Club

PWS-ID No. 6524777

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacteriological")	Monthly	2 Distribution samples per month. Disinfectant residuals must be reported.
Stage II Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly 2019	Sample according to approved Stage 2 D/DBPR Monitoring Plan.
Asbestos	2020	Certification or results due every nine years. Use Form 62-555.900(10), F.A.C.
Lead & Copper	June - Sept 2021	Sample from sites approved on the Lead and Copper Sampling Plan every three years.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019	CCR must be delivered by July 1, 2019. The CCR Certification of Delivery must be submitted to the Department by August 10, 2019. Use Form 62-555.900(alternate 19), F.A.C.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions or disagree with the assessment, please contact the appropriate personnel at (813) 470-5700. Monitoring schedules are subject to change, at any time, based on results of analyses or other factors. This chart shall not relieve any person from any requirement of Florida law.

It is important for you to provide this information to your operator and/or sampler:

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/2019 to provide time for revisions, re-tests, and/or corrections.**
- **Test results must be submitted to DEP within the first ten days following the end of the required monitoring period, or the first ten days following the month in which the sample results were received, whichever time is the shortest. Failure to comply may result in enforcement action.**