



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030050

System Type: Community

PWS Name: BAY COUNTY WATER SYSTEM

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Annually	2025	
		Secondary Contaminants	Triennially	2026	
		Volatile Organics (VOCs)	Annually	2025	
		Radionuclides	9 years	2031	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially must include dioxin	2026	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Monthly samples collected in 2025 at WMXB - MEXICO BEACH MASTER METER RW21 - 2521 PALO ALTO AVE W17 - 17TH ST AT MLK BLVD, NW SIDE OF INTERSECTION NB13 - 6340 GRASSY POINT RD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030141

System Type: Community

PWS Name: CALLAWAY CITY OF WATER SYSTEM

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	First week of January, April, July, and October 2025	at HERITAGE WOODS LIFTSTATION 20 JAMES ST 4TH ST LIFT STATION 31 HWY 2297 LIFT STATION 36 for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.

- Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030148

System Type: Community

PWS Name: SPRINGFIELD CITY OF

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	1 st week of March, June, September, and December 2025 at 117 HARLEM 2723 ARDEN AVE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.

- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030435

System Type: Community

PWS Name: LYNN HAVEN CITY OF WATER SYS.

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2026	
		Secondary Contaminants	Triennially	2026	
		Volatile Organics (VOCs)	Triennially	2026	
		Radionuclides	9 years	2029	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially 2 nd set	2026	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	2 nd week of February, May, August, and November 2025 at 109 CASHEL MARA 3203 AZALEA CIRCLE 1300 RHODE ISLAND 3431 CHERRY RIDGE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030467

System Type: Community

PWS Name: MEXICO BEACH CITY OF

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	1 st week of March, June, September, and December 2025	at 140 Palm Street 413 La Siesta Dr. for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos-Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.

- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030515

System Type: Community

PWS Name: PANAMA CITY BEACH CITY OF

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Monthly samples collected in 2025 at 5226 FINISTERE DR - SS264 112 GOLF DR - SS272 2225 THOMAS DR - SS141 9230 WIDENER ST - SS160 HERON TURN - SS266 12561 EMERALD LAKE DR - SS111 314 PIRATES COVE - SS76 17120 PCB PKWY - SS23 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030517

System Type: Community

PWS Name: PANAMA CITY WATER SYSTEM

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	February, May, August, and November 2025 at JOHN PITTS & AMBER WAY (SITE 142) COLLEGIATE DR & N BAY DR (SITE 3) 8TH ST & PREMIER DR (SITE 17) GRAY AVE & 1ST PLAZA (SITE 29) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.

- Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030520

System Type: Community

PWS Name: PARKER CITY OF WATER SYSTEM

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	1st Week of August 2025 at 5307 SOULE DR 4617 HYACINTH ST for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.

- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030568

System Type: Community

PWS Name: CREEKSIDE ESTATES PC, LLC WATER SYSTEM

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	Gross Alpha	2027	
			Rad 226 & 228	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		August 2027 at 1403 29TH CT for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Annually	Jun-Sep 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030716

System Type: NTNC

PWS Name: WALLER ELEMENTARY SCHOOL

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	September 2025 at BUILDING 4 ROOM 104 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030774

System Type: NTNC

PWS Name: FLORIDA POWER AND LIGHT LANSING-SMITH PLANT

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Radionuclides	Wells 4 & 6	2027	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2025 at UNIT 3 for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034054

System Type: Community

PWS Name: DEER HAVEN PARK

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2027 at LOT #23 (Entry to Distribution) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034106

System Type: NTNC

PWS Name: STACEY'S SWINGERS DAY CARE

2027 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2025 at AFTER SCHOOL BUILDING SINK #1 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034168

System Type: NTNC

PWS Name: PRECIOUS MEMORIES NO. 2

2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Secondary Contaminants	Triennially	Not required for NTNC	
		Volatile Organics (VOCs)	Triennially	2025	
		Radionuclides	6 years	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2025 at BACK ROOM SINK for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not

approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.