

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1070014 PWS Name: ALTHA TOWN OF WATER SYSTEM

System Type: Community

## 2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring		
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2025		
		Primary Inorganics	Triennially	2027		
		Secondary Contaminants	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution	
		Volatile Organics (VOCs)	Triennially	2027		
			Gross Alpha	2027 - Wells 1, 2, 3		
		Radionuclides	Rad 226/228	2027 - Wells 1 & 3 2030 - Well 2		
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	25764 1	August 2025 at 25764 NE ALLIANCE ROAD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 10	

#### PWS ID: 1070014 PWS Name: ALTHA TOWN OF WATER SYSTEM

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
  - Community and NTNC Public Water Systems must sample during each month.
    - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
    - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
    - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1070116 PWS Name: CARR SCHOOL System Type: NTNC

### 2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution	
		Primary Inorganics	Triennially	2025		
		Volatile Organics (VOCs)	Triennially	2025		
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2025 at BOY'S RESTROOM for TTHMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 5	

\*Submit *Asbestos Plan or Abestos Free Certification* and *SOC Waiver Requests* by **October 31**<sup>st</sup> to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

PWS ID: 1070116 PWS Name: CARR SCHOOL

and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1070685 PWS Name: BLOUNTSTOWN CITY OF

System Type: Community

### 2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2025		
		Primary Inorganics	Triennially	2026		
		Secondary Contaminants	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution	
		Volatile Organics (VOCs)	Triennially	2026	distribution	
		Radionuclides	Gross Alpha	Well 1 & 2 - 2032; Well 3 - 2026		
			RAD 226/228	Well 1- 2029; Well 2 & 3 - 2032		
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	1943	August 2025 at 19431 HWY 71 NORTH for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 20	

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
  - Community and NTNC Public Water Systems must sample during each month.
    - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
    - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
    - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1074015 PWS Name: SHELTON TRUCKING SERVICE INC.

System Type: NTNC

## 2025 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2025	
		Primary Inorganics	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2025 at FRONT OFFICE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\****Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.