

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1230545 PWS Name: PORT ST. JOE CITY OF

System Type: Community

## 2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Annually	2023	
		Secondary Contaminants	Annually	2025	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Annually	2023	distribution
		Radionuclides	9 years	2029	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs) including Dioxin	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a
		SOC - Dalapon	Annually	4 <sup>th</sup> Qtr 2023	waiver using <u>Form 62-560.545(2)</u>
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	79 STANDPIPE AT	May, August, and November 2023 at 94 CHARLES AVE 3871 E HWY 98 17 LILAC ST & W. BEATTY AVE 348 MARLIN ST THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

## **Bacteriological Monitoring**

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
  - Community and NTNC Public Water Systems must sample during each month.
    - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
    - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
    - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1230734 PWS Name: WEWAHITCHKA CITY OF

System Type: Community

## 2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2024	_
		Secondary Contaminants	Triennially	2024	_ Sample at <u>each</u> Point of Entry to the
		Volatile Organics (VOCs)	Triennially	2024	distribution
		VOC - Xylene	Annually	1 <sup>st</sup> qtr 2023	
		Radionuclides	6 years	2024	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2023 at RIAN STREET (NEAR RISH) ITHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

## **Bacteriological Monitoring**

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
  - Community and NTNC Public Water Systems must sample during each month.
    - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
    - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
    - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1230848 PWS Name: GULF COUNTY WATER DEPARTMENT System Type: Community

## 2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution
		Secondary Contaminants	Triennially	2023	
		Secondary - Odor	Resample	1 <sup>st</sup> qtr 2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha	<b>2026</b> - Well 2 <b>2027</b> - Well 4	
		Kadionuciides	Rad 226 & 228	<b>2024</b> - Well 4 <b>2026</b> - Well 2	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	561 BA	7, May, August, and November 2023 at ARRIER DUNES DRIVE 7182 SR-30 TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 20
					Page 1 of 2

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

## **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
  - Community and NTNC Public Water Systems must sample during each month.
    - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
    - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
    - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1234011 PWS Name: GULF FORESTRY WORK CAMP

System Type: Community

## 2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	6 years	2024	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	for	July 2024 at WAREHOUSE ITHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

#### PWS ID: 1234011 PWS Name: GULF FORESTRY WORK CAMP

#### approved.

**\*\****Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1234013 PWS Name: GULF CORRECTIONAL INSTITUTION System Type: Community

## 2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the
		Volatile Organics (VOCs)	Triennially	2024	distribution
			Gross Alpha	2023	
		Radionuclides	Rad 226 & 228	2026	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population $>3,300$ must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2023 at ILER PARK LOT #20 ITHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

#### PWS ID: 1234013 PWS Name: GULF CORRECTIONAL INSTITUTION

#### approved.

**\*\****Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <a href="https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical">https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical</a>.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.

A CONTRACTOR OF THE OWNER	Drinking Water	DEP Northwest District Potable Water Office		
	Program	160 W. Government Street, Suite 308 Pensacola, FL 32502		
DEP NW District Contacts	General #:(850) 595-8300 Fax #: (850) 595-8392	Important Reminders		
	Michael Mucci			
- Environmental Managar	(850) 595-0569			
~Environmental Manager	Michael.Mucci@floridadep.gov			
	Alyssa Tessier			
~Stage 2 Disinfection Byproducts	(850) 595-0685	Email DBP results to: <u>NWDPWS@floridadep.gov</u>		
(DBP) Compliance	Alyssa.Tesier@floridadep.gov	Community and NTNC Systems should be monitoring according to their most current Stage 2 DBP		
~Disinfectant Residuals Reports ~Precautionary Boil Water Notices	Email DBP results to: NWDPWS@floridadep.gov	monitoring plan. Contact Alyssa if you have any questions concerning your monitoring plan.		
~Chemical Compliance (Nitrates/Nitrites,	Paula Smith	Call if you have any questions on requirements		
Inorganics, SOC, VOC, Asbestos,	(850) 595-0632			
Secondaries, Rads)	Paula.Smith@floridadep.gov	Email Chem results to Paula at her individual account ( <u>Paula.Smith@floridadep.gov</u> )		
	Jack Darby			
~Consumer Confidence Reports (CCR)	(850) 595-0689 Jack.Darby@floridaDEP.gov	For community water systems, CCRs must be delivered to customers by July 1st every year.		
~Potable Water Compliance &	Angelia Butler	If you ever need help with something regarding DEP potable water regulations, please consider using our Public Outreach Request Form at: <u>http://www.surveygizmo.com/s3/878438/Request-DEP-</u>		
Enforcement, Cross Connection Control	(850) 595-0598 Angelia.Butler@floridadep.gov	Northwest-District-Compliance-Assistance		
		Load & Connerton complian sites should be verified aband of anyoling to anyone between the		
~Lead and Copper Rule (LCR) Tap Monitoring	Roger Thomas (850) 595-0660	Lead & Copper tap sampling sites should be verified ahead of sampling to ensure homes are not vacant and that homeowners are still willing to participate.		
~Precautionary Boil Water Notices	Roger.N.Thomas@floridadep.gov	Email LCR results to NWDPWS@floridadep.gov		
	Any Drinking Water NWD Staff	Email MORs to: <u>DWRM_Data_Entry_Tal@dep.state.fl.us</u> ( cc: <u>NWDPWS@floridadep.gov</u> ) Email BWNs (issuances, rescissions, and clearance results) to: <u>NWDPWS@floridadep.gov</u>		
	Email MORs to:	Notify this office of Boil Water Notices or other abnormal operating conditions as soon as possible, but		
~Monthly Operation Reports (MORs) ~Boil Water Notices (BWNs)	DWRM Data Entry Tal@dep.state.fl.us ALSO cc: NWDPWS@floridadep.gov	Notify this office of Boll Water Notices or other abnormal operating conditions as soon as possible, but never later than noon of the next business day. Planned events that may adversely affect finished-water quality, interrupt water service to 150 or more service connections or 350 or more people, interrupt water service to any one service connection for more than eight hours, or necessitate the issuance of a precautionary "boil water" notice in accordance with the Department of Health's "Guidelines for the Issuance of Precautionary Boil Water Notices" must be reported to this office no later than the <u>previous</u> business day.		
	Email BWN info and clearance bacti-s to: NWDPWS@floridadep.gov			
	Kelly Dunn	Email Bact. compliance results (routine and repeat) to: <u>NWDPWS@floridadep.gov</u>		
~Bacteriological Compliance	(850) 595-0562			
(Routine Bact. Sampling, Well & Tank Clearances, Revised Total Coliform &	Kelly.Dunn@floridadep.gov	Please sample EARLY to prevent last-minute mix-ups and allow resampling within the monitoring period if necessary! Lab results are due within the first 10 days following the end of the required		
Ground Water Rules)	Email Bact. compliance results (routine and repeat) to: <u>NWDPWS@floridadep.gov</u>	monitoring period. Reporting forms that are incomplete, incorrect, or illegible may be considered invalid.		
	Katie Ates	The Department is committed to the expeditious review of applications and issuance of permits. 1)		
~General Permits	(850) 595-0656	Water systems must verify that written clearance has been granted by this office before providing water to (placing into permanent operation) any permitted PWS construction project; 2) Please		
~Permit Clearances	Katie.L.Ates@floridadep.gov	water to (placing into permisent operation) any permitted rwo construction project, 2) rease notify this office in writing before modifying any permitted work so it can be determined whether a supplemental permit application will be required.		
	TBD			
	(850) 767-0044			
Panama City Office				
	Larry Couch			
	(850) 767-0047 Larry.Couch@floridadep.gov			
	Tracy White			
	(850) 245-7628			
Tallahassee Branch Office	Tracy.A.White@floridadep.gov			
	Colby Saults (850) 245-7627			
	(850) 245-7627 Colby.Saults@floridadep.gov			
	Mark C. Sumner			
Branch Office Environ. Administrator	850-767-0046			
1	Mark.C.Sumner@dep.state.fl.us			
Important Numbers and Websites		4 (200) 220 0540		
State Watch Office		1-(800)-320-0519 (950)-245-7500		
FDEP Operator Certification FDEP State Revolving Fund		(850) 245-7500 (850) 245-2835		
FDEP State Revolving Fund		(000) 240-2000 https://floridadep.gov/		
FDEP Northwest District Website		https://floridadep.gov/northwest/		
Water Tracker Website: Please email water	ertracker@floridaden.gov.if.vou.do			
not have a user name and/or password	n you du	https://flwatertracker.com		
OCULUS - FDEP electronic document		https://depedms.dep.state.fl.us/Oculus/		
management system				
management system Florida Rural Water Association, (FRWA)		https://www.frwa.net		