

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320011 System Type: Community

PWS Name: ALFORD TOWN OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
		Nitrate & Nitrite	Annually	2023					
		Primary Inorganics	Triennially	2024					
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution				
		Volatile Organics (VOCs)	Triennially	2024	distribution				
		Radionuclides	9 years	2027					
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*				
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at ALFORD PUBLIC WORKS for TTHMs and HAA5s**					
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5				

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: ALFORD TOWN OF

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320025 System Type: Community

PWS Name: APALACHEE CORRECTIONAL INSTITUTION

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Somula at each Daint of Entwy to the
		Volatile Organics (VOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Radionuclides	Gross Alpha	2024 - Well 3 2027 - Wells 2, 2A	
			Rad 226 & 228	2027 - All Wells	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- 555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	for 7	July 2023 at DAIRY FARM THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

PWS Name: APALACHEE CORRECTIONAL INSTITUTION

approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320111 System Type: Community

PWS Name: CAMPBELLTON WATER DEPARTMENT

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2023				
		Primary Inorganics	Triennially	2024				
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution			
		Volatile Organics (VOCs)	Triennially	2024	distribution			
		Radionuclides	9 years	2027				
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	for T	August 2024 at 2251 HWY 2 TTHMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5			

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: CAMPBELLTON WATER DEPARTMENT

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320143 System Type: Community

PWS Name: COTTONDALE WATER SYSTEM

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		VOC - Vinyl chloride	Annually	4 th Qtr Well 3 - 2023	
		D 11 11 1		2027 - Well 3	
		Radionuclides	9 years	2030 - Well 2	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	CITY	August 2023 at RECREATION PARK THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

PWS Name: COTTONDALE WATER SYSTEM

*Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320145 System Type: Community

PWS Name: GRACEVILLE CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
		Nitrate & Nitrite	Annually	2023					
		Primary Inorganics	Triennially	2023					
		Secondary Contaminants	Triennially	2023	Sample at <u>each</u> Point of Entry to the				
		Volatile Organics (VOCs)	Triennially	2023	distribution				
		Radionuclides	9 years	2026					
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*				
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	for 7	July 2023 at 5565 HWY 77 FTHMs and HAA5s**				
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20				

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

PWS Name: GRACEVILLE CITY OF

approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320263 System Type: NTNC

PWS Name: DOT MAINTENANCE YARD

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2025	Sample at <u>each</u> Point of Entry to the
		Volatile Organics (VOCs)	Triennially	2025	distribution
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- 555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	September 2025 at WAREHOUSE SHED for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

PWS Name: DOT MAINTENANCE YARD

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320311 System Type: Community

PWS Name: GREENWOOD WATER SYSTEM

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
		Nitrate & Nitrite	Annually	2023					
		Primary Inorganics	Triennially	2024					
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution				
		Volatile Organics (VOCs)	Triennially	2024	distribution				
		Radionuclides	9 years	2027					
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*				
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at DOVE NEST LANE for TTHMs and HAA5s**					
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10				

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: GREENWOOD WATER SYSTEM

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320440 System Type: Community

PWS Name: MALONE TOWN OF WATER SYSTEM

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
	•	Nitrate & Nitrite	Annually	2023					
		1	Quarterly	Well 2					
		Primary Inorganics	Triennially	2024					
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution				
		Volatile Organics (VOCs)	Triennially	2024					
		Radionuclides	9 years	2027 - Well 4					
		Radionuciides	9 years	2030 - Well 2					
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*				
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		August 2023 at & COLLINS CHAPEL RD TTHMs and HAA5s**				
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10				

*Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

PWS Name: MALONE TOWN OF WATER SYSTEM

approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320444 System Type: NTNC

PWS Name: ADMINISTRATIVE SERVICE CENTER - REGION 1

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
		Nitrate & Nitrite	Annually	2023					
		Primary Inorganics	Triennially	2025	Sample at <u>each</u> Point of Entry to the				
		Volatile Organics (VOCs)	Triennially	2025	distribution				
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*				
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)				
		SOC - benzo(a)pyrene	Quarterly	2023	Public notice must be reissued during 1 st & 2 nd quarter 2023				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2025 at WWTP for TTHMs and HAA5s**					
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5				

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: ADMINISTRATIVE SERVICE CENTER - REGION 1

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320449 System Type: Community

PWS Name: MARIANNA CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	Canada at and Daint of Future to the
		Volatile Organics (VOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution
			Gross Alpha	2026	
		Radionuclides	Rad 226 & 228	2023 - Well 5 2026 - Wells 1, 6, 7	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- 555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	374	October 2023 at 1 INDUSTRIAL PK THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

PWS Name: MARIANNA CITY OF

approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320686 System Type: Community

PWS Name: GRAND RIDGE TOWN OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring

Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
			Gross Alpha	2024 - Wells 1, 3	
		Radionuclides	Gloss Alpha	2027 - Wells 2, 4	
		Kadionuciaes	Rad 226 & 228	2027 - Wells 2, 4	
			Rad 220 & 228	2030 - Wells 1, 3	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- 555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	LIFT STATION 7	eptember 2023 at #1 (6566 GRANDE OAK LOOP) THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

PWS Name: GRAND RIDGE TOWN OF

*Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320689 System Type: Community

PWS Name: SNEADS TOWN OF WATER SYSTEM

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2023				
		Primary Inorganics	Triennially	2024				
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution			
		Volatile Organics (VOCs)	Triennially	2024	distribution			
		Radionuclides	9 years	2027				
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- 555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	PAULA	August 2023 at STREET (DEAD END) THMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10			

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: SNEADS TOWN OF WATER SYSTEM

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320879 System Type: Community

PWS Name: QUIET HAVEN TRAILER PARK

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2024		
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution	
		Volatile Organics (VOCs)	Triennially	2024	distribution	
		Radionuclides	9 years	2027		
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	LOT 40	August 2024 at 2745 FLEETWOOD LN THMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: QUIET HAVEN TRAILER PARK

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324027 System Type: NTNC

PWS Name: SPANISH TRAIL LUMBER

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2025		
		Volatile Organics (VOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution	
			Gross Alpha	2028 - Well 3		
		Radionuclides	D 100 (0 000	2024 - Well 1	7	
		-	Rad 226 & 228	2028 - Well 3		
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		August 2025 at REAK BUILDING TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

PWS Name: SPANISH TRAIL LUMBER

approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324031 System Type: Community

PWS Name: JACOB CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2024		
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution	
		Volatile Organics (VOCs)	Triennially	2024	distribution	
		Radionuclides	9 years	2027		
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		August 2024 at 00 JACKSON ROAD FTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: JACOB CITY OF

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324046 System Type: NTNC

PWS Name: ALONG THE WAY DAYCARE

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2025	Sample at <u>each</u> Point of Entry to the	
		Volatile Organics (VOCs)	Triennially	2025	distribution	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		September 2025 at HALL BATH FTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

PWS Name: ALONG THE WAY DAYCARE

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324064 System Type: Community

PWS Name: BLUE SPRINGS MHP (AKA SPRINGSIDE)

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2024		
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution	
		Volatile Organics (VOCs)	Triennially	2024	distribution	
		Radionuclides	9 years	2027		
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	5	eptember 2024 at 147 GOLD LANE TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: BLUE SPRINGS MHP (AKA SPRINGSIDE)

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324074 System Type: Community

PWS Name: JACKSON CORRECTIONAL INSTITUTION

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Quarterly	2023	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
				2027 - Well 1	
		Radionuclides	Gross Alpha	2030 - Well 2	
			Rad 226 & 228	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2023 at E HOME PARK (MRT #1) FTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 10

PWS Name: JACKSON CORRECTIONAL INSTITUTION

*Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324092 System Type: NTNC

PWS Name: TIPPY TOES DAYCARE (DEE'S EARTH ANGELS)

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2023			
		Primary Inorganics	Triennially	2025			
		Volatile Organics (VOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution		
		Radionuclides	9 years	2028			
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		August 2025 at KITCHEN SINK FTHMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 4		

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

PWS Name: TIPPY TOES DAYCARE (DEE'S EARTH ANGELS)

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324098 System Type: Community

PWS Name: JACKSON COUNTY UTILITIES NO. 1

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2024		
		Secondary Contaminants	Triennially	2024	Somela at each Doint of Entwite the	
		Volatile Organics (VOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution	
		Radionuclides	9 years	2027		
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using <u>Form 62-560.545(2)</u>	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2023 at PARK DRIVE HYDRANT #12 TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: JACKSON COUNTY UTILITIES NO. 1

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324101 System Type: NTNC

PWS Name: SPRINGHILL REGIONAL LANDFILL

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2025		
		Volatile Organics (VOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution	
		VOC - Dichloromethane	Annual	4th Qtr 2023		
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		August 2025 at E BIB AT OLD SCALE TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: SPRINGHILL REGIONAL LANDFILL

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324199 System Type: NTNC

PWS Name: JACKSON COUNTY UTILITIES NO. 2

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
	•	Nitrate & Nitrite	Annually	2023		
		Primary Inorganics	Triennially	2025	Sample at <u>each</u> Point of Entry to the	
		Volatile Organics (VOCs)	Triennially	2025	distribution	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2025 at WY 231 HYDRANT #11 TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5	

^{*}Submit Asbestos Plan or Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

^{**}Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

PWS Name: JACKSON COUNTY UTILITIES NO. 2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - O A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.

	Drinking Water	DEP Northwest District Potable Water Office	
a de la constantina della cons	Program	160 W. Government Street, Suite 308 Pensacola, FL 32502	
DEP NW District Contacts	General #:(850) 595-8300	Important Reminders	
DEF TWV DISTRICT CONTACTS	Fax #: (850) 595-8392	Important reminuers	
	Michael Mucci		
~Environmental Manager	(850) 595-0569		
	Michael.Mucci@floridadep.gov		
	Alyssa Tessier		
~Stage 2 Disinfection Byproducts	(850) 595-0685	Email DBP results to: nwbpws@floridadep.gov	
(DBP) Compliance ~Disinfectant Residuals Reports	Alyssa.Tesier@floridadep.gov	Community and NTNC Systems should be monitoring according to their most current Stage 2 DBP	
~Precautionary Boil Water Notices	Email DBP results to: NWDPWS@floridadep.gov	monitoring plan. Contact Alyssa if you have any questions concerning your monitoring plan.	
	Paula Smith		
~Chemical Compliance (Nitrates/Nitrites, Inorganics, SOC, VOC, Asbestos,	(850) 595-0632	Call if you have any questions on requirements	
Secondaries, Rads)	Paula.Smith@floridadep.gov	Email Chem results to Paula at her individual account (Paula.Smith@floridadep.gov)	
	Jack Darby		
~Consumer Confidence Reports (CCR)	(850) 595-0689	For community water systems, CCRs must be delivered to customers by July 1st every year.	
	Jack.Darby@floridaDEP.gov		
	Angelia Butler	Management of the control of the con	
~Potable Water Compliance & Enforcement, Cross Connection Control	(850) 595-0598	If you ever need help with something regarding DEP potable water regulations, please consider using our Public Outreach Request Form at: http://www.surveygizmo.com/s3/878438/Request-DEP-	
	Angelia.Butler@floridadep.gov	Northwest-District-Compliance-Assistance	
~Lead and Copper Rule (LCR) Tap	Roger Thomas	Lead & Copper tap sampling sites should be verified ahead of sampling to ensure homes are not	
Monitoring	(850) 595-0660	vacant and that homeowners are still willing to participate.	
~Precautionary Boil Water Notices	Roger.N.Thomas@floridadep.gov	Email LCR results to NWDPWS@floridadep.gov	
	Any Drinking Water NWD Staff	Email MORs to: <u>DWRM_Data_Entry_Tal@dep.state.fl.us_(</u> cc: <u>NWDPWS@floridadep.gov_)</u> Email BWNs (issuances, rescissions, and clearance results) to: <u>NWDPWS@floridadep.gov_</u>	
~Monthly Operation Reports (MORs) ~Boil Water Notices (BWNs)	Email MORs to: DWRM Data Entry Tal@dep.state.fl.us ALSO cc: NWDPWS@floridadep.gov	Notify this office of Boil Water Notices or other abnormal operating conditions as soon as possible, but never later than noon of the next business day. Planned events that may adversely affect finished-water quality, interrupt water service to 150 or more service connections or 350 or more people, interrupt water service to any one service connection for more than eight hours, or necessitate the issuance of a	
	Email BWN info and clearance bacti-s to: NWDPWS@floridadep.gov	precautionary "boil water" notice in accordance with the Department of Health's "Guidelines for the Issuance of Precautionary Boil Water Notices" must be reported to this office no later than the <u>previous</u> business day.	
		E-11 Port and the form of the state of the s	
~Bacteriological Compliance	Kelly Dunn (850) 595-0562	Email Bact. compliance results (routine and repeat) to: NWDPWS@floridadep.gov	
(Routine Bact. Sampling, Well & Tank Clearances, Revised Total Coliform &	Kelly.Dunn@floridadep.gov	Please sample EARLY to prevent last-minute mix-ups and allow resampling within the monitoring period if necessary! Lab results are due within the first 10 days following the end of the required	
Ground Water Rules)	Email Bact. compliance results (routine and repeat) to: https://www.nwbpws.gelloridadep.gov	monitoring period. Reporting forms that are incomplete, incorrect, or illegible may be considered invalid.	
	Katie Ates	The Department is committed to the expeditious review of applications and issuance of permits. 1)	
~General Permits ~Permit Clearances	(850) 595-0656	Water systems must verify that written clearance has been granted by this office before providing water to (placing into permanent operation) any permitted PWS construction project; 2) Please	
Terrint Glearances	Katie.L.Ates@floridadep.gov	notify this office in writing before modifying any permitted work so it can be determined whether a supplemental permit application will be required.	
	TBD		
	(850) 767-0044		
Panama City Office			
	Larry Couch		
	(850) 767-0047		
	Larry.Couch@floridadep.gov Tracy White		
	Tracy White (850) 245-7628	No or recent recent constructions on the construction of the const	
Tollohoone Press b Office	Tracy.A.White@floridadep.gov	<u> </u>	
Tallahassee Branch Office	Colby Saults		
	(850) 245-7627]	
	Colby.Saults@floridadep.gov		
Branch Office Environ Administrate	Mark C. Sumner		
Branch Office Environ. Administrator 850-767-0046 Mark.C.Sumner@dep.state.fl.us		1	
Important Numbers and Websites			
State Watch Office		1-(800)-320-0519	
FDEP Operator Certification		(850) 245-7500	
FDEP State Revolving Fund		(850) 245-2835	
FDEP Website		https://floridadep.gov/	
FDEP Northwest District Website		https://floridadep.gov/northwest/	
Water Tracker Website: Please email water not have a user name and/or password OCULUS - FDEP electronic document	ertracker@floridadep.gov if you do	https://flwatertracker.com	
management system		https://depedms.dep.state.fl.us/Oculus/	
Florida Rural Water Association, (FRWA)		https://www.frwa.net	
Floridan Newsletter		https://floridadep.gov/subscribe	
Tapline Newsletter		http://www.floridadep.gov/northwest/nw-outreach/content/northwest-district-newsletters	