

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370023 PWS Name: ANNAWOOD SUBDIVISION System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	8	September 2024 at 12 PEGGY DRIVE ITHMs and HAA5s**				
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5				

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.

- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370077 PWS Name: BLOUNT'S LANDING WATER SYSTEM System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at 244 LANIER STREET TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370096 PWS Name: BURGESS CIRCLE SUBDIVISION

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	312	September 2024 at 9 BURGESS CIRCLE TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370288 PWS Name: TWIN LAKES MOBILE HOME PARK System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at SISTRUNK CIRCLE TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

PWS ID: 1370288 PWS Name: TWIN LAKES MOBILE HOME PARK

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370353 PWS Name: LEON CO. REGIONAL SYSTEM EAST

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
		Nitrate & Nitrite	Annually	2024					
		Primary Inorganics	Triennially	2024					
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution				
		Volatile Organics (VOCs)	Triennially	2024	distribution				
		Radionuclides	9 years	2027					
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*				
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		August 2024 at 8 FOXWWOD DRIVE TTHMs and HAA5s**				
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10				

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370393 PWS Name: BRADFORDVILLE REGIONAL W/S

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2026	
		Secondary Contaminants	Triennially	2026	
		Volatile Organics (VOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution
			Gross Alpha	2026	
		Radionuclides	D 100 (0 000)	2026 - All other wells	
			Rad 226 & 228	2029 - Well Bradfordville	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	8712 7140	eptember 2024 at SPRING SHORE DR BEECH RIDGE TR THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370403 PWS Name: LAKE TALQUIN WATER COMPANY System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		D. 1	Gross Alpha	2027	
		Radionuclides	RAD 226/228	2024	_
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at 36 SUMMIT DRIVE TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5

PWS ID: 1370403 PWS Name: LAKE TALQUIN WATER COMPANY

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370461 PWS Name: MEADOW HILLS S/D WATER SYSTEM

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at 1503 DOVE ROAD TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370463 PWS Name: MERIDIAN HILLS WATER SYSTEM

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring		
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2024		
		Primary Inorganics	Triennially	2024		
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution	
		Volatile Organics (VOCs)	Triennially	2024	distribution	
		Radionuclides	9 years	2027		
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	MERIDIAN HILL	eptember 2024 at & RED HAWK (FLUSH STAND) THMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5	

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370598 PWS Name: SEDGEFIELD SUBDIVISION

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at BURNWELL STREET TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370616 PWS Name: GRAND VILLAGE MHP WEST System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2024				
		Primary Inorganics	Triennially	2024				
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution			
		Volatile Organics (VOCs)	Triennially	2024	distribution			
		Radionuclides	9 years	2027				
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at 482 EMILY LOOP TTHMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5			

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370617 PWS Name: LEON CO. REGIONAL SYSTEM SOUTH System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2024				
		Primary Inorganics	Triennially	2024				
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the			
		Volatile Organics (VOCs)	Triennially	2024	distribution			
		D 1' 1'1	Gross Alpha	2024				
		Radionuclides	Rad 226 & 228	2027	_			
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population $>3,300$ must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	TÎN	tember 2024 at 2556 JY LEAF ROAD for 'HMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10			

PWS ID: 1370617 PWS Name: LEON CO. REGIONAL SYSTEM SOUTH

approved.

*******Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370640 PWS Name: STONEGATE SUBDIVISION

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	2850	September 2024 at) PINE RIDGE DRIVE TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370655 PWS Name: TALLAHASSEE CITY OF

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2024		
		Primary Inorganics	Triennially	2026	-	
		Secondary Contaminants	Triennially	2026		
		Volatile Organics (VOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution	
		VOC - Tetrachloroethylene	Quarterly	GAC Wells		
		VOC - Trichloroethylene	Quarterly	GAC Wells		
		Radionuclides	See attached Chart	See attached Chart		
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	394 3024 LA 2773 F 371 3767 WAKU	ary, 20 th May, 19 th August, and 18 th November 2024 at 4 NW PASSAGE -MGD24 AKE BRADFORD RD - MGJ1 HANNON HILL DR -MGC41 8 LOMA FARM - MGM1 9 GREYFIELD DR - MGI26 JLLA RIVER CLUB - WV15 or TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 50	

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



WELL TRACKING CHART

SYSTEM NAME:	City of Tallahassee			PWS ID NO.: <u>1370655</u>		
Well #	GA	Rad 226	Rad 228	Comments		
CW02	2032	2032	2032	Sampled in 2023		
CW03	2032	2032	2032	Sampled in 2023		
CW04	2032	2032	2032	Sampled in 2023		
CW05	2032	2032	2032	Sampled in 2023		
CW06	2026	2026	2026	Sampled in 2017		
CW07	2032	2032	2032	Sampled in 2023		
CW08	2032	2032	2032	Sampled in 2023		
CW09	2032	2032	2032	Sampled in 2023		
CW10	2032	2032	2032	Sampled in 2023		
CW11	2032	2032	2032	Sampled in 2023		
CW12	2032	2032	2032	Sampled in 2023		
CW13	2032	2029	2029	Sampled GA 2023 & Rads 2020		
CW15	2032	2029	2029	Sampled GA 2023 & Rads 2020		
CW16	2032	2032	2032	Sampled in 2023		
CW17	2032	2029	2029	Sampled GA 2023 & Rads 2020		
CW18	2032	2032	2032	Sampled in 2023		
CW21	2032	2032	2032	Sampled in 2023		
CW22	2032	2032	2032	Sampled in 2023		
CW23	2029	2029	2029	Sampled GA 2023 & Rads 2020		
CW25	2032	2029	2029	Sampled GA 2023 & Rads 2020		
CW26	2023	2029	2029	Sampled GA 2014 & Rads 2020		
(OOS in 2023)						
CW27	2032	2032	2032	Sampled in 2023		
CW28	2032	2032	2032	Sampled in 2023		
CW29	2032	2032	2032	Sampled in 2023		
CW32	2028	2028	2028	Sampled in 2019		
CW33	2026	2029	2029	Sampled in 2020		
CW35	2032	2032	2032	Sampled in 2023		



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370669 PWS Name: MEADOWS-AT-WOODRUN

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

		_	Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2026	
		Secondary Contaminants	Triennially	2026	
		Volatile Organics (VOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution
			G 41.1	2026 Well 1	
			Gross Alpha	2029 Well 2	
		Radionuclides	D 100(0 000	2026 Well 1	
			Rad 226 & 228	2029 Well 2	1
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		August 2024 at) GOODWIN ROAD TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370745 PWS Name: LEON CO. REGIONAL SYSTEM WEST System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		VOC - trans-1,2- dichloroethene	Annually	2nd Qtr 2024 WP1 West]
		D 1' 1'1	0	2027 - WP2, Tower	
		Radionuclides	9 years	2029 - WP1	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use <u>Form 62-</u> <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	8439 LA	eptember 2024 at KE ATKINSON DRIVE THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10
					Daga 1 of 2

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

*******Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370791 PWS Name: LAKE BRADFORD ESTATES MHP System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2024			
		Primary Inorganics	Triennially	2024			
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution		
		Volatile Organics (VOCs)	Triennially	2024	distribution		
		Radionuclides	9 years	2027			
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	for	July 2024 at LOT 222/223 TTHMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5		

PWS ID: 1370791 PWS Name: LAKE BRADFORD ESTATES MHP

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370888 PWS Name: LAKE JACKSON AREA WATER SYSTEM System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2024			
		Primary Inorganics	Triennially	2026			
		Secondary Contaminants	Triennially	2026			
		Volatile Organics (VOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution		
			C 41.1	2026 OchInter			
			Gross Alpha	2029 Lake V, T4			
		Radionuclides	Radium 226 & 228	2026 Lake V, OchInter			
				2029 T4			
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2026	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 mus take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		August 2024 at NDIAN MOUND ROAD TTHMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 20		

PWS ID: 1370888 PWS Name: LAKE JACKSON AREA WATER SYSTEM

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1370898 PWS Name: BREWSTER SUBDIVISION

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at 0 BREWSTER ROAD TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1374008 PWS Name: BUCK LAKE ESTATES System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at 15 PINTAIL DRIVE TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1374049 PWS Name: NORTH LAKE MEADOW WATER SYSTEM

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2024		
		Primary Inorganics	Triennially	2024		
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the	
		Volatile Organics (VOCs)	Triennially	2024	distribution	
		D 1' 1' 1	Gross Alpha	2024		
		Radionuclides	Radium 226 & 228	2027		
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	for	July 2024 at 7278 KIDD DRIVE TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 5	

PWS ID: 1374049 PWS Name: NORTH LAKE MEADOW WATER SYSTEM

approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1374054 PWS Name: PLANTATION ESTATES

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at MISTLETOE DRIVE ITHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1374061 PWS Name: GRASSROOTS FREE SCHOOL INC.

System Type: NTNC

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
	-	Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2025	Sample at <u>each</u> Point of Entry to the
		Volatile Organics (VOCs)	Triennially	2025	distribution
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		August 2025 at T PORCH FOUNTAIN THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

*******Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E.</u> <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1374072 PWS Name: LAKE TALQUIN ESTATES (AKA DOGWOOD MHP) System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2024		
		Primary Inorganics	Triennially	2024		
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution	
		Volatile Organics (VOCs)	Triennially	2024	distribution	
		Radionuclides	6 years	2024		
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	for	August 2024 at LOT 2302 TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5	

PWS ID: 1374072 PWS Name: LAKE TALQUIN ESTATES (AKA DOGWOOD MHP)

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department within 10 days following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1374079 PWS Name: FORT BRADEN SCHOOL

System Type: NTNC

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution
		Radionuclides	9 years	2030 - Well 1	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		September 2024 at ROOM 306 ROOM 217 r TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 10

PWS ID: 1374079 PWS Name: FORT BRADEN SCHOOL

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1374104 PWS Name: GRAND VILLAGE MHP - EAST

System Type: Community

2024 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2024	
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution
		Volatile Organics (VOCs)	Triennially	2024	distribution
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62- <u>555.900(10)</u> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2024 at 121 EMILY LOOP TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

•

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
 - Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E</u>. <u>coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>.