



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1390087

System Type: Community

PWS Name: BRISTOL CITY OF WATER SYSTEM

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring

Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	Gross Alpha	2033 - Neal, Tower, Well 8	
				2027 - Copley	
		Rad226 & 228		2030 - Neal 2033 - Tower	
				2027 - Copley, Well 8	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2026 at TOWN FIELD HOUSE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1390651

System Type: Community

PWS Name: SWEETWATER WATER SYSTEM

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	September 2027 at 8795 NW MLK RD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1390901

System Type: Community

PWS Name: HOSFORD TOWN OF WATER SYSTEM

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	3 rd week of January, April, July, & October 2026 at 15893 NE SHADOW LN 18105 NE BUD DUNCAN RD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394001

System Type: Community

PWS Name: LIBERTY CORRECTIONAL INSTITUTION

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	Gross Alpha	2027 – Well 2, 4 2033- Well 3	
			Rad 226 & 228	2027 - Wells 2, 4 2030 - Well 3	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2026 at WWTP & WARDEN'S HOUSE for TTHMs and HAA5s**

		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 10
--	--	-------------------------------	-------------	--------------	------------------------------------------------------------------------

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394003

System Type: Community

PWS Name: SUMATRA WATER SYSTEM

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	3 rd Week of July 2027 at 10740 SW COUNTY ROAD 22 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394005

System Type: NTNC

PWS Name: APALACHEE POLE COMPANY

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2028	
		Volatile Organics (VOCs)	Triennially	2028	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2028	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2028 at FRONT OFFICE BATHROOM for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394006

System Type: Community

PWS Name: ESTIFFANULGA WATER SYSTEM

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	3 rd Week of July 2026 at 24877 CR 333 & 7805 MW Chattahoochee Cir for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2028	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394007

System Type: NTNC

PWS Name: REX LUMBER BRISTOL LLC

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2028	
		Volatile Organics (VOCs)	Triennially	2028	
		Radionuclides	6 years	2031	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2028	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2028 at FRONT OFFICE BATHROOM for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394009

System Type: Community

PWS Name: LAKE MYSTIC WATER SYSTEM

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	3 rd Week of July 2027 at 14785 N.W. MILLRIDGE DR (JEFF HILL) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2026	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394010

System Type: NTNC

PWS Name: LIBERTY WILDERNESS CROSSROADS CAMP INC.

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2028	
		Volatile Organics (VOCs)	Triennially	2028	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2028	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2028 at KITCHEN for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394012

System Type: Community

PWS Name: ROCK BLUFF WATER SYSTEM

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2027	
		Secondary Contaminants	Triennially	2027	
		Volatile Organics (VOCs)	Triennially	2027	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2027	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	April 2027 at 6209 NW TORREYA PARK RD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1394013

System Type: NTNC

PWS Name: GEORGIA PACIFIC - HOSFORD FACILITY

2026 Drinking Water Chemical Monitoring Requirements

The table below summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2026	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2028	
		Volatile Organics (VOCs)	Triennially	2028	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2028	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2028 at GUARD HOUSE for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sep 2027	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**