



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460035

System Type: Community

PWS Name: AUBURN WATER SYSTEM

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		VOC-1,2-dichloroethane	Annually	2 nd Qtr 2023 at Well 4	
		Radionuclides	9 years	2029	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at BILL LUNDY RD - MR-2 CONE DR - MR-5 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460043

System Type: Community

PWS Name: BAKER WATER SYSTEM INC.

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at 6609 LENWOOD JACKSON ROAD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460144

System Type: Community

PWS Name: FORT WALTON BEACH CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at 40 READY AVE 180 FERRY ROAD NE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460147

System Type: Community

PWS Name: NICEVILLE CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Need Well 11 all chems once back in service Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha	2026	
			Rad 226 & 228	2023 - Wells 2,3,4,5,8 2026 - Wells - 1,6,10,11	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at 935 JOHN SIMS PKWY 1102 LAKEWAY DR for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460149

System Type: Community

PWS Name: VALPARAISO CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha	2026	
			Rad 226 & 228	2023	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at 385 IOWA STREET for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460182

System Type: Community

PWS Name: CRESTVIEW CITY OF WATER DEPT.

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha including uranium	2023-Well 9	
				2026-Wells 4,5,6,7,8	
				2029-Wells 3, 10	
		Rad 226 & 228		2023-Wells 8, 9	
				2026-Wells 4, 5, 6, 7	
			2029- Wells 3, 10		
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at 3140 APLIN RD - MR4 4263 ANTIOCH RD - MR6 for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30
--	--	-------------------------------	-------------	---------------	--

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460202

System Type: Community

PWS Name: DESTIN WATER USERS INC.

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring

Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	6 & 9 years	2026	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		August 2023 at 333 CALHOUN 710 WINTON CT for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460352

System Type: Community

PWS Name: HOLT WATER WORKS INC.

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at 845 WIGGINS ROAD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460416

System Type: Community

PWS Name: LAUREL HILL CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2028	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at 8212 Steelemill Creek Rd. for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460455

System Type: Community

PWS Name: MARY ESTHER CITY OF

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at 491 W. MIRACLE STRIP PKWY for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460472

System Type: Community

PWS Name: MILLIGAN WATER SYSTEM INC.

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at 5238 OLD RIVER ROAD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460506

System Type: Community

PWS Name: OKALOOSA CO.WTR.& SWR.SYSTEM

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha	2023-Wells OC1, OC3	
				2026- All other wells	
				2029-Well CW4	
		Rad 226 & 228		2023-Well OC1	
				2026-All other wells	
				2029-Well CW4	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		SOC-di(2-ethylhexyl)phthalate (DEHP)	Annually	3rd Qtr 2023 at Well OC1	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at 330 BLUEFISH DR CHOCTAW LANE for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30
--	--	-------------------------------	-------------	---------------	--

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460704

System Type: NTNC

PWS Name: EGLIN USCG STATION (DESTIN)

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2025 at BOATHOUSE for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460775

System Type: Community

PWS Name: OKALOOSA COUNTY BLUEWATER BAY-RAINTREE

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at NANCY WARD LANE 4333 SUNSET BEACH for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460782

System Type: Community

PWS Name: HURLBURT FIELD AFB WATER SYSTEM

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at HOT CARGO AREA BLDG 90838 ANTENNA FARM CSL 1-4 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Annually	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460826
PWS Name: EGLIN MAIN

System Type: Community

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	9 years	2026-All other wells	
				2027-Well 5	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
			Dioxin	2023-Wells 2,3,6,61,65	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at BUILDING 425 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460828

System Type: Community

PWS Name: EGLIN WEST/HOUSING

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		VOC-1,2,4-trichlorobenzene	Annually	2nd Qtr 2023 at Well 8	
		Radionuclides	Gross Alpha	2026-All other wells	
				2029-Well 7	
				Rad 226 & 228	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at BUILDING 1377 for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20
--	--	----------------------------------	-------------	---------------	--

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460829

System Type: NTNC

PWS Name: EGLIN AFB DUKE FIELD 3

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Radionuclides	Rad 226/228	2030 - Wells 26, 27	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		SOC-Dalapon	Quarterly	1st - 3 rd quarter - Well 27	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2025 at BUILDING 3130 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1460830

System Type: Community

PWS Name: EGLIN AUX. 6 RANGER CAMP

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2024 at BUILDING 6034 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1464034

System Type: Community

PWS Name: OKALOOSA CORRECTIONAL INST.

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2031	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Diquat	Annually	1 st Quarter 2023 Well 1	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at DJJ 4455 - STRAIGHT LINE RD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2025	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not

approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1464044

System Type: Community

PWS Name: OKALOOSA COUNTY MID SYSTEM (CRESTVIEW)

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha	2023-Well MC7	
				2026-All other wells	
			Rad 226 & 228	2023-Well MC7	
				2026-All other wells	
				2029-Well MC6	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at SUGARTOWN ROAD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests*** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1464061

System Type: NTNC

PWS Name: EGLIN SITE C-3 (LASER)

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2025 at BUILDING 2066 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1464063

System Type: NTNC

PWS Name: EGLIN SITE C64-C TEST FACILITY

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2025 at BUILDING 9621 for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2024	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1464065

System Type: NTNC

PWS Name: EGLIN SITE A-30

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2025	
		Volatile Organics (VOCs)	Triennially	2025	
		Asbestos	Every 9 years	2031	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2025	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2025 at BUILDING 9551 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1464067

System Type: Community

PWS Name: EGLIN 7TH SPECIAL FORCES GROUP

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2023 at BUILDING 4335 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1464068

System Type: Community

PWS Name: OKALOOSA WATERWORKS

2023 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2023	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2030	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart. Systems may apply for a waiver using Form 62-560.545(2))
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2023 at 7991 RED BARROW ROAD (HYDRANT 88) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.





Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.

	Drinking Water Program	DEP Northwest District Potable Water Office 160 W. Government Street, Suite 308 Pensacola, FL 32502
DEP NW District Contacts	General #:(850) 595-8300 Fax #:(850) 595-8392	Important Reminders
~Environmental Manager	Michael Mucci (850) 595-0569 Michael.Mucci@floridadep.gov	
~Stage 2 Disinfection Byproducts (DBP) Compliance ~Disinfectant Residuals Reports ~Precautionary Boil Water Notices	Alyssa Tessier (850) 595-0685 Alyssa.Tesier@floridadep.gov Email DBP results to: NWDPWS@floridadep.gov	Email DBP results to: NWDPWS@floridadep.gov Community and NTNC Systems should be monitoring according to their most current Stage 2 DBP monitoring plan. Contact Alyssa if you have any questions concerning your monitoring plan.
~Chemical Compliance (Nitrates/Nitrites, Inorganics, SOC, VOC, Asbestos, Secondaries, Rads)	Paula Smith (850) 595-0632 Paula.Smith@floridadep.gov	Call if you have any questions on requirements Email Chem results to Paula at her individual account (Paula.Smith@floridadep.gov)
~Consumer Confidence Reports (CCR)	Jack Darby (850) 595-0689 Jack.Darby@floridaDEP.gov	For community water systems, CCRs must be delivered to customers by July 1st every year.
~Potable Water Compliance & Enforcement, Cross Connection Control	Angelia Butler (850) 595-0598 Angelia.Butler@floridadep.gov	If you ever need help with something regarding DEP potable water regulations, please consider using our Public Outreach Request Form at: http://www.surveymoz.com/s3/878438/Request-DEP-Northwest-District-Compliance-Assistance
~Lead and Copper Rule (LCR) Tap Monitoring ~Precautionary Boil Water Notices	Roger Thomas (850) 595-0660 Roger.N.Thomas@floridadep.gov	Lead & Copper tap sampling sites should be verified ahead of sampling to ensure homes are not vacant and that homeowners are still willing to participate. Email LCR results to NWDPWS@floridadep.gov
~Monthly Operation Reports (MORs) ~Boil Water Notices (BWNs)	Any Drinking Water NWD Staff Email MORs to: DWRM_Data_Entry_Tal@dep.state.fl.us ALSO cc: NWDPWS@floridadep.gov Email BWN info and clearance bacti-s to: NWDPWS@floridadep.gov	Email MORs to: DWRM_Data_Entry_Tal@dep.state.fl.us (cc: NWDPWS@floridadep.gov) Email BWNs (issuances, rescissions, and clearance results) to: NWDPWS@floridadep.gov Notify this office of Boil Water Notices or other abnormal operating conditions as soon as possible, but never later than noon of the next business day. Planned events that may adversely affect finished-water quality, interrupt water service to 150 or more service connections or 350 or more people, interrupt water service to any one service connection for more than eight hours, or necessitate the issuance of a precautionary "boil water" notice in accordance with the Department of Health's "Guidelines for the Issuance of Precautionary Boil Water Notices" must be reported to this office no later than the <u>previous</u> business day.
~Bacteriological Compliance (Routine Bact. Sampling, Well & Tank Clearances, Revised Total Coliform & Ground Water Rules)	Kelly Dunn (850) 595-0562 Kelly.Dunn@floridadep.gov Email Bact. compliance results (routine and repeat) to: NWDPWS@floridadep.gov	Email Bact. compliance results (routine and repeat) to: NWDPWS@floridadep.gov Please sample EARLY to prevent last-minute mix-ups and allow resampling within the monitoring period if necessary! Lab results are due within the first 10 days following the end of the required monitoring period. Reporting forms that are incomplete, incorrect, or illegible may be considered invalid.
~General Permits ~Permit Clearances	Katie Ates (850) 595-0656 Katie.L.Ates@floridadep.gov	The Department is committed to the expeditious review of applications and issuance of permits. 1) Water systems must verify that written clearance has been granted by this office before providing water to (placing into permanent operation) any permitted PWS construction project; 2) Please notify this office in writing before modifying any permitted work so it can be determined whether a supplemental permit application will be required.
Panama City Office	TBD (850) 767-0044 Larry Couch (850) 767-0047 Larry.Couch@floridadep.gov	
Tallahassee Branch Office	Tracy White (850) 245-7628 Tracy.A.White@floridadep.gov Colby Saults (850) 245-7627 Colby.Saults@floridadep.gov	
Branch Office Environ. Administrator	Mark C. Sumner 850-767-0046 Mark.C.Sumner@dep.state.fl.us	
Important Numbers and Websites		
State Watch Office	1-(800)-320-0519	
FDEP Operator Certification	(850) 245-7500	
FDEP State Revolving Fund	(850) 245-2835	
FDEP Website	https://floridadep.gov/	
FDEP Northwest District Website	https://floridadep.gov/northwest/	
Water Tracker Website: Please email watertracker@floridadep.gov if you do not have a user name and/or password	https://flwatertracker.com	
OCULUS - FDEP electronic document management system	https://depdms.dep.state.fl.us/Oculus/	
Florida Rural Water Association, (FRWA)	https://www.frwa.net	
Floridan Newsletter	https://floridadep.gov/subscribe	
Tapline Newsletter	http://www.floridadep.gov/northwest/nw-outreach/content/northwest-district-newsletters	