



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Aero-Tech

2900 Gary Drive
Plymouth IN 46563

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
70-147-AT2-C3	C3	0.25	66.00	64	64		835	ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-500 gallon per day ATU. Requires 500 gallon minimum pretreatment tank. W/o clarifier can be pretreatment tank to AT-750 ATU										
70-147-AT3-C3	C3	0.25	66.00	64	64		835	ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-600 gallon per day ATU. Requires 600 gallon minimum pretreatment tank. W/o clarifier can be pretreatment tank to AT-750 ATU										
70-147-AT4-C3	C3	0.25	66.00	72	72		1050	ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-750 gallons per day ATU. Requires 750 gallon minimum pretreatment tank. W/o clarifier can be pretreatment tank to AT-1000 ATU										
70-147-AT5-C3	C3	0.25	66.00	84	84		1450	ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-1000 gallons per day ATU. Requires 1000 gallon minimum pretreatment tank.										
70-147-AT6-C3	C3	0.25	72.00	96	96		2100	ATU	12/20/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-1500 gallons per day ATU. Requires 1500 gallon minimum pretreatment tank.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Alpha General Services, Inc.

Post Office Box 3331

Sebring, FL 33871

Highlands

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)			
28-004-09S-C4	C4	0.38	59.00	69.8	102.8	2.5	1050		B,GI	3/22/2002	
REMARKS: Fiberglass tank. No mid-seam test after install needed with Alpha sticker. Approved as posttreatment tank when preceded by the 28-004- 36S-C3 treatment tank housing SludgeHammer S-800 or S-1000 ATUs. Remarks updated 1/29/2025.											
28-004-18S-C3	C3	0.25	50.00	69.5	124.5		1300	1,552	ATU	3/22/2002	
REMARKS: For use with Bio-Microbics MicroFAST ATUs. NSF 40 configurations: houses MicroFAST 0.5, when used with a 333 gal min. settling tank; MicroFAST 0.625 or 0.75 when used with a 356 gal min. settling tank; MicroFAST 0.9 when used with a 475 gal min. settling tank. NSF 245 configurations: houses MicroFAST 0.5, 0.625 or 0.75 when used with 475 to 750 gallon settling tank; MicroFAST 0.9 when used with a 689 to 1088 gallon settling tank. All in lid installation; no mid-seam test after install needed with Alpha sticker.											
28-004-20D-C3	C3	0.30	55.57	69.5	135.5	2.5	1500		B,GI	3/22/2002	
REMARKS: Fiberglass tank. Was-21; no mid-seam test after install needed with Alpha sticker. Can house SludgeHammer S-400 ATU. Remarks updated 1/29/2025.											
28-004-20S-C3	C3	0.30	55.75	69.5	135.5	2.5	1500		B	3/22/2002	
REMARKS: Fiberglass tank. No mid-seam test after install needed with Alpha sticker. Can house the SludgeHammer S-600 ATU as a treatment tank when used with 28-004-01S-C4 post-treatment tank. Remarks updated 1/29/2025.											
28-004-36S-C3	C3	0.30	55.75	69.6	195.6		2200		B	3/22/2002	
REMARKS: Fiberglass tank. No mid-seam test after install needed with Alpha sticker. For use with SludgeHammer S-800 and S-1000 ATUs. Can house S-800 or S-1000 as a treatment tank, when used with 28-004-09S-C4 post-treatment tank. Remarks updated 1/29/2025.											
28-004-AK6S-C3	C3	0.19	50.50	46.5	131.5	2	1133	1,333	ATU	4/17/2024	
REMARKS: Fiberglass tank. Slide in baffles. Houses AquaKlear AK6S245F ATU (600 gal/day), NSF245-certified. Two 1/2" airlines coming through riser. Approved for use with lid 236.											
28-004-BM1-C3	C3	0.25	49.00	69.5	124.5		1300	1,552	ATU	2/6/2008	
REMARKS: Slide-in baffle located for use with Bio-Microbics MicroFAST ATUs. NSF 40 configurations: houses the MicroFAST 0.5, 0.625, 0.75, 0.9; NSF 245 configurations: houses the MicroFAST 0.5. All in lid installation; no mid-seam test after install needed with Alpha sticker.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

AquaKlear, Inc.

870 Bierdeman Road
 Pearl MS 39208

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
70-114-05-C3	C3	0.25	50.50					ATU	12/30/2004	
REMARKS: fiberglass tank-houses the 500 gallon per day AquaKlear ATU (NSF 40-certified model); houses the AquaKlear AK6S245FC (NSF 245-certified model) with Pence pretreatment tank 05-027-025-C4.										
70-114-06-C3	C3	0.31	55.00	46	90			ATU	5/24/2002	
REMARKS: Fiberglass tank-houses the 600 gallon per day AquaKlear ATU (NSF 40-certified model). Approved 05/24/2002. Approved as a pretreatment tank for the AK12S245F ATU (NSF245 certified) when the ATU is housed in 70-114-10-C3. Updated 11/19/2024.										
70-114-073-C3	C3	0.51	56.50	62	66	2	735	834 ATU	8/5/2019	
REMARKS: Fiberglass tank. Can be used as pretreatment tank for the AquaKlear AK10S245F ATU (NSF 245-certified model) when that is housed in AquaKlear tank 70-114-10-C3, skimmer return enters through riser.										
70-114-08-C3	C3	0.38	56.50					ATU	12/30/2004	
REMARKS: fiberglass tank-houses the 800 gallon per day AquaKlear ATU (NSF 40-certified model).										
70-114-10-C3	C3	0.44	56.50	56	113			ATU	12/30/2004	
REMARKS: Fiberglass tank. Houses 1000 gallon per day AquaKlear AK1000F ATU (NSF40-certified) (approval 12/30/2004); with pretreatment tank 70-114-073-C3 and skimmer return through risers. Houses 1000 gallon per day AquaKlear AK10S245F ATU (NSF245-certified) (approval 8/5/2019). Houses the 1200 gallon per day AK12S245C ATU (NSF245-certified) when preceded by the 70-114-06-C3 pretreatment tank. Updated 11/19/2024.										
70-114-15-C3	C3	0.44	68.00	65	136			ATU	12/5/2006	
REMARKS: fiberglass tank-houses the 1500 gallon per day AquaKlear ATU (NSF 40-certified model).										
70-114-75-C3	C3	0.38	56.50					ATU	12/30/2004	
REMARKS: fiberglass tank-houses the 750 gallon per day AquaKlear ATU (NSF 40-certified model).										
70-114-AK6S-C3	C3	0.25	50.50	50	137.5	2	1133	1,333 ATU	8/5/2019	
REMARKS: Fiberglass tank. Monolithic baffles. Houses AquaKlear AK6S245F ATU (600 gal/day), NSF245-certified. 1/2" airlines coming through riser										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Baker Septic Installations, Inc.

7740 South George Blvd.
Sebring, FL 33875

Highlands

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
28-031-DF50-C4	C4	3.00	51.50	78	78		900	ATU		6/21/2010	
REMARKS: Circular tank-Houses Delta 500 gpd DF50-CA ATU. max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.											
28-031-J1-C3	C3	3.00	50.00	59	120		1160	1,494 ATU		10/30/2006	
REMARKS: Mid-seam tank. Houses Jet Models J-500 through J-1500 ATUs and J-500CF through J-1500CF ATUs. J-1000, J-1000CF, J-1250, J-1250CF, J-1500, J-1500CF must be preceded by a pretreatment tank 1000 gallons or greater. The CF-series is NSF 245 certified.											
28-031-NW1-C4	C4	3.00	41.00	72	146		1300	1,805 ATU		7/9/2025	
REMARKS: Houses the Norweco Singulair Model 960-500 and TNT-500 ATU. Both are NSF-40 certified for 500 gpd and 600 gpd. TNT-500 is NSF 245-certified for 500 gpd and 600 gpd. Also houses the first three compartments of the Norweco Singulair R3-500 ATU (NSF 245/350 certified) when followed by the Norweco Green HKBFR tank (70-150-NW2-C3). Side outlets permitted.											
28-031-NW2-C4	C4	3.00	41.00	72	146		1300	1,805 ATU		7/9/2025	
REMARKS: Houses the Norweco Singulair Model 960-1000 and TNT-1000 ATU. The TNT-1000 is NSF245-certified. Pretreatment tank minimum requirements: 1000-gal capacity, 15 gal per inch of liquid level and 12 inches of freeboard. The pretreatment tank must be installed so that the outlet invert of the pretreatment tank is aligned vertically and horizontally to the inlet invert of the treatment tank. The pretreatment tank outlet invert and the treatment tank inlet invert are both 5 inches below the water level. Also houses the first three compartments of the Norweco Singulair R3-1000 ATU (NSF 245/350 certified) when followed by two Norweco Green HKBFR tanks (70-150-NW2-C3) in parallel. Side outlets permitted.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Bingham Onsite Precasting Inc.

6172 Highway 640 West
Mulberry FL 33830

Polk

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)			
53-137-71S-C3	C3	3.50	73.00				4000	4,755	B, ATU	3/22/2002	
REMARKS: For use with Bio-Microbics engineered ATUs: MicroFAST 4.5 low-profile leg installation with pretreatment tank and three-hole lid of GT3 tank.											
53-137-A1-C3	C3	3.00					500		ATU	3/22/2002	
REMARKS: Used to house the Alliance ATU											
53-137-C/A-C3	C3	3.00	52.50				750		ATU	3/22/2002	
REMARKS: Used to house the Cajun-Aire 500 & 750 ATU											
53-137-MM1-C4	C4	0.38	66.00						ATU	3/22/2002	
REMARKS: Used to house the Mighty Mac 500 ATU											
53-137-MM2-C3	C3	0.38	66.00						ATU	10/6/2002	
REMARKS: Used to house the Mighty Mac 750 ATU											
53-137-MM3-C3	C3	0.38	66.00						ATU	10/6/2002	
REMARKS: Used to house the Mighty Mac 600 ATU											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Bonded Septic Tank

P.O. Box 1509-State Rd 486
Hernando, FL 34442

Citrus

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL USE DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
09-030-11D-C3	C3	3.00	43.25	64	120.5	1	1114	1,337	6/3/2008	
REMARKS: For use with BioMicrobics MicroFAST ATUs. NSF 40 configurations: 0.4, 0.5, 0.625 and 0.75 ATU. NSF 245 configuration: MicroFAST 0.4. 9/19/2018 - approved to use three inlets, one on the inlet side, and one each on the left and right side of the tank, within 12 inches of the inlet wall. The inverts of all inlets are one inch above the invert of the outlet. Revised 06/18/2025.										
09-030-11S-C3	C3	3.00	43.25	64	120.5	1	1138	1,337	6/3/2008	
REMARKS: For use with Bio-Microbics MicroFAST ATUs. Houses the NSF 40-certified configurations as follows: MicroFAST 0.5, when used with a 333 gal min. settling tank; MicroFAST 0.625 or 0.75 when used with a 356 gal min. settling tank; MicroFAST 0.9 when used with a 475 gal min. settling tank; and MicroFAST 1.5 when used with a 713 gal min. settling tank. The tank houses NSF 245-certified configurations as follows: MicroFAST 0.5, 0.625 or 0.75 when used with a 475 to 750 gallon settling tank. Approved with three inlets.										
09-030-BM1D-C3	C3	3.50	54.50	65	123	1	1350	1,550	4/22/2021	
REMARKS: Slide-in baffle wall. For use with Bio-Microbics MicroFAST ATUs (suspended from the lid configurations). NSF 40-certified configurations as follows: MicroFAST 0.5, 0.625, 0.75 and 0.9. NSF 245-certified configurations as follows: MicroFAST 0.5. Approved with three inlets. DOH approved lids # 226, 227 and 228.										
09-030-BM1S-C3	C3	3.50	54.50	65	123	1	1350	1,550	4/22/2021	
REMARKS: For use with Bio-Microbics MicroFAST ATUs (suspended from the lid configurations). NSF 40-certified configurations as follows: MicroFAST 0.5, when preceded by a 333 gal min settling tank; MicroFAST 0.625 or 0.75 when preceded by a 356 gal min. settling tank; MicroFAST 0.9 when preceded by a 475 min. settling tank; and MicroFAST 1.5 when preceded by a 713 gal min. settling tank. The tank houses NSF 245-certified configurations as follows: MicroFAST 0.5, 0.625 or 0.75 when preceded by a 475 to 750 gallon settling tank; MicroFAST 0.9 when preceded by a 689 to 1088 gallon settling tank. Approved with three inlets. DOH approved lids # 226, 227, 228 and 229.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Bord na Mona

P.O. Box 77457

Greensboro NC 27417

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL USE DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
70-130-01S-TM	TM	0.25								3/30/2005

REMARKS: Polyethylene tank used to house 12" above ground 7'L x 4.5'W x 2.5'D Puroflo Peat Biofilter ATU



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Caribe Jet, Inc.

4753 E. Highway 92
Lakeland FL 33801

Polk

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL		
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE	DATE	FAMILY
53-131-J1-C3	C3	3.00	50.00				1160	1,494	ATU	8/22/2005	

REMARKS: Houses Jet Models J-500 through J-1500 ATUs and J-500CF through J-1500CF ATUs. J-1000, J-1000CF, J-1250, J-1250CF, J-1500, J-1500CF must be preceded by a pretreatment tank 1000 gallons or greater. The CF-series models are NSF 245 certified.



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Cast Systems LLC.

19400 Peachland Blvd.
Port Charlotte FL 33954

Charlotte

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL	
				WIDTH	LENGTH			(Pump Tanks)	USE	DATE	FAMILY
08-123-DF50-C3	C3	3.00	52.25				919	1,057	ATU	7/2/2003	

REMARKS: used to house the Delta Whitewater DF50-CA or UC50-CA ATU. max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Clearstream Wastewater Systems, Inc.

P.O. Box 7568
Beaumont TX 77726-7568

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)			
70-120-05N-C3	C3	0.25	63.00					ATU	11/5/2002		
REMARKS: Fiberglass tank - houses Clearstream 500 gallon per day ATU 500N/D/DA. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-06N-C3	C3	0.31	55.00					ATU	11/5/2002		
REMARKS: Fiberglass tank - houses Clearstream 600 gallon per day ATU 600N/D/DA. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-07N-C3	C3	0.31	65.00					ATU	11/5/2002		
REMARKS: Fiberglass tank-houses Clearstream 750 gallon per day ATU 750D/750N. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-08CST-C3	C3	0.25	65.00				1315	ATU,B	2/23/2009		
REMARKS: Fiberglass Midseam; used to house 800 gpd ATU Clearstream 800N/D/DA. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-08ST-C3	C3	0.25	63.00				864	ATU,B	2/23/2009		
REMARKS: Fiberglass Midseam; used to house 500 gpd ATU Clearstream 500NT/DT/DAT. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-10N-C3	C3	0.38	87.00					ATU	11/5/2002		
REMARKS: Fiberglass tank-houses Clearstream 1000 gallon per day ATU 1000D/1000N. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-10ST-C3	C3	0.25	55.00				1094	ATU,B	2/23/2009		
REMARKS: Fiberglass Midseam; used to house 600 gpd ATU Clearstream 600NT/DT/DAT. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-15N-C3	C3	0.44	82.00					ATU	11/5/2002		
REMARKS: Fiberglass tank-houses Clearstream 1500 gallon per day ATU 1500N/1500D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-25A-C3	C3	0.25	55.00	79	79	0	850	1,000 ATU	10/19/2015	1	
REMARKS: Fiberglass Midseam; used to house 500 gpd ATU Clearstream 500N/DST/DAST. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-25A-C4	C4	0.25	55.00	79	79	0	850	1,000 ATU	10/19/2015	2	
REMARKS: Fiberglass Midseam; used to house 500 gpd ATU Clearstream 500N/DST/DAST. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-25AB-C3	C3	0.25	55.00	79	79	0	850	1,000 ATU	10/19/2015	1	
REMARKS: Fiberglass Midseam 500NST-B/DST; used to house 500 gpd ATU Clearstream 500GST/500N/500D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-25AB-C4	C4	0.25	55.00	79	79	0	850	1,000 ATU	10/19/2015	2	
REMARKS: Fiberglass Midseam 500NST-B/DST; used to house 500 gpd ATU Clearstream 500GST/500N/500D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-26A-C3	C3	0.25	55.00	88	88	0	1050	1,250 ATU	10/19/2015	3	
REMARKS: Fiberglass Midseam; used to house 600 gpd ATU Clearstream 600NT, 600DT and 600DAT. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											
70-120-26A-C4	C4	0.38	55.00	88	88	0	1050	1,250 ATU	10/19/2015	4	
REMARKS: Fiberglass Midseam; used to house 600 gpd ATU Clearstream 600NT, 600DT and 600DAT. The D and DA models are NSF 245 certified and require a pretreatment tank with a minimum volume of 50% the gpd rating. The D model requires an extra pump tank and recirculation.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Clearstream Wastewater Systems, Inc.

P.O. Box 7568
Beaumont TX 77726-7568

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL	
				WIDTH	LENGTH			(Pump Tanks)	USE	DATE	FAMILY
70-120-26AB-C4	C4	0.38	55.00	88	88	0	1050	1,250	ATU	10/19/2015	4
REMARKS: Fiberglass Midseam 600NT-B/DT; used to house 600 gpd ATU Clearstream 600N/600D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-26AB-C3	C3	0.25	55.00	88	88	0	1050	1,250	ATU	10/19/2015	3
REMARKS: Fiberglass Midseam 600NT-B/DT; used to house 600 gpd ATU Clearstream 600N/600D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-27A-C3	C3	0.25	65.00	88	88	0	1250	1,450	ATU	10/19/2015	5
REMARKS: Fiberglass Midseam 750NT/DT; used to house 750 gpd ATU Clearstream 750N/750D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-27A-C4	C4	0.44	65.00	88	88	0	1250	1,450	ATU	10/19/2015	6
REMARKS: Fiberglass Midseam 750NT/DT; used to house 750 gpd ATU Clearstream 750N/750D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-27AB-C3	C3	0.25	65.00	88	88	0	1250	1,450	ATU	10/19/2015	5
REMARKS: Fiberglass Midseam 750NT-B/DT; used to house 750 gpd ATU Clearstream 750N/750D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											
70-120-27AB-C4	C4	0.44	65.00	88	88	0	1250	1,450	ATU	10/19/2015	6
REMARKS: Fiberglass Midseam 750NT-B/DT; used to house 750 gpd ATU Clearstream 750N/750D. D-model (NSF 245-certified model) requires additional pump tank and recirculation.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Consolidated Treatment Systems, Inc.

1501 Commerce Center Drive
Franklin OH 45005

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
70-113-EG1-C3	C3		64.00						2/25/2005	
REMARKS: fiberglass-houses Enviro-Guard 750 gpd ATU										
70-113-MF1-C3	C3		54.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 0.5 (500 gpd) ATU										
70-113-MF2-C3	C3		54.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 0.6 (600 gpd) ATU										
70-113-MF3-C3	C3		58.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 0.75 (750 gpd) ATU										
70-113-MF4-C3	C3		64.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 1.0 (1000 gpd) ATU										
70-113-MF5-C3	C3		54.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 1.5 (1500 gpd) ATU										
70-113-N1-C3	C3		62.50						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M6-A (500 gpd) ATU										
70-113-N1A-C3	C3	0.19	62.50	72	72		500	ATU	1/26/2012	
REMARKS: fiberglass-houses NAYADIC M6-A (500 gpd) ATU										
70-113-N2-C3	C3		68.00						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M8-A (600 gpd) ATU										
70-113-N3-C3	C3		75.50						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M1050-A (800 gpd) ATU										
70-113-N4-C3	C3		86.00						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M1200-A (1000 gpd) ATU										
70-113-N5-C3	C3		96.50						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M2000-A (1500 gpd) ATU										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Del Zotto Mfg. Co.

4575 W. Highway 40
Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
42-007-08D-C4	C4	4.00	42.00				1050		11/13/2002	
REMARKS: Houses Bionest BNC-400 ATU.										
42-007-08D-C3	C3	2.50	42.00	60	118	2	1050	1,248	11/13/2002	
REMARKS: Houses Bionest BNC-400 ATU.										
42-007-20D-C4	C4	4.00	49.00				1500		11/13/2002	
REMARKS: Can house SludgeHammer S-400 ATU. Remarks updated 1/29/2025.										
42-007-30D-C3	C3	4.00	42.00				1900		2/4/2002	
REMARKS: Houses Bionest BNC-750 ATU.										
42-007-32D-C3	C3	4.00	45.00	83	158		2000	2,481	10/22/2008	
REMARKS: Can house SludgeHammer S-600 ATU. Remarks updated 1/29/2025.										
42-007-45D-C3	C3	4.00	56.00	83	158		2500	2,984	10/22/2008	
REMARKS: Can house SludgeHammer S-800 ATU. Remarks updated 1/29/2025.										
42-007-49D-C3	C3	4.00	60.00				2700		2/4/2002	
REMARKS: Houses Bionest BNC-1000 ATU.										
42-007-AK6S-C4	C4	3.00	50.50	50	139.5	2	1069	1,265	ATU 4/20/2020	
REMARKS: Monolithic baffles. Houses AquaKlear AK6S245C ATU (600 gal/day), NSF 245-certified. 1/2" airlines coming through riser.										
42-007-CS1-C3	C3	3.00	57.00	0	0				ATU 6/6/2007	
REMARKS: Concrete; used to house 600 gpd ATU Clearstream 600NC3T, 600DC3 and 600DAC3. The D and DA models are NSF 245 certified.										
42-007-G30D-C4	C4	6.00	56.00	116.5	150.75	2.5	3000	3,750	2/2/2009	
REMARKS: Approved for HS20 traffic loading; April 2014, changed inlet for 2.5" drop. Can house SludgeHammer S-1000 ATU. Remarks updated 1/29/2025.										
42-007-J05-C4	C4	3.00	50.00	60	120.4	3	1148	1,474	ATU 6/14/2019	
REMARKS: Approved for use with Jet J-500CF ATU (500 GPD), DOH Lid #164 (4" thick, max soil cover 24"), DOH Lid #165 (8" thick, non-traffic, max soil cover 48"), DOH Lid #166 (12" thick, H15 Traffic, tank remains C4). J-500CF is NSF 245 certified.										
42-007-J07-C4	C4	3.00	50.00	60	120.4	3	1148	1,474	ATU 6/14/2019	
REMARKS: Approved for use with Jet J-750CF ATU (750 GPD), DOH Lid #164 (4" thick, max soil cover 24"), DOH Lid #165 (8" thick, non-traffic, max soil cover 48"), DOH Lid #166 (12" thick, H15 Traffic, tank remains C4). J-750CF is NSF 245 certified.										
42-007-J10-C4	C4	3.00	50.00	60	120.4	3	1148	1,474	ATU 6/14/2019	
REMARKS: Approved for use with Jet J-1000CF ATU (1000 GPD), DOH Lid #167 (4" thick, max soil cover 24"), DOH Lid #168 (8" thick, non-traffic, max soil cover 48"), DOH Lid #169 (12" thick, H15 Traffic, tank remains C4). J-1000CF is NSF 245 certified and must be preceded by a pretreatment tank 1000 gallons or greater.										
42-007-J15-C4	C4	3.00	50.00	60	120.4	3	1148	1,474	ATU 6/14/2019	
REMARKS: Approved for use with Jet J-1500CF ATU (1500 GPD), DOH Lid #167 (4" thick, max soil cover 24"), DOH Lid #168 (8" thick, non-traffic, max soil cover 48"), DOH Lid #169 (12" thick, H15 Traffic, tank remains C4). J-1500CF is NSF 245 certified and must be preceded by a pretreatment tank 1000 gallons or greater.										
42-007-JT1-C4	C4	3.00	52.38	61.63	123				ATU 1/15/2009	
REMARKS: Houses Jet Models J-500 through J-1500 ATUs and J-500CF through J-1500CF ATUs. J-1000, J-1000CF, J-1250, J-1250CF, J-1500, J-1500CF must be preceded by a pretreatment tank 1000 gallons or greater. The CF-series models are NSF 245 certified.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Delta Treatment Systems, LLC

P.O. Box 969

Denham Springs LA 70727

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL	
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE	DATE
70-115-DF1-C3	C3	0.31	51.56	72	72			ATU	6/11/2002	1
REMARKS: Fiberglass tank-Houses Delta DF50-FF or UC50-FF ATU @ 500 gpd; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-DF2-C3	C3	0.31	59.50	75	75			ATU	6/11/2002	2
REMARKS: Fiberglass tank-Houses Delta DF60-FF or UC60-FF ATU @ 600 gpd; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-DF3-C3	C3	0.38	64.00	81	81			ATU	6/11/2002	3
REMARKS: Fiberglass tank-Houses Delta DF75-FF or UC75-FF @ 750 gpd, or UC90-FF ATU @ 900 gpd. Max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-DF4-C3	C3	0.38	61.00	96	96			ATU	6/11/2002	
REMARKS: Fiberglass tank-Houses Delta DF100A-FF or UC100A-FF ATU @ 1000 gpd. Max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-DF5-C3	C3	0.38	91.50	96	96			ATU	6/11/2002	
REMARKS: Fiberglass tank-Houses Delta DF150-FF or UC150-FF ATU @ 1500 gpd. Max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-E0-C3	C3	0.31	48.00	66	66		710	ATU	5/30/2012	1
REMARKS: Fiberglass tank-Houses 500 gpd Delta E50-N (NSF 245-certified model) ATU; requires at least 500 gallon pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-E1A-C3	C3	0.31	48.00	72	72		840	ATU	5/30/2012	1
REMARKS: Fiberglass tank-Houses 500 gpd Delta E50-N (NSF 245-certified model) ATU (outlet changed compared to DF1); requires at least 500 gallon pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-E1B-C3	C3	0.31	52.00	72	72		916	ATU	5/30/2012	1
REMARKS: Fiberglass tank-Houses 600 gpd Delta E60-N (NSF 245-certified model) ATU (outlet changed compared to DF1); requires at least 600 gallon pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-E2-C3	C3	0.31	57.00	75	75		1100	ATU	5/30/2012	2
REMARKS: Fiberglass tank-Houses 750 gpd Delta E75-N (NSF 245-certified model) ATU (outlet changed compared to DF2); requires at least 750 gallon pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										
70-115-E3-C3	C3	0.38	63.00	81	81		1400	ATU	5/30/2012	3
REMARKS: Fiberglass tank-Houses 1000 gpd Delta E100-N (NSF 245-certified model) ATU (outlet changed compared to DF3); requires at least 1000 gallon pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Dura-Cast Products, Inc.

16160 US Highway 27

Lake Wales FL 33859

Polk

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL	
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE	DATE

53-161-95D-C3	C3	0.25	41.50	60	117.25	1	950	1,039	ATU	11/14/2024
---------------	----	------	-------	----	--------	---	-----	-------	-----	------------

REMARKS: Polyethylene; Snyder Industries "900 Gallon D2"/Norwesco "900 Gallon Low Profile" modified with a higher inlet and outlet and a different location of the slide-in baffle. Approved for use to house the Microfast 0.4 (400 gpd) NSF 245 certified ATU. White color.

53-161-BM5-C3	C3	0.25	40.00	60	157	2	1250	1,443	ATU	10/22/2025
---------------	----	------	-------	----	-----	---	------	-------	-----	------------

REMARKS: Polyethylene; Snyder Industries "1250 Gallon D2"; Norwesco "1250 Gallon Low Profile" modified with a different location of the slide-in baffle. Houses the BioMicrobics MicroFAST 0.5 Flex (500 GPD) ATU NSF 245 certified. White color.



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Ecological Tanks, Inc.

2247 Highway 151 N.
Downsville LA 71234

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
70-125-AS10-C3	C3	0.47	90.00					ATU	6/3/2003	
REMARKS: Houses the Aqua Safe 1000 ATU										
70-125-AS15-C3	C3	0.47	90.00					ATU	6/3/2003	
REMARKS: Houses the Aqua Safe 1500 ATU										
70-125-AS5-C3	C3	0.40	67.50					ATU	6/3/2003	
REMARKS: Houses the Aqua Safe 500 ATU										
70-125-AS5L-C3	C3	0.30	51.50	79	79	2.5	908	1,048 ATU	1/13/2016	1
REMARKS: Houses the Aqua Safe AS500L 500 gpd ATU										
70-125-AS6-C3	C3	0.40	67.50					ATU	6/3/2003	
REMARKS: Houses the Aqua Safe 600 ATU										
70-125-AS6L-C3	C3	0.30	60.50	79	79	2.5	1058	1,198 ATU	1/13/2016	1
REMARKS: Houses the Aqua Safe AS600L 600 gpd ATU										
70-125-AS7-C3	C3	0.45	67.50					ATU	6/3/2003	
REMARKS: Houses the Aqua Safe 750 ATU										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

E-Z Treat Inc.

P.O. Box 176

Haymarket VA 20168

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL	
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE	DATE

70-283-EZ6-TM	TM	0.20	0.00	47	87		0	494		8/5/2025	
---------------	----	------	------	----	----	--	---	-----	--	----------	--

REMARKS: Polyethylene. Used to house the unsaturated media filter for the 600 gpd ATU E-Z Treat Model D117 (Model 600 1Pod 3Tank Simplex) and 1200 gpd D101 (Model 600 2Pod 3Tank Simplex). These ATU models are NSF 40/245/350-certified. Tank preceded by septic tank and followed by recirculation and pump tank. Maximum burial depth, 2 inches below the upper flange.

70-283-EZ7-TM	TM	0.20	0.00	47	87		0	494		8/5/2025	
---------------	----	------	------	----	----	--	---	-----	--	----------	--

REMARKS: Polyethylene. Used to house the unsaturated media filter for the 750 gpd ATU E-Z Treat Model Pod D217 (Model 750 1Pod 3Tank Simplex) and 1500 gpd D201 (Model 750 1Pod 3Tank Simplex). These ATU models are NSF 40/245/350-certified. Tank preceded by septic tank and followed by recirculation and pump tank. Maximum burial depth, 2 inches below the upper flange.



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Florida Septic, Inc.

Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)		APPROVAL USE DATE	FAMILY
				WIDTH	LENGTH						
01-011-09D-C3	C3	2.50	50.00	62.5	101.5	1	1050	1,270	B	1/31/2001	
REMARKS: Houses Bionest BNC-400 ATU											
01-011-11D-C4	C4		44.00	72.5	104.5	2.5	1050	1,348	B, GI	3/17/2003	
REMARKS: Houses Bionest BNC-400 ATU. Wall thickness can be either 4" or 6". AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-11S-C4	C4		44.00	72.5	104.5	2.5	1050	1,348	B, GI	3/17/2003	
REMARKS: Wall thickness can be either 4" or 6". AASHTO HS20 traffic loading rated when buried between 18" to 48". Approved as pretreatment tank for the AK12S245C ATU (NSF245 certified) when the ATU is housed in the 01-011-AK10-C3. Approved 03/17/2003. Updated 11/19/2024.											
01-011-13D-C4	C4		52.00	73	105	2.5	1250	1,564	B, GI	3/17/2003	
REMARKS: Houses Bionest BNC-500 ATU. Wall thickness can be either 4" or 6". AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-20D-C3	C3	3.00	62.50	61	129.5	2.5	1500	1,700	B, GI	5/31/2001	
REMARKS: Houses Bionest BNC-600 ATU.											
01-011-23D-C4	C4	4.00	53.00	69	133	2.5	1500	1,800	B, GI	7/30/2001	
REMARKS: Houses Bionest BNC-600 ATU											
01-011-27D-C4	C4	6.00	53.00	73	137	2.5	1500	1,918	B, GI	10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house Bionest BNC-600 ATU. Can house SludgeHammer S-400 ATU. Remarks updated 1/29/2025.											
01-011-37D-C3	C3	3.00	53.00	74.25	150.5	2.5	2000	2,300	B	7/30/2001	
REMARKS: Houses Bionest BNC-750 ATU											
01-011-38D-C4	C4	4.00	53.00	76.25	152.75	2.5	2000	2,400	B	7/30/2001	
REMARKS: Houses Bionest BNC-750 ATU											
01-011-39D-C4	C4	6.00	53.00	80.25	156.75	2.5	2000	2,400	B	5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house Bionest BNC-750 ATU. Can house SludgeHammer S-600 ATU. Remarks updated 1/29/2025.											
01-011-43D-C4	C4	4.00	65.50	78	154.5	2.5	2500	2,900		7/30/2001	
REMARKS: Houses Bionest BNC-1000 ATU											
01-011-49D-C4	C4	6.00	65.50	82	158.5	2.5	2500	3,023		5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house SludgeHammer S-800 ATU. Remarks updated 1/29/2025.											
01-011-57D-C4	C4	6.00	45.50	103.5	191.63	2.5	3000	3,733	B	10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house SludgeHammer S-1000 ATU. Remarks updated 1/29/2025.											
01-011-64D-C4	C4	4.00	49.50	99.75	188	2.5	3300	4,023	B	8/14/2001	
REMARKS: Houses Bionest BNC-1250 ATU											
01-011-65D-C4	C4	6.00	49.50	103.8	192	2.5	3300	4,023	B	10/31/2001	
REMARKS: Houses Bionest BNC-1250 ATU. AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-68D-C3	C3	4.00	55.75	100.1	188.5	2.5	3700	4,461	B	8/14/2001	
REMARKS: Houses Bionest BNC-1500 ATU											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Florida Septic, Inc.

Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	B	APPROVAL USE DATE	FAMILY
				WIDTH	LENGTH						
01-011-69D-C4	C4	6.00	55.75	104.1	192.5	2.5	3700	4,461	B	5/29/2002	
REMARKS: Houses Bionest BNC-1500 ATU. AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-AK10-C3	C3	3.00	56.50	62	119	2	1342	1,583	ATU	8/12/2008	
REMARKS: Houses AquaKlear AK1000C 1000 gallon per day ATU (approval 8/12/2008); with pretreatment tank 01-011-02S-C4 and skimmer return through riser. Houses 1000 gallon per day AquaKlear AK10S245C ATU (NSF245-certified) (approval 8/5/2019). Two notches for 1/2" airline on inlet side. Houses the 1200 gallon per day AK12S245C ATU (NSF245-certified) when preceded by pretreatment tank 01-011-11S-C4. Updated 11/19/2024.											
01-011-AK5-C4	C4	3.00	49.50	50	89.5	1.5	640	773	ATU	12/14/2005	
REMARKS: Houses AquaKlear AK500C 500 gpd ATU; two notches for 1/2" airline on inlet side											
01-011-AK6S-C4	C4	3.00	50.50	50	139.5	2	1075	1,365	ATU	4/11/2019	
REMARKS: Monolithic baffles. Houses AquaKlear AK6S245C ATU (600 gal/day). NSF245 certified. Two notches for 1/2" airline and one notch for optional drip recirculation on inlet side. Approved for use with Lid #237 and traffic lid #240.											
01-011-AK7-C3	C3	3.00	50.50	77	103.92	2	1353	1,593	ATU	4/10/2025	
REMARKS: Houses the AquaKlear AK7.5S245CA ATU (750 GPD). The AK7.5S245CA ATU is NSF 245 certified. DEP Lid #245 (5.5" thick).											
01-011-AK8-C3	C3	3.00	57.75	57	103	2	1020	1,193	ATU	12/14/2005	
REMARKS: Used to house AquaKlear AK800C gallon per day ATU; two notches for 1/2" airline on inlet side.											
01-011-BM1-C3	C3	2.50	45.00	69.88	102	3	1100	1,479	ATU	10/31/2003	
REMARKS: Houses Bio-Microbics MicroFAST 0.5FS ATU (NSF 40-certified units only).											
01-011-BM10-C4	C4	6.00	63.00	82	158.5	2.5	2400	3,021		3/28/2012	
REMARKS: Converted 02-05-2012. Houses Bio-Microbics MicroFAST 1.5 ATU (NSF 40-certified units only).. AASHTO HS20 traffic loading rated when buried between 18" to 48".											
01-011-BM11-C4	C4	6.00	66.00	106	194.75	3	4500	5,909	ATU	3/28/2012	
REMARKS: Used to house Bio-Microbics MicroFAST 3.0F and 3.0FS ATU. AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-BM12-C4	C4	6.00	65.00	106	194.75	11	4400	5,913	ATU	3/28/2012	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Used to house Bio-Microbics MicroFAST 4.5F ATU											
01-011-BM2-C4	C4	4.00	53.00	69	133	2.5	1500	1,919	ATU	10/31/2003	
REMARKS: Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: 0.5FS, 0.625FS, 0.75FS, 0.9.FS. NSF 245-certified units: 0.5FS, 0.625FS, 0.75FS.											
01-011-BM4-C3	C3	3.00	43.00	74.25	150.5	3	1600	2,433	ATU	10/31/2003	
REMARKS: Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: 0.5F, 0.625F, 0.75F, 0.9.F. NSF 245-certified units: 0.5F, 0.625F, 0.75F.											
01-011-BM5-C3	C3	4.00	66.00	102	190.75	3	4500	5,909	ATU	10/31/2003	
REMARKS: Used to house Bio-Microbics MicroFAST 3.0F and 3.0FS ATU											
01-011-BM6-C3	C3	4.00	65.00	102	190.75	11	4400	5,913	ATU	2/17/2004	
REMARKS: Used to house Bio-Microbics MicroFAST 4.5F ATU											
01-011-BM7-C4	C4	4.00	63.00	78	154.5	2.5	2400	3,021	ATU	9/13/2007	
REMARKS: Houses BioMicrobics MicroFAST 1.5 (F or S) ATU (NSF 40-certified units only). Inlet and/or outlet can be 4" or 6". Approved to house the BioMicrobics MicroFAST 0.9 ATU (NSF 245-certified units) 5/29/2020											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Florida Septic, Inc.

Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
01-011-BM8-C4	C4	6.00	63.00	82	158.5	2.5	2400	3,021	ATU	3/1/2012	
REMARKS: (01-011-29S-C4 converted to ATU tank, 02-05-2012) Houses Bio-Microbics MicroFAST 1.5 ATU. NSF 40-certified units: with minimum 713 gallon pretreatment tank. NSF 245-certified units: with 1021 to 1613 gallon pretreatment tank.											
01-011-BM9-C4	C4	6.00	53.00	73	137	2.5	1500	1,919	ATU	10/31/2001	
REMARKS: Converted 01-011-27D-C4, Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: 0.5, 0.625, 0.75, 0.9. NSF 245-certified units: 0.5, 0.625, 0.75.. AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-E100-C4	C4	4.00	53.00	69	133	2.5	1500	1,920	ATU	8/27/2020	
REMARKS: Originally approved as 01-011-23S-C4, Houses the Delta EcoPod E100-N ATU (1,000 gpd). Minimum pretreatment tank effective capacity required is 1,000 gal; maximum allowed is 2,500 gal unless specified by the design engineer. The Delta EcoPod is NSF 245-certified.											
01-011-E100H-C4	C4	6.00	53.00	73	137	2.5	1500	1,920	ATU	4/8/2021	
REMARKS: Originally approved as 01-011-27S-C4, Houses the Delta EcoPod E100-N ATU (1,000 gpd). Minimum pretreatment tank effective capacity required is 1,000 gal; maximum allowed is 2,500 gal unless specified by the design engineer. The Delta EcoPod is NSF 245-certified. Lid # 223. HS20											
01-011-E150-C4	C4	4.00	60.00	77.25	153.5	2.5	2300	2,754	ATU	8/27/2020	
REMARKS: Originally approved as 01-011-41S-C4, Houses the Delta EcoPod E150-N ATU (1,500 gpd) . Minimum pretreatment tank effective capacity required is 1,500 gal; maximum allowed is 3,750 gal unless specified by the design engineer. The Delta EcoPod is NSF 245-certified.											
01-011-E150H-C4	C4	6.00	60.00	81.25	157	2.5	2300	1,920	ATU	4/8/2021	
REMARKS: Originally approved as 01-011-60S-C4, Houses the Delta EcoPod E150-N ATU (1,500 gpd). Minimum pretreatment tank effective capacity required is 1,500 gal; maximum allowed is 3,750 gal unless specified by the design engineer. The Delta EcoPod is NSF 245-certified. Lid #224. HS20											
01-011-E200-C4	C4	4.00	49.50	99.75	188	2.5	3300	4,018	ATU	8/27/2020	
REMARKS: Originally approved as 01-011-64S-C4, Houses the Delta EcoPod E200-DCA (2,000 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 2,000 gal.											
01-011-E200H-C4	C4	6.00	49.50	103.8	192	2.5	3300	4,024	ATU	4/8/2021	
REMARKS: Originally approved as 01-011-65S-C4, Houses the Delta EcoPod E200-DCA (2,000 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 2,000 gal. Lid # 225. HS20											
01-011-E250-C3	C3	4.00	55.75	100.1	188.5	2.5	3700	4,460	ATU	8/27/2020	
REMARKS: Originally approved as 01-011-68S-C3, modified structural rib. Houses the Delta EcoPod E250-DCA (2,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 2,500 gal.											
01-011-E250H-C4	C4	6.00	55.75	104.1	192.5	2.5	3700	4,460	ATU	4/8/2021	
REMARKS: Originally approved as 01-011-69S-C3, modified structural rib. Houses the Delta EcoPod E250-DCA (2,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 2,500 gal. Lid # 225. HS20											
01-011-E300-C3	C3	4.00	64.00	101.1	189.5	3	4300	5,100	ATU	8/27/2020	
REMARKS: Originally approved as 01-011-72S-C3, Houses the Delta EcoPod E300-DCA (3,000 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,000 gal.											
01-011-E300H-C4	C4	6.00	64.00	105.1	193.5	3	4300	5,100	ATU	4/8/2021	
REMARKS: Originally approved as 01-011-73S-C3, Houses the Delta EcoPod E300-DCA (3,000 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,000 gal. Lid # 225. HS20											
01-011-E350-C3	C3	4.00	73.50	102	190.75	2.75	5000	5,900	ATU	8/27/2020	
REMARKS: Originally approved as 01-011-76S-C3, Houses the Delta EcoPod E350-DCA (3,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,500 gal.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Florida Septic, Inc.

Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
01-011-E350H-C4	C4	6.00	73.50	106	194.75	2.75	5000	5,900	ATU	4/8/2021	
REMARKS: Originally approved as 01-011-77S-C3, Houses the Delta EcoPod E350-DCA (3,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,500 gal. Lid # 225. HS20											
01-011-E400-C3	C3	4.00	73.50	102	190.75	2.75	5000	5,900	ATU	8/27/2020	
REMARKS: Originally approved as 01-011-76S-C3, Houses the Delta EcoPod E400-DCA (4,000 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 4,000 gal.											
01-011-E400H-C4	C4	6.00	73.50	106	194.75	2.75	5000	5,900	ATU	4/8/2021	
REMARKS: Originally approved as 01-011-77S-C3, Houses the Delta EcoPod E350-DCA (3,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,500 gal. Lid # 225. HS20											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS
 SEPTIC TANK MANUFACTURERS
 run date: 3/31/2026
 Searching for: ATU

Fuji Clean USA

41-2 Greenwood Road
 Brunswick ME 04011

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
70-154-CE10-C3	C3	0.15	59.00	56.25	98.375	2	1069	ATU	11/19/2015		
REMARKS: Fiberglass. Used to house Fuji Clean USA CE10 1000 gpd ATU; no mid-seam testing required											
70-154-CE14-C3	C3	0.12	59.50	69	119	2.5	1498	ATU	5/10/2016		
REMARKS: Fiberglass. Used to house Fuji Clean USA CE14 1350 gpd ATU; no mid-seam testing required											
70-154-CE21-C3	C3	0.12	63.50	72.5	152.88	1.97	2252	2,536 ATU	5/10/2016		
REMARKS: Fiberglass. Used to house Fuji Clean USA CE21 1900 gpd ATU; no mid-seam testing required											
70-154-CE30-C3	C3	0.12	68.88	77.75	183	2.125	3199	3,435 ATU	5/10/2016		
REMARKS: Fiberglass. Used to house Fuji Clean USA CE30 2700 gpd ATU; no mid-seam testing required											
70-154-CE5-C3	C3	0.12	47.25	43.25	84.625	1.6	540	ATU	11/19/2015		
REMARKS: Fiberglass. Used to house Fuji Clean USA CE5 500 gpd ATU; no mid-seam testing required											
70-154-CE7-C3	C3	0.12	50.88	48.25	94.75	2	749	ATU	11/19/2015		
REMARKS: Fiberglass. Used to house Fuji Clean USA CE7 700 gpd ATU; no mid-seam testing required											
70-154-CEN10-C3	C3	0.12	59.50	69	119	2.5	1498	ATU	11/19/2015		
REMARKS: Fiberglass. Used to house Fuji Clean USA CEN10 1000 gpd ATU; no mid-seam testing required. The CEN is NSF 245 certified.											
70-154-CEN14-C3	C3	0.12	63.50	72.5	152.88	1.97	2252	2,536 ATU	1/30/2020		
REMARKS: Fiberglass. Used to house Fuji Clean USA CEN 14 1350 gpd ATU; no mid-seam testing required. The CEN is NSF 245 certified.											
70-154-CEN21-C3	C3	0.12	68.88	77.75	183	2.125	3199	3,435 ATU	2/28/2020		
REMARKS: Fiberglass. Used to house Fuji Clean USA CEN21 1900 gpd ATU; no mid-seam testing required.											
70-154-CEN5-C3	C3	0.12	50.88	48.25	94.75	2	749	ATU	11/19/2015		
REMARKS: Fiberglass. Used to house Fuji Clean USA CEN5 500 gpd ATU; no mid-seam testing required. The CEN is NSF 245 certified.											
70-154-CEN7-C3	C3	0.15	59.00	56.25	98.375	2	1069	ATU	11/19/2015		
REMARKS: Fiberglass. Used to house Fuji Clean USA CEN7 700 gpd ATU; no mid-seam testing required. The CEN is NSF 245 certified.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

George W. Shepard & Son, Inc.

PO Box 202
Naples FL 34106

Collier

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH						
11-149-H10G-C3	C3	2.50	65.00	89	89	1.25	1880	2,100	ATU	2/26/2014	1
REMARKS: Houses the Hoot 1000 gpd gravity ATU system (H-1000 A), requires 700-1500 gal pretreatment tank											
11-149-H10G-C4	C4	2.50	65.00	89	89	1.25	1880	2,100	ATU	2/26/2014	1
REMARKS: Houses the Hoot 1000 gpd gravity ATU system (H-1000 A), requires 700-1500 gal pretreatment tank; 5000 psi concrete											
11-149-H10P-C3	C3	2.50	65.00	89	157		3309		ATU	10/25/2011	1
REMARKS: Formerly manufactured by Averett 53-037-H10P-C3; Houses the Hoot 1000 gpd dosed ATU system (H-1000 AND), requires 700-1500 gal pretreatment tank. The H-1000 AND needs recirculation from the drip irrigation filter flush for the nitrogen-reducing PBTS configuration. With DEP Lid #239 (for chlorinator/dechlorinator; 3 inches thick); Lid #238 (for chlorinator/dechlorinator; 8 inches thick, H2O traffic, tank remains C3); Lid #241 (approved June 2012, 8 inches thick, H2O traffic, tank remains C3). Revised 9/9/2024.											
11-149-H10P-C4	C4	2.50	65.00	89	157		3309		ATU	4/3/2012	1
REMARKS: Houses the Hoot 1000 gpd dosed ATU system (H-1000 AND), requires 700-1500 gal pretreatment tank; 5000 psi concrete. The H-1000 AND needs recirculation from the drip irrigation filter flush for the nitrogen-reducing PBTS configuration. With DEP Lid #239 (for chlorinator/dechlorinator; 3 inches thick); Lid #238 (for chlorinator/dechlorinator; 8 inches thick, H2O traffic, tank remains C4); Lid #241 (approved June 2012, 8 inches thick, H2O traffic, tank remains C4). Revised 9/9/2024.											
11-149-H4P-C4	C4	2.50	52.00	74.5	177.5		2239	3,105	ATU	4/7/2021	
REMARKS: Monolithic baffles. Houses the Hoot ANR-450 and ANR-500 gpd NSF 245 ATU with lid #179, #180 (traffic rated), #230 (access port layout for drip irrigation headworks) or #231 (access port layout for drip irrigation headworks and traffic rated). Optional side inlets centered approximately 12" from inlet side of tank. Inlet inverts 57" from outside bottom of tank. Revised 5/8/2024.											
11-149-H6G-C3	C3	2.50	52.00	74.5	106		1320		ATU	10/24/2011	3
REMARKS: Formerly manufactured by Averett 53-037-H6G-C3; Houses either the Hoot 500 or 600 gpd gravity flow ATU (H-500A; H-600A)											
11-149-H6G-C4	C4	2.50	52.00	74.5	106		1320		ATU	7/12/2012	8
REMARKS: Houses either the Hoot 500 or 600 gpd gravity flow ATU (H-500A; H-600A); 5000 psi concrete											
11-149-H6P-C4	C4	2.50	52.00	74.5	160		2080		ATU	7/12/2012	8
REMARKS: Houses either the Hoot 500 or 600 gpd dosed ATU system (H-500 AND, H-600 AND). The H-500/600 AND needs recirculation from the drip irrigation filter flush for the nitrogen-reducing PBTS configuration. 5000 psi concrete. With DEP Lid #233 (for chlorinator/dechlorinator; 8 inches thick, H2O traffic, tank remains C4), Lid #234 (approved June 2012, 8 inches thick, H2O traffic, tank remains C4). Also houses the Hoot NR-600 NSF 245 certified ATU. Drawing revised 9/1/2023. Listing revised 1/29/2025.											
11-149-H6P-C3	C3	2.50	52.00	74.5	160		2080		ATU	10/25/2011	2
REMARKS: Formerly manufactured by Averett 53-037-H6P-C3; Houses either the Hoot 500 or 600 gpd dosed ATU system (H-500 AND, H-600 AND). The H-500/600 AND needs recirculation from the drip irrigation filter flush for the nitrogen-reducing PBTS configuration. With DEP Lid #232 (for chlorinator/dechlorinator; 3 inches thick); Lid #233 (for chlorinator/dechlorinator; 8 inches thick, H2O traffic, tank remains C3); Lid #234 (approved June 2012, 8 inches thick, H2O traffic, tank remains C3). Also houses the Hoot NR-600 NSF 245 certified ATU. Drawing revised 9/1/2023. Listing revised 1/29/2025.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Gunter Septic Tank Mfg.

1434 Martin Luther King Blvd.

Seffner FL 33565

Hillsborough

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
29-022-PS1A-C4	C4	3.00	42.00	62.25	62.25	1	525	637	ATU	1/17/2025	
REMARKS: Houses the Anua PuraSys PS1-5 to PS1-8 ATU. Requires single or dual compartment pre-treatment tank, sized using Table II of 62-6, Florida Administrative Code based on the unit treatment capacity. The PuraSys is NSF 245 certified. Variation of 29 022 06S C4. Revised drawing approved January 17, 2025.											
29-022-PS1B-C4	C4	3.50	53.00	68	128	1	1500	1,704	ATU	1/17/2025	
REMARKS: Houses the Anua PuraSys PS1-4 ATU. The PuraSys is NSF 245 certified. Variation of 29 022 21D C3. Revised drawing approved January 17, 2025.											
29-022-PS1C-C4	C4	3.50	57.00	74	120.25	1	1650	1,931	ATU	1/17/2025	
REMARKS: Houses the Anua PuraSys PS1-5 ATU. The PuraSys is NSF 245 certified. Variation of 29 022 26D C3. Revised drawing approved January 17, 2025.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

H.G. McGrew, Inc.

3805 Industrial Drive
Bossier City LA 71112

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL	
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE	DATE
70-121-MM1-C4	C4	0.38	66.00					ATU	3/22/2002	
REMARKS: Used to house the Mighty Mac 500 ATU										
70-121-MM2-C3	C3	0.38	66.00					ATU	10/6/2002	
REMARKS: Used to house the Mighty Mac 750 ATU										
70-121-MM3-C3	C3	0.38	66.00					ATU	10/6/2002	
REMARKS: Used to house the Mighty Mac 600 ATU										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Howie Concrete Products, Inc.

2817 Central Avenue
Big Pine Key, FL 33043

Monroe

Active

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL		
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE	DATE	FAMILY
44-085-08D-C3	C3	2.50	41.00				900			1/23/2004	
REMARKS: Houses the Bio-Microbics MicroFAST 0.5F short ATU (NSF 40-certified units only). Houses .250 and .375 RetroFAST units as Alternative Repair Method.											
44-085-11D-C3	C3	2.50	41.00				1050			1/23/2004	
REMARKS: Houses the Bio-Microbics MicroFAST 0.5F short ATU (NSF 40-certified units only). Houses .250 and .375 RetroFAST units as Alternative Repair Method.											
44-085-NW1-C3	C3	2.50	54.00							3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 500/600 gallon per day ATU. Add 1000 gallon pretreatment chamber to become 1000 gallon per day ATU. The Singulair TNT models are NSF 245 certified.											
44-085-NW2-C3	C3	2.50	66.00							3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 750/800 gallon per day ATU. Add 1250 pretreatment chamber to become 1250 gallon per day ATU. The Singulair TNT models are NSF 245 certified.											
44-085-NW3-C3	C3	2.50	78.00							3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 1500 gallon per day ATU (requires minimum 1500 gallon pretreatment tank) The Singulair TNT models are NSF 245 certified.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Hydro-Action

2055 Pidco Drive
Plymouth IN 46563

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL	
				WIDTH	LENGTH			(Pump Tanks)	USE	DATE	FAMILY
70-118-HA1-C3	C3	0.25	64.00		70	1	798	997	ATU	9/24/2002	
REMARKS: Fiberglass tank. Hydro-Action Model PP800. Approved for use as pretreatment tank for AN-800 ATU (800 gallon per day; NSF 40 and 245 certified), treatment tank for AN-400 ATU (450 gallon per day; NSF 40 and 245 certified) and AP-500 ATU (500 gallon per day; NSF 40 certified).											
70-118-HA10-C4	C4		63.00		57.25	1	506	641	ATU	5/20/2025	
REMARKS: Fiberglass tank. Hydro-Action Model PP500. Approved for use as pretreatment tank for AN-500 ATU (550 gallon per day). NSF 40 and 245 certified.											
70-118-HA11-C4	C4		63.00		68.875	1	762	960	ATU	5/20/2025	
REMARKS: Fiberglass tank. Hydro-Action Model PP750. Approved for use as pretreatment tank for AN-600 ATU (660 gallon per day). NSF 40 and 245 certified.											
70-118-HA2-C3	C3	0.25	64.00		76	1	968	1,215	ATU	9/24/2002	
REMARKS: Fiberglass tank. Hydro-Action Model PP1000. Approved for use as treatment tank for AN-500 ATU (550 gallon per day; NSF 40 and 245 certified) and AP-600 ATU (600 gallon per day; NSF 40 certified).											
70-118-HA3-C3	C3	0.31	64.00		82	1	1125	1,384	ATU	9/24/2002	
REMARKS: Fiberglass tank. Hydro-Action Model PP1200. Approved for use as pretreatment tank for AN-1100 ATU (1100 gallon per day; NSF 40 and 245 certified), treatment tank for AN-600 ATU (660 gallon per day; NSF 40 and 245 certified), and AP-750 ATU (750 gallon per day; NSF 40 certified).											
70-118-HA4-C3	C3	0.38	70.00		86.25	1	1460	1,832	ATU	9/24/2002	
REMARKS: Fiberglass tank. Hydro-Action Model PP1500. Approved for use as treatment tank for AP-1000G ATU (1000 gallon per day). NSF 40 certified.											
70-118-HA5-C3	C3	0.38	80.00		95	1	1948	1,879	ATU	9/24/2002	
REMARKS: Fiberglass tank. Hydro-Action Model PP2200. Approved for use as treatment tank for AN-1100 ATU (1100 gallon per day; NSF 40 and 245 certified) and, AP-1500G ATU (1500 gallon per day; NSF 40 certified).											
70-118-HA6-C4	C4		62.00		95	1	1495	1,879	ATU	5/20/2025	
REMARKS: Fiberglass tank. Hydro-Action Model PP1600. Approved for use as treatment tank for AN-800 ATU (800 gallon per day). NSF 40 and 245 certified.											
70-118-HA7-C4	C4		45.00		57.25	1	349	483	ATU	5/20/2025	
REMARKS: Fiberglass tank. Hydro-Action Model LPP300. Approved for use as a pretreatment tank for AN-IVS ATU (450 gallon per day). NSF 40 and 245 certified. use as a pretreatment tank for AN-IVS ATU (450 gallon											
70-118-HA8-C4	C4		44.00		82	1	801	1,005	ATU	5/20/2025	
REMARKS: Fiberglass tank. Hydro-Action Model LPP750. Approved for use as treatment tank for LP-500 ATU (500 gallon per day; NSF 40 certified) and, AN-IVS ATU (450 gallon per day; NSF 40 and 245 certified).											
70-118-HA9-C4	C4		63.00		52	1	385	500	ATU	5/20/2025	
REMARKS: Fiberglass tank. Hydro-Action Model PP400. Approved for use as pretreatment tank for AN-400 ATU (450 gallon per day). NSF 40 and 245 certified.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Infiltrator Water Technologies, LLC

4 Business Park Road; P.O. Box 768
Old Saybrook, CT 06475

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
70-143-16D-C4	C4	0.20	44.00	61.7	175.6	2	1537	1,750	B,D,L	4/3/2014 5
REMARKS: Dual compartment polypropylene tank with four vertical stiffeners and baffle attached to stiffener. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches. IM-1530. Can house SludgeHammer S-400 ATU. Remarks updated 1/29/2025.										
70-143-EA5-C4	C4	0.20	44.00	62.2	127	2	1090	1,280		10/20/2020
REMARKS: Three compartment polypropylene tank. Two vertical, two lateral and four diagonal horizontal stiffeners. Houses Delta Enviro-Aire 52.5 ATU (525 gal/day). Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches. IM 1060.										
70-143-EA6-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309		7/14/2023
REMARKS: Three compartment polypropylene tank with two internal vertical stiffeners, two lateral and four diagonal horizontal stiffeners. Houses Delta Enviro-Aire 52.5 ATU (525 gal/day). The Delta Enviro-Aire 52.5 is NSF 40-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial is six inches. CM-1060.										
70-143-EA7-C4	C4	0.20	44.00	61.7	175.6	2	1537	1,750		10/20/2020
REMARKS: Three compartment polypropylene tank. Four vertical, three lateral and four diagonal horizontal stiffeners. Houses Delta Enviro-Aire EA75 ATU (750 gal/day). Inlet/outlet reversed from usual IM 1530. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-ED1-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309	ATU	7/8/2025
REMARKS: Multi compartment polypropylene tank with two internal vertical stiffeners and three baffles. Houses the ECOPOD Edge500 (500 GPD) ATU. The ECOPOD Edge 500 is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial is six inches. CM-1060.										
70-143-EP10S-C4	C4	0.20	44.00	61.7	175.6	2	1537	1,750	ATU	12/23/2019
REMARKS: Single compartment polypropylene tank with four vertical stiffeners. Houses Delta ECOPOD E100-N-IM1530 (1000 gal/day). Requires min 1000-gal pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-EP5S-C4	C4	0.20	44.00	62.2	127	2	1090	1,280	ATU	8/9/2019
REMARKS: Single compartment polypropylene tank, two vertical and six horizontal stiffeners. Houses Delta ECOPOD E50-N-IM1060 (500 gal/day). Requires min 500-gal or 70-143-54S-C4 pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-EP5S-C3	C3	0.20	44.00	62.2	127	2	1090	1,280	ATU	1/9/2019
REMARKS: Single compartment polypropylene tank, two vertical stiffeners. Houses Delta ECOPOD E50-N-IM1060 (500 gal/day). Requires min 500-gal or 70-143-54S-C4 pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-EP6S-C4	C4	0.20	44.00	62.2	127	2	1090	1,280	ATU	8/9/2019
REMARKS: Single compartment polypropylene tank, two vertical and six horizontal stiffeners. Houses Delta ECOPOD E60-N-IM1060 (600 gal/day). Requires min 600-gal pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-EP6S-C3	C3	0.20	44.00	62.2	127	2	1090	1,280	ATU	1/9/2019
REMARKS: Single compartment polypropylene tank, two vertical stiffeners. Houses Delta ECOPOD E60-N-IM1060 (600 gal/day). Requires min 600-gal pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-EP7S-C3	C3	0.20	44.00	62.2	127	2	1090	1,280	ATU	1/9/2019
REMARKS: Single compartment polypropylene tank, two vertical stiffeners. Houses Delta ECOPOD E75-N-IM1060 (750 gal/day). Requires min 750-gal pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Infiltrator Water Technologies, LLC

4 Business Park Road; P.O. Box 768
Old Saybrook, CT 06475

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
70-143-EP7S-C4	C4	0.20	44.00	62.2	127	2	1090	1,280 ATU	8/9/2019	
REMARKS: Single compartment polypropylene tank, two vertical and six horizontal stiffeners. Houses Delta ECOPOD E75-N-IM1060 (750 gal/day). Requires min 750-gal pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-EPC5S-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309	6/23/2022	
REMARKS: Single compartment polypropylene tank with two internal vertical stiffeners. Houses Delta ECOPOD E50-N (500 gal/day). Requires min 500-gallon or 70-143-54S-C4 pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial is six inches. CM-1060.										
70-143-EPC6S-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309	6/23/2022	
REMARKS: Single compartment polypropylene tank with two internal vertical stiffeners. Houses Delta ECOPOD E60-N (600 gal/day). Requires min 600-gallon pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial is six inches. CM-1060.										
70-143-EPC7S-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309	6/23/2022	
REMARKS: Single compartment polypropylene tank with two internal vertical stiffeners. Houses Delta ECOPOD E75-N (750 gal/day). Requires min 750-gallon pretreatment tank; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta ECOPOD ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial is six inches. CM-1060.										
70-143-EZ1-C3	C3	0.20	44.00	62.2	127	2	1090	1,280 ATU	8/5/2025	
REMARKS: Single compartment polypropylene tank. Category 3 tank with 2 vertical stiffeners. As with all Infiltrator tanks, any holes must be installed by the manufacturer or certified assembler. Approved as a recirculating and a pump tank for E-Z Treat Model 600 and 750. Midseam length and width. Use of side inlets/outlets only allowed when used as a component of E-Z Treat ATU system. Minimum burial depth is six inches. Modification of the 70-143-11S-C3 IM 1060.										
70-143-EZ1-C4	C4	0.20	44.00	62.2	127	2	1090	1,280 ATU	8/5/2025	
REMARKS: Single compartment polypropylene tank. Category 4 tank with 2 vertical and 6 horizontal support stiffeners. As with all Infiltrator tanks, any holes must be installed by the manufacturer or certified assembler. Approved as a recirculating and a pump tank for E-Z Treat Model 600 and 750. Midseam length and width. Use of side inlets/outlets only allowed when used as a component of E-Z Treat ATU system. Minimum burial depth is six inches. Modification of the 70 143 11S C4 IM 1060.										
70-143-EZ2-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309 ATU	8/5/2025	
REMARKS: Single compartment polypropylene tank with two internal vertical stiffeners. Midseam length and width. As with all Infiltrator tanks, any holes must be installed by the manufacturer or certified assembler. Approved as a recirculating and a pump tank for E-Z Treat Model 600 and 750. Midseam length and width. Use of side inlets/outlets only allowed when used as a component of E-Z Treat ATU system. Minimum burial is six inches. Modification of the 70 143 21S C4 CM-1060.										
70-143-NR5-C4	C4	0.20	44.00	62.2	127	2	1090	1,280	6/28/2023	
REMARKS: Single compartment polypropylene tank. Two vertical, two lateral and four diagonal horizontal stiffeners. Houses Delta Ecopod E-50NR (500 gal/day). Requires min 475 gal pretreatment volume; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta Ecopod E-50NR ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches. IM 1060.										
70-143-NRC5-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309	6/28/2023	
REMARKS: Single compartment polypropylene tank. Two vertical stiffeners. Houses Delta Ecopod E-50NR (500 gal/day). Requires min 475 gal pretreatment volume; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta Ecopod E-50NR ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches. CM 1060.										
70-143-NX5-C4	C4	0.20	44.00	62.2	127	2	1090	1,280	9/20/2023	
REMARKS: Single compartment polypropylene tank. Two vertical, two lateral and four diagonal horizontal stiffeners. Houses Delta Ecopod E-50NX (500 gal/day). Requires min 475 gal pretreatment volume; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta Ecopod E-50NX ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches. IM 1060.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Infiltrator Water Technologies, LLC

4 Business Park Road; P.O. Box 768
Old Saybrook, CT 06475

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
70-143-NX6-C4	C4	0.20	44.00	61.7	175.6	2	1537	1,750	12/21/2023	
REMARKS: Dual compartment polypropylene tank with four vertical stiffeners. Houses Delta Ecopod E-50NX (500 gal/day). The Delta Ecopod E-50NX ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches. IM-1530.										
70-143-NXC5-C4	C4	0.20	44.00	61.7	134.2	2	1111	1,309	9/20/2023	
REMARKS: Single compartment polypropylene tank. Two vertical stiffeners. Houses Delta Ecopod E-50NX (500 gal/day). Requires min 475 gal pretreatment volume; max pretreatment volume is 2.5 times daily treatment capacity unless specified by the design engineer. The Delta Ecopod E-50NX ATU is NSF 245-certified. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches. CM 1060.										
70-143-PS1A-C4	C4	0.20		61.7	64.9	3	483	557 ATU	5/7/2020	
REMARKS: Polypropylene. Houses the Anua PuraSys PS1-5 to PS1-8 ATU. Requires single or dual compartment pretreatment tank, sized using Table II of 64E-6, Florida Administrative Code based on the unit treatment capacity. The PuraSys is NSF 245 certified. Variation of IM-540. Revised drawing approved 8/4/2021. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										
70-143-PS1B-C4	C4	0.20		62.2	127		1090	1,280 ATU	5/7/2020	
REMARKS: Polypropylene. Houses the Anua PuraSys PS1-9 to PS1-13 ATU. No inlet and outlet holes. Requires single or dual compartment pretreatment tank, sized using Table II of 64E-6, Florida Administrative Code based on the unit treatment capacity. The PuraSys is NSF 245 certified. Variation of IM-1060. Two vertical stiffeners and six horizontal stiffeners. Midseam length and width. Use of side inlets/outlets not allowed in Florida. Minimum burial depth is six inches.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Jones Precast, Inc.

880 Arron RD

Crawfordville FL 32327

Wakulla

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL USE DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
65-162-BM3-C3	C3	2.50	40.25	60	119	2.25	900	1,045	6/15/2023	

REMARKS: For use with Bio-Microbics MicroFAST ATUs shortened installation. NSF 40 configurations only; houses MicroFAST 0.5. Either one of the side outlets to be used for the air line only. Lid #235 (3 inches thick).



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Mack Concrete Industries

Post Office Box 157

Astatula, FL 34705

Lake

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
35-015-08D-C3	C3	2.50	42.00				1050		3/22/2002	
REMARKS: Houses Bionest BNC-400 ATU										
35-015-15D-C3	C3	3.00	48.00				1500		3/22/2002	
REMARKS: Houses Bionest BNC-500 ATU and 600 ATU										
35-015-30D-C3	C3	3.00	48.00				2000		3/22/2002	
REMARKS: Houses Bionest BNC-750 ATU										
35-015-64D-C3	C3	4.00	42.00				3500		3/22/2002	
REMARKS: Houses Bionest BNC-1250 ATU										
35-015-72D-C3	C3	4.00	51.00				4300		3/22/2002	
REMARKS: Houses Bionest BNC-1500 ATU										
35-015-CA1-C3	C3	2.50	55.00	62	94			ATU	9/18/2008	
REMARKS: CajunAire 500 gallon per day ATU										
35-015-NW1-C3	C3	2.50	54.00						3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 500/600 gallon per day ATU. Add 1000 gallon pretreatment chamber to become 1000 gallon per day ATU. Singulair TNT models are NSF 245-certified.										
35-015-NW2-C3	C3	2.20	66.00						3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 750/800 gallon per day ATU. Add 1250 pretreatment chamber to become 1250 gallon per day ATU. Singulair TNT models are NSF 245-certified.										
35-015-NW3-C3	C3	2.50	78.00						3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 1500 gallon per day ATU (requires minimum 1500 gallon pretreatment tank). Singulair TNT models are NSF 245-certified.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Mid-State Precast, Inc.

8037 Commercial Blvd.
Sebring FL 33870

Highlands

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	APPROVAL USE DATE	FAMILY
				WIDTH	LENGTH					
28-O15-03D-C4	C4	3.00	55.00				1050		11/9/2001	
REMARKS: Houses Bionest BNC-400 ATU. Monolithic baffle										
28-O15-06D-C4	C4	3.00	49.50				1250		11/9/2001	
REMARKS: Houses Bionest BNC-500 ATU. Monolithic baffle										
28-O15-08D-C3	C3	3.00	53.30				1050		11/9/2001	
REMARKS: Houses Bionest BNC-400 ATU. Also available in 4" and 6" thick wall tanks										
28-O15-10D-C4	C4	6.00	53.30				1050		4/22/2002	
REMARKS: Houses Bionest BNC-400 ATU. HS20 traffic rated										
28-O15-16D-C3	C3	3.00	57.80				1250		4/22/2002	
REMARKS: Houses Bionest BNC-500 ATU; slide-in baffle										
28-O15-17D-C3	C3	4.00	57.80				1250		8/2/2002	
REMARKS: Houses Bionest BNC-500 ATU; slide-in baffle										
28-O15-19D-C3	C3	3.00	44.00	68	145	1	1500	1,800 b	4/22/2002	
REMARKS: Houses Bionest BNC-600 ATU. Monolithic baffle										
28-O15-24D-C4	C4	6.00	42.00	90	130		1500		4/22/2002	
REMARKS: Without slide-in baffle, houses Bio-Microbics MicroFAST 1.5 ATU when used with 713 gallon min pretreatment tank (02/26/10) (NSF 40-certified units only). HS20 traffic rated.										
28-O15-24S-C4	C4	6.00	42.00	90	130		1500		4/22/2002	
REMARKS: Houses Bio-Microbics MicroFAST 1.5 ATU when used with 713 gallon min pretreatment tank (02/26/10) (NSF 40-certified units only). HS20 traffic rated.										
28-O15-34D-C4	C4	6.00	56.00				2000		4/22/2002	
REMARKS: Houses Bionest BNC-750 ATU. HS20 traffic rated										
28-O15-35D-C4	C4	4.00	55.50				2000	2,455	11/19/2004	
REMARKS: Houses Bionest BNC-750 ATU.										
28-O15-46D-C4	C4	6.00	70.00				2500		12/12/2000	
REMARKS: Houses Bionest BNC-1000 ATU. HS20 traffic rated										
28-O15-AA1-C3	C3	3.00	52.00	64	103	2	1098		6/30/2006	
REMARKS: Approved for use to house Aqua Aire AA500 NSF 40 or AA500-35NR NSF 40/245 certified ATU (both 500 gpd). Updated 2/4/2025.										
28-O15-AA2-C3	C3	3.00	54.00	75	88	2	1155		10/5/2006	
REMARKS: Approved for use to house Aqua Aire AA800 NSF 40 or AA800-5NR NSF 245 certified ATU (both 800 gpd). AA800-5NR requires pretreatment tanks (minimum effective capacity 500 gallons, maximum 1000 gallons). Updated 8/5/2024.										
28-O15-AA3-C3	C3	2.50	52.00	64	81.5	2	857		4/13/2007	
REMARKS: Approved for use to house Aqua Aire AA600 NSF 40 or AA600-4NR NSF 245 certified ATU (both 600 gpd). AA600-4NR requires pretreatment tanks (minimum effective capacity 400 gallons, maximum 1000 gallons). Updated 8/5/2024.										
28-O15-AA4-C3	C3	3.00	52.00	75	115	2	1420		5/7/2008	
REMARKS: Approved for use to house Aqua Aire AA1000 NSF 40 or AA1000-75NR NSF 245 certified ATU (both 1000 gpd). AA1000-75NR requires pretreatment tanks (minimum effective capacity 750 gallons, maximum 1000 gallons). Updated 8/5/2024.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS
 SEPTIC TANK MANUFACTURERS
 run date: 3/31/2026
 Searching for: ATU

Mid-State Precast, Inc.

8037 Commercial Blvd.
 Sebring FL 33870

Highlands

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
28-O15-AA5-C3	C3	3.00	62.00	90	90	2	1751		8/25/2010	
REMARKS: Approved for use to house Aqua Aire AA1200 NSF 40 or AA1200-75NR NSF 245 certified ATU (both 1200 gpd). AA1200-75NR requires pretreatment tanks (minimum effective capacity 750 gallons, maximum 1200 gallons). Updated 8/5/2024.										
28-O15-AW1-C3	C3	2.50	52.00				500		8/19/2003	
REMARKS: American Wastewater 500 gallon per day B.E.S.T. 1 ATU										
28-O15-AW2-C3	C3	2.50	54.00				800		2/3/2004	
REMARKS: American Wastewater 800 gallon per day B.E.S.T. 1 ATU										
28-O15-AW3-C3	C3	2.50	82.00				1200		2/3/2004	
REMARKS: American Wastewater 1200 gallon per day B.E.S.T. 1 ATU										
28-O15-AW4-C3	C3	2.50	61.00	0	0		1000		6/30/2006	
REMARKS: American Wastewater 1000 gallon per day B.E.S.T. 1 ATU										
28-O15-NW1-C3	C3	2.50	51.00						8/23/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 500/600 gallon per day ATU. Add 1000 gallon pretreatment chamber to become 1000 gallon per day ATU. TNT model is NSF 245 certified.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Murrill Tank Service, Inc.

3621 Alab Club Road
Mobile AL 36605

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
68-135-H10P-C4	C4	2.50	64.00					ATU	8/3/2007	
REMARKS: Houses the Hoot 1000 gpd dosed ATU system; requires 700-1500 gal pretreatment tank										
68-135-H6G-C3	C3	2.50	52.00					ATU	1/8/2007	
REMARKS: Houses either the Hoot 500 or 600 gpd gravity flow ATU system.										
68-135-H6P-C3	C3	2.50	52.00					ATU	1/8/2007	
REMARKS: Houses either the Hoot 500 or 600 gpd dosed or drip irrigation ATU system										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Norweco

220 Republic Street
Norwalk OH 44857-1156

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
70-150-NW1-C3	C3	0.38	52.00	78	125.5	4	1280	1,430 ATU	11/17/2011	
REMARKS: Polyethylene tank; three joined compartments; used to house ATU Norweco Singulair Green 960-500 or TNT-500 ATU, Both are NSF-40 certified for 500 and 600 gpd; TNT-500 is NSF 245-certified for 500 gpd and 600 gpd. Also houses the first component of the Norweco Singulair Green R3-500 GPD (NSF 245 certified; 500 and 600 gpd). Length revised 10/27/2016.										
70-150-NW2-C3	C3	0.38	50.50	78	63	1	485	600	2/18/2022	
REMARKS: Polyethylene single compartment tank used to house the Norweco Hydro-Kinetic Biofilter, a component of the Norweco Singulair Green R3-500 GPD ATU (NSF 245 certified; 500 and 600 gpd). The 70-150-NW1-C3, housing the first component of the Norweco Singulair Green R3-500 GPD, precedes this tank.										
70-150-NW3-C3	C3	0.38	51.50	78	168		1750	1,750 ATU	3/6/2025	
REMARKS: Polyethylene tank; four joined compartments. Used to house ATU Norweco Singulair Green 960-500 or TNT-500 ATU, both are NSF-40 certified for 500 and 600 gpd; TNT-500 is NSF 245-certified for 500 gpd and 600 gpd. Design based on the 70-150-NW1-C3 tank with an added pump compartment.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Norwesco/Snyder Industries

4365 Steiner Street
St. Bonifacius MN 55375

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
70-156-PS1A-C3	C3	0.25	46.00	63.5	63.5	2	525	525 ATU	5/7/2020	
REMARKS: Polyethylene. Houses the Anua PuraSys PS1-5 to PS1-8 ATU. Requires single or dual compartment pretreatment tank, sized using Table II of 64E-6, Florida Administrative Code based on the unit treatment capacity. The PuraSys is NSF 245 certified. Variation of Snyder Industries "525 Gallon D2"; Norwesco "525 Gallon Low Profile" P/N 44831. Revised drawing approved 4/29/2021.										
70-156-PS1C-C3	C3	0.25		50	127		1050	1,223 ATU	5/7/2020	
REMARKS: Polyethylene. Houses the Anua PuraSys PS1-9 to PS1-14 ATU. No inlets/outlets. Requires single or dual compartment pretreatment tank, sized using Table II of 64E-6, Florida Administrative Code based on the unit treatment capacity. The PuraSys is NSF 245 certified. Variation of Snyder Industries "1050 Gallon D2"; Norwesco "1050 Gallon Low Profile".										
70-156-PS1D-C3	C3	0.25		60	157		1250	1,443 ATU	5/7/2020	
REMARKS: Polyethylene. Houses the Anua PuraSys PS1-13 to PS1-14 ATU. No inlets/outlets. Requires single or dual compartment pretreatment tank, sized using Table II of 64E-6, Florida Administrative Code based on the unit treatment capacity. The PuraSys is NSF 245 certified. Variation of Snyder Industries "1250 Gallon D2"; Norwesco "1250 Gallon Low Profile".										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Orencia Systems, Incorporated

814 Airway Avenue
Sutherlin Or 97479

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		

70-128-AXRT1-C3	C3								5/24/2010	
REMARKS: Fiberglass recirculating tank used to house Advantex AX20-RT as part of a 500 gpd ATU (NSF 245-certified), requires 1000 gal minimum pretreatment tank.										

70-128-X100-C3	C3								11/28/2006	
REMARKS: Fiberglass tank used to house AdvanTex AX100 treatment media as part of a 2000 gpd ATU.										

70-128-X20-C3	C3								8/30/2004	
REMARKS: Fiberglass tank used to house AdvanTex AX20 treatment media as part of a 500 gpd ATU (NSF 245-certified).										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Perry Precast, Inc.

P.O. Box 24

Mayo FL 32066

Lafayette

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL	
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE DATE	FAMILY
34-107-11S-C3	C3	3.00	42.00				1050	1,373		1/30/2006
REMARKS: 11/28/2018 - Also houses Bio-Microbics MicroFAST ATUs. NSF 40 units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625 or 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required). NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gallon settling tank required). HS 1.0 with 500 gal min. pretreatment tank.										
34-107-16S-C3	C3	3.00	42.00				1650	2,078		1/30/2006
REMARKS: 11/28/2018 - Also houses Bio-Microbics MicroFAST 1.5 ATU (NSF 40-certified units only; min 713 gallon pretreatment tank required).										
34-107-AK6S-C3	C3	3.00	53.63	50	139.63	2	1069	1,265		11/9/2023
REMARKS: Concrete tank. Monolithic baffles. Houses AquaKlear AK6S245F ATU (600 gal/day), NSF245-certified. Two notches for 1/2" airline and one notch for optional drip recirculation on inlet side. Lid #174										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Premier Tech

1, Avenue Premier
Quebec G5R 6C1 C

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL		
				WIDTH	LENGTH			(Pump Tanks)	USE	DATE	FAMILY
70-124-650-C3	C3		49.00							4/3/2003	

REMARKS: Fiberglass tank-Used to house the STB-650 EcoFlo peat biofilter ATU



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Quanics

3244 Old LaGrange Road
Crestwood KY 40014

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
70-116-01-C3	C3	0.25	30.00						8/29/2002	
REMARKS: ATS-SCAT-200 (200 gallon per day ATU) fiberglass										
70-116-02-C3	C3	0.25	30.00						8/29/2002	
REMARKS: ATS-SCAT-400 (400 gallon per day ATU) fiberglass										
70-116-03-C3	C3	0.25	30.00						8/29/2002	
REMARKS: ATS-SCAT-650 (650 gallon per day ATU) fiberglass										
70-116-04-C3	C3	0.25	30.00						8/29/2002	
REMARKS: ATS-SCAT-1050 (1050 gallon per day ATU) fiberglass										
70-116-08-C3	C3	0.31		96	198		3000		9/8/2010	
REMARKS: Fiberglass (FRP) Houses 5000 gpd Quanics Aerocell or Bio-COIR ATU media										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Rick's Pre Fab

8450 SW 43 Terrace
Miami FL 33155

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
13-045-04S-C3	C3	3.00	51.00				900		3/22/2002	
REMARKS: Also houses Bio-Microbics MicroFAST 0.5 ATU. NSF 40-certified units: min. 333 gallon min. settling tank required; NSF 245-certified units: 475 to 750 gallon settling tank required.										
13-045-08S-C3	C3	3.00	51.00	60	104	2	1050	1,260 B	1/3/2007	
REMARKS: Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required); NSF 245-certified units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gallon settling tank required). Can house HS 1.0 with 500 gallon min. pretreatment tank.										
13-045-12S-C3	C3	3.13	51.00	68	102	2	1200	1,460 B, ATU	3/22/2002	
REMARKS: Also houses RetroFAST 0.25 and 0.375 as Alternative Drainfield Repair. Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625/0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required); NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gallon settling tank required); MicroFAST 0.9 (689 to 1088 gal min. settling tank required).. Can house HS 1.0 with 500 gallon min. pretreatment tank. 8/31/17 - Wall revised based on 2005 drawing.										
13-045-16S-C3	C3	3.13	51.00				1350		3/22/2002	
REMARKS: Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (450 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required); NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gallon settling tank required); MicroFAST 0.9 (689 to 1088 gallon settling tank required) Can house H.S. 1.0.										
13-045-20S-C3	C3	3.13	51.00				1500		3/22/2002	
REMARKS: Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (450 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required); NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gallon settling tank required); MicroFAST 0.9 (689 to 1088 gallon settling tank required). Can house H.S. 1.0.										
13-045-21S-C3	C3	4.00	51.00	62	92		900		8/19/2009	
REMARKS: H10 traffic rating. Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); NSF 245 units: MicroFAST 0.5, (475 to 750 gallon gal min. settling tank required); RetroFAST 0.25 and 0.375 as Alternative Drainfield Repair.										
13-045-22S-C3	C3	4.00	51.00	62	106		1050		8/19/2009	
REMARKS: H10 traffic rating. Also houses Bio-Microbics MicroFAST. NSF 40-certified units: MicroFAST 0.5 ATU (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (450 gal min. settling tank required). NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal min. settling tank required). Houses RetroFAST 0.25 and 0.375 as Alternative Drainfield Repair. Can house HS 1.0 with 500 pretreatment tank.										
13-045-23S-C3	C3	4.00	51.00	70	104		1200		8/19/2009	
REMARKS: H10 traffic rating. Also houses RTF 0.25, RTF 0.375 as Alternative Drainfield Repair. Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (450 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required); NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal. settling tank required); MicroFAST 0.9 (689 to 1088 gal min. settling tank required). Can house HS 1.0 with 500 gallon pretreatment tank.										
13-045-24S-C3	C3	4.00	51.00	73	122		1500		8/19/2009	
REMARKS: H10 traffic rating. Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (450 gal min. settling tank required) MicroFAST 1.5 (713 gal. min settling tank required); NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gallon settling tank required); MicroFAST 0.9 (689 to 1088 gal min. settling tank required). Can house HS 1.0.										
13-045-31S-C4	C4	6.00	51.00	66	96	2.5	900	B, GI	9/22/2009	
REMARKS: HS20 traffic rating. Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); NSF 245 units: MicroFAST 0.5, (475 to 750 gal. settling tank required); RetroFAST 0.25 and 0.375 as Alternative Drainfield Repair.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Rick's Pre Fab

8450 SW 43 Terrace
Miami FL 33155

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)			
13-045-32S-C4	C4	6.00	51.00	66	110	2.5	1050	B, GI	9/22/2009		
REMARKS: HS20 traffic rating. Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required); NSF 245-certified units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal. settling tank required). Houses HS 1.0 with 500 gallon min. pretreatment tank. Houses RetroFAST 0.25 and 0.375 as Alternative Drainfield Repair.											
13-045-33S-C4	C4	6.00	51.00	74	108	2.5	1200	B, GI	9/22/2009		
REMARKS: HS20 traffic rating. Also houses RetroFAST 0.25, 0.375 as Alternative Drainfield Repair. Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required). NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal. settling tank required); MicroFAST 0.9 (689 to 1088 gal min. settling tank required).											
13-045-34S-C4	C4	6.00	51.00	77	126	2.5	1500	B	9/22/2009		
REMARKS: HS20 traffic rating. Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required); NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal. settling tank required); MicroFAST 0.9 (689 to 1088 gal. settling tank required). Can house HS 1.0.											
13-045-BM1-C3	C3	3.00	51.00	60	104	2	1050	1,260 ATU	9/15/2017		
REMARKS: Houses Bio-Microbics MicroFAST 0.5 ATU. NSF 40-certified.											
13-045-BM2-C3	C3	3.00	51.00	68	102	2	1200	1,460 ATU	9/15/2017		
REMARKS: This tank is a modification of 13-045-23DC3 approved 8/19/2009, with the 1st and 2nd compartments reversed. Used to house the Bio- Microbics MicroFAST 0.50 ATU (500 gpd), MicroFAST 0.625 ATU (625 gpd), and MicroFAST 0.75 ATU (750 gpd) in shortened leg installation (NSF 40 certified configurations only). Used to house the Bio-Microbics RetroFAST 0.25 and RetroFAST 0.375 as an Alternative Repair Method. Comments updated 1/10/22.											
13-045-BM4-C3	C3	4.00	51.00	70	104	2	1200	1,449 ATU	8/11/2020		
REMARKS: This tank is a modification of 13-045-23DC3 approved 8/19/2009, with the 1st and 2nd compartments reversed. Used to house the Bio- Microbics MicroFAST 0.50 ATU (500 gpd), MicroFAST 0.625 ATU (625 gpd), and MicroFAST 0.75 ATU (750 gpd) in shortened leg installation (NSF 40 certified configurations only). Used to house the Bio-Microbics RetroFAST 0.25 and RetroFAST 0.375 as an Alternative Repair Method. Comments updated 1/10/22. H10 traffic rating.											
13-045-H6P-C4	C4	3.00	52.00	74.5	160		2060	2,440 ATU	12/20/2024		
REMARKS: Houses either the Hoot 500 or 600 gpd dosed ATU system (H-500 AND, H-600 AND), needs recirculation for nitrogen-reducing PBTS configuration. With DEP Lid #232 (for chlorinator/dechlorinator; 3 inches thick, tank remains C4) Lid #233 (for chlorinator/dechlorinator; 8 inches thick, H20 traffic, tank remains C4).											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Roth Global Plastics, Inc.

P.O. Box 11166
Syracuse, NY 13218

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
70-142-05S-C4	C4	0.25	40.00	62	60	3	500	525	7/1/2008	
REMARKS: Polyethylene tank- Pump tank volume = 525 gallons; laundry interceptor tank volume = 452 gallons. Roth Model RMT-500. Updated drawing reviewed 8/27/2019. Approved for use to house the Aero-Stream Eco-Nest NSF 40 certified ATUs: two tank models AS450-2 and AS500-2 with the first tank used for pretreatment and the second tank for aerobic treatment; three tank models AS450-3 and AS500-3 with the first tank used for pretreatment, the second tank for aerobic treatment and the third tank for tertiary treatment/settling. Updated 7/15/2024.										
70-142-08S-C4	C4	0.25	42.00	62	103	2	750	1,007	7/1/2008	
REMARKS: Polyethylene tank. Roth Model RMT-750. Use of side inlet/outlet ports not allowed. One stiffening post allowed. Updated drawing reviewed 4/21/2022. Approved for use to house the Aero-Stream Eco-Nest NSF 40 certified ATUs: two tank models AS750-2 and AS1000-2 with the first tank used for pretreatment and the second tank for aerobic treatment; three tank models AS750-3 and AS1000-3 with the first tank used for pretreatment, the second tank for aerobic treatment and the third tank for tertiary treatment/settling. Updated 7/15/2024.										
70-142-09S-C4	C4	0.25	42.00	62	118	2	900	1,147	7/1/2008	
REMARKS: Polyethylene tank. Roth Model RMT-1000E. Use of side inlet/outlet ports not allowed. Two stiffening posts allowed. Updated drawing reviewed 4/21/2022. Approved for use to house the Aero-Stream Eco-Nest NSF 40 certified ATUs: two tank models AS750-2 and AS1000-2 with the first tank used for pretreatment and the second tank for aerobic treatment; three tank models AS750-3 and AS1000-3 with the first tank used for pretreatment, the second tank for aerobic treatment and the third tank for tertiary treatment/settling. Updated 7/15/2024.										
70-142-10S-C4	C4	0.25	42.00	62	133	2	1060	1,337	7/1/2008	
REMARKS: Polyethylene tank. Roth Model RMT-1060. Use of side inlet/outlet ports not allowed. Two stiffening posts allowed. Updated drawing reviewed 4/21/2022. Approved for use to house the Aero-Stream Eco-Nest NSF 40 certified ATUs: two tank model AS1000-2 with the first tank used for pretreatment and the second tank for aerobic treatment; three tank model AS1000-3 with the first tank used for pretreatment, the second tank for aerobic treatment and the third tank for tertiary treatment/settling. Updated 7/15/2024.										
70-142-12S-C4	C4	0.25	42.00	62	148	2	1250	1,464	7/1/2008	
REMARKS: Polyethylene tank. Roth Model RMT-1250. Use of side inlet/outlet ports not allowed. Two stiffening posts allowed. Updated drawing reviewed 4/21/2022. Approved for use to house the Aero-Stream Eco-Nest NSF 40 certified ATUs: two tank model AS1000-2 with the first tank used for pretreatment and the second tank for aerobic treatment; three tank model AS1000-3 with the first tank used for pretreatment, the second tank for aerobic treatment and the third tank for tertiary treatment/settling. Updated 7/15/2024.										
70-142-15S-C4	C4	0.25	42.00	62	177	2	1500	1,771	7/1/2008	
REMARKS: Polyethylene tank. Roth Model RMT-1500. Use of side inlet/outlet ports not allowed. Two stiffening posts allowed. Updated drawing reviewed 4/21/2022. Approved for use to house the Aero-Stream Eco-Nest NSF 40 certified ATUs: two tank model AS1500-2 with the first tank used for pretreatment and the second tank for aerobic treatment; three tank model AS1500-3 with the first tank used for pretreatment, the second tank for aerobic treatment and the third tank for tertiary treatment/settling. Updated 7/15/2024.										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

Sauer Septic

21020 Obrien Road
Groveland FL 34736

Lake

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL		
				WIDTH	LENGTH			GALLONS (Pump Tanks)	USE	DATE	FAMILY
35-028-AK6S-C4	C4	3.00	50.50	50	139.5	2	1075	1,365	ATU	4/19/2024	

REMARKS: Concrete three-compartment tank. Houses AquaKlear AK6S245C ATU (600 gal/day), NSF245-certified. Two notches for 1/2" airline on inlet end of tank. Approved for use with lid 237.



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 3/31/2026

Searching for: ATU

SB Engineering, Inc.

430 Flagami Blvd
Miami FL 33144

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)		
13-160-NW1-C3	C3	2.50	54.00	66	111	3	1300	1,612 ATU	7/30/2020	
REMARKS: Houses the Norweco Singlair Model 960-500 & TNT-500 ATU. Both are NSF-40 certified for 500 gpd and 600 gpd. TNT-500 is NSF 245-certified for 500 gpd and 600 gpd. *Mid-seam watertightness test after field installation required per 62-6.013(10)(d) F.A.C. Also houses the first three compartments of the Norweco Singlair R3-500 with the Norweco Green HKBFR tank (70-150-NW2-C3) following it (May 8, 2023).										
13-160-NW2-C3	C3	2.50	66.00	66	111	3	1600	1,910 ATU	7/30/2020	
REMARKS: Houses the Norweco Singlair Model 960-750 & TNT-750 ATU. Both are NSF-40 certified for 750 gpd and 800 gpd. TNT-750 is NSF 245-certified for 750 gpd and 800 gpd *Mid-seam water-tightness test after field installation required per 64E-6.013(10)(d) F.A.C.										
13-160-NW3-C3	C3	2.50	54.00	66	111	-4	1300	1,610 ATU	7/30/2020	
REMARKS: Houses the Norweco Singlair Model 960-1000 & TNT-1000 ATU. Both are NSF-40 certified for 1000 gpd. TNT-1000 is NSF 245-certified for 1000 gpd. *Mid-seam water-tightness test after field installation required per 64E-6.013(10)(d) F.A.C. The inlet invert is 4 inches lower than the outlet invert for this tank * Pretreatment chamber min requirements: 1000 gal capacity, 15 gal per inch of liquid level and 12 inches of freeboard. The pretreatment tank must be installed so that the outlet invert of the pretreatment tank is aligned vertically and horizontally to the inlet invert of the treatment tank. The pretreatment tank outlet invert and the treatment tank inlet invert are both 5 inches below the water level.										
13-160-NW3P-C4	C4	4.00	49.00	70	99	8	1050	1,356 ATU	12/4/2020	2
REMARKS: Pretreatment tank for 13-160-NW3-C3 tank that houses the Norweco Singlair Model 960-1000 & TNT-1000 ATU. The outlet invert is 8 inches lower than the inlet invert for this tank and 5 inches lower than the liquid level. The installation must achieve a liquid level of 49", which can only be checked when connected to the 13-160-NW3-C3 tank. Drops for level tanks relative to inlet NW3P: outlet NW3P = 8, inlet NW3 = 8, outlet NW3 = 4 inches. Approved Lids: 192, 193, 194										
13-160-NW4-C3	C3	2.50	66.00	66	111	-4	1600	1,908 ATU	7/30/2020	
REMARKS: Houses the Norweco Singlair Model 960-1250 & TNT-1250 ATU. Both are NSF-40 certified for 1250 gpd. TNT-1250 is NSF 245-certified for 1250 gpd. *Mid-seam water-tightness test after field installation required per 64E-6.013(10)(d) F.A.C. The inlet invert is 4 inches lower than the outlet invert for this tank * Pretreatment chamber min requirements: 1250 gal capacity, 16 gal per inch of liquid level and 12 inches of freeboard. The pretreatment tank must be installed so that the outlet invert of the pretreatment tank is aligned vertically and horizontally to the inlet invert of the treatment tank. The pretreatment tank outlet invert and the treatment tank inlet invert are both 5 inches below the water level.										
13-160-NW4P-C3	C3	3.00	40.00	66	140	8	1250	1,669 ATU	12/4/2020	1
REMARKS: Pretreatment tank for 13-160-NW4-C3 tank that houses the Norweco Singlair Model 960-1250 & TNT-1250 ATU. The outlet invert is 8 inches lower than the inlet invert for this tank and 5 inches lower than the liquid level. The installation must achieve a liquid level of 40", which can only be checked when connected to the 13-160-NW4-C3 tank. Drops for level tanks relative to inlet NW3P: outlet NW4P = 8, inlet NW3 = 8, outlet NW3 = 4 inches. Approved Lids: 195, 196, 197										
13-160-NW5-C3	C3	2.50	78.00	66	111	-4	1900	2,208 ATU	7/30/2020	
REMARKS: Houses the Norweco Singlair Model 960-1500 & TNT-1500 ATU. Both are NSF-40 certified for 1500 gpd. TNT-1500 is NSF 245-certified for 1500 gpd. *Mid-seam water-tightness test after field installation required per 64E-6.013(10)(d) F.A.C. The inlet invert is 4 inches lower than the outlet invert for this tank * Pretreatment chamber min requirements: 1500 gal capacity, 22 gal per inch of liquid level and 12 inches of freeboard. The pretreatment tank must be installed so that the outlet invert of the pretreatment tank is aligned vertically and horizontally to the inlet invert of the treatment tank. The pretreatment tank outlet invert and the treatment tank inlet invert are both 5 inches below the water level.										
13-160-NW5P-C4	C4	4.00	49.00	70	148	8	1650	2,090 ATU	12/4/2020	2
REMARKS: Pretreatment tank for 13-160-NW5-C3 tank that houses the Norweco Singlair Model 960-1500 & TNT-1500 ATU. The outlet invert is 8 inches lower than the inlet invert for this tank and 5 inches lower than the liquid level. The installation must achieve a liquid level of 49", which can only be checked when connected to the 13-160-NW5-C3 tank. Drops for level tanks relative to inlet NW5P: outlet NW3P = 8, inlet NW3 = 8, outlet NW5 = 4 inches. Approved Lids: 201, 202, 203										