



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010017

System Type: Community

PWS Name: ALACHUA WTP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	6 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at 11808 NW 74 Terrace for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	8220
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	9

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010041

System Type: Community

PWS Name: ARREDONDO ESTATES

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at 6915 SW 55 th Place for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Biannually	Jan-Jun 2020	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	738
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010042

System Type: Community

PWS Name: PALMS OF ARCHER

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at Lot 2607 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1092
Monitoring Frequency	Monthly
Raw Sampling	4-log: Raw not required, recommend quarterly
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010199

System Type: Community

PWS Name: ARCHER WATER SYSTEM

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2020 at Fire Hydrant (11582 SW 168 th Drive) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit **Asbestos Free Certification** and **SOC Waiver Requests** (*waivers only available for 2nd set for systems with population over 3,300*) by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1440
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010201

System Type: Community

PWS Name: HIGH SPRINGS WTP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2020	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		L1- City Hall (110 NW 1st Ave) November 2020 for TTHMs and HAA5s L2- Boat Ramp (25083 NW210th Lane) May 2020 for TTHMs and HAA5s
		Lead and Copper (tap samples)	Annually	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit **Asbestos Free Certification** and **SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	5795
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	7

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010207

System Type: Community

PWS Name: NEWBERRY WTP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at SW 242 Terrace, LS 21 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	3885
Monitoring Frequency	Monthly
Raw Sampling	4-log: Raw not required, recommend quarterly
Distribution Sampling	4

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010212
PWS Name: WALDO WTP

System Type: Community

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at 15185 NW Waldo Road for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1042
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010410

System Type: Non-Transient Non-Community

PWS Name: PHOENIX COMMERCIAL PARK

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are not available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2020 at Baghouse A / Press Plate for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	30
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010477

System Type: Community

PWS Name: HAWTHORNE WTP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021 - Both plants	
		Secondary Contaminants	Triennially	2021- Both plants	
		Volatile Organics (VOCs)- Full Set	Triennially	2021- Both plants	
		Total Xylenes	Annually	2020 - (Apr-Jun) from WTP 2-Blue Tower	
		Radionuclides	6 years 9 years	2021- WTP 2 Blue Tower 2024- WTP 3- Railroad	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 <i>waivers are not available during 2021 and 2022</i>)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2020 at Hosebib @ Rec Facility for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	2275
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010612

System Type: Community

PWS Name: GATOR WATERWORKS WATER SYSTEM

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at 3088 SE 18 Ave for HAA5s only and 2226 SE 45 Terrace for TTHMs only **	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	800
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010625

System Type: Community

PWS Name: LAKE ALTO ESTATES MHP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 <i>waivers are not available during 2021 and 2022</i>)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2021 at 18104 NE 143 Ave (House) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	325
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010749

System Type: Community

PWS Name: MICANOPY WATER SYSTEM

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	2nd Month / 2nd Week Quarterly at SW 1st & Church Street for TTHMs and HAA5s and Fire Hydrant@ 108 NE Evans Court for TTHMs and HAA5s***	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit **Asbestos Free Certification** and **SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	605
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2010946

System Type: Community

PWS Name: GRU - MURPHREE WTP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 <i>waivers are not available during 2021 and 2022</i>)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	First Month / Third Week quarterly at Sample locations: L1, L3-L7 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 50
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	190600
Monitoring Frequency	Monthly
Raw Sampling	4-log: Raw not required, recommend quarterly
Distribution Sampling	120

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2011006

System Type: Community

PWS Name: SANTA FE HILLS SUBDIVISION

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2021 at 16731 NW 173 Terrace for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	200
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2011251

System Type: Community

PWS Name: WESTGATE MANOR MHP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	Triennially	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 <i>waivers are not available during 2021 and 2022</i>)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2021 at Last Trailer for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit ***Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)*** by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	300
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014164

System Type: Non-Transient Non-Community

PWS Name: UF-CENTER FOR AQUATIC WEEDS

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are not available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2022 at Hand Sink, Room 109 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests* (waivers only available for 2nd set for systems with population over 3,300) by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	250
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014167

System Type: Non-Transient Non-Community

PWS Name: GREENFIELD PRESCHOOL

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are not available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at Bathroom Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	68
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014196

System Type: Community

PWS Name: CROSS CREEK MHP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		VOCs Total Xylene	Annually	<i>Third Quarter 2020 3 years BDL required</i>	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 <i>waivers are not available during 2021 and 2022</i>)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2021 at Cross Creek Lift Station for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	156
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014203

System Type: Non-Transient Non-Community

PWS Name: ALACHUA LEARNING CENTER

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at Outside Hosebibb off Classroom for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Free Certification* and *SOC Waiver Requests* (waivers only available for 2nd set for systems with population over 3,300) by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	162
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014209

System Type: Non-Transient Non-Community

PWS Name: CHRISTIAN LIFE WORLD ACADEMY

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at Ladies Restroom Sink for TTHMs and HAA5s** (2019 TTHM > 75% MCL)	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring

and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	45
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014214

System Type: Non-Transient Non-Community

PWS Name: USGS-WETLAND & AQUATIC RESEARCH CENTER

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are not available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2020 at Room 56 (for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014215

System Type: Non-Transient Non-Community

PWS Name: WINDSOR BAPTIST CHURCH & ACADEMY

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are not available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at Annex Kitchen Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	50
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014218

System Type: Non-Transient Non-Community

PWS Name: ISKCON OF ALACHUA COUNTY INC

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are not available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at Sink on East Side of Temple for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014223

System Type: Non-Transient Non-Community

PWS Name: DEERHAVEN RENEWABLE

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	September 2022 at Scalehouse Bldg Sink (1st floor bathroom) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	45
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014226

System Type: Non-Transient Non-Community

PWS Name: LHS 360 INNOVATION CAMPUS

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	4th Quarter 2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Quarterly	2020	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are not available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at Office Restroom Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Annually	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests* (waivers only available for 2nd set for systems with population over 3,300) by **October 31st** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	80
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2014229

System Type: Non-Transient Non-Community

PWS Name: GAINESVILLE AREA ROWING WTP

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Annually	2020-2022	
		Radionuclides: Gross Alpha	Quarterly	2020	
		Radionuclides: Combined Uranium	9 years	2028	
		Radionuclides: Combined Radium (Rad 226+228)	N/A	Waived- 4 Quarters BDL	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at Restroom #4 Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. Form submittal does not automatically waive

sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	30
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Reports can be submitted to DEP_NED@dep.state.fl.us.
-