



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030050

System Type: Community

PWS Name: BAY COUNTY WATER SYSTEM

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Annually	2021	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Annually	2021	
		Radionuclides	9 years	2029	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Monthly samples collected in 2021 at WMXB - MEXICO BEACH MASTER METER RW21 - 2521 PALO ALTO AVE W17 - 17TH ST AT MLK BLVD, NW SIDE OF INTERSECTION NB13 - 6340 GRASSY POINT RD for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30
--	--	-------------------------------	-------------	---------------	--

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030141

System Type: Community

PWS Name: CALLAWAY CITY OF WATER SYSTEM

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	First week of January, April, July, and October 2021 at HERITAGE WOODS LIFTSTATION 20 JAMES ST 4TH ST LIFT STATION 31 HWY 2297 LIFT STATION 36 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.

- Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030148

System Type: Community

PWS Name: SPRINGFIELD CITY OF

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	1 st week of March, June, September, and December 2021 at 117 HARLEM 2723 ARDEN AVE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.

- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030371

System Type: NTNC

PWS Name: WESTROCK CP LLC - PANAMA CITY MILL

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Radionuclides	****	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially Must also sample for Dioxin	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2021 at CAUSTIC PLANT for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* (waivers only available for 2nd set for systems with population over 3,300) by **October 31st** to allow time for Department review. SOC form submittal does not

automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030435

System Type: Community

PWS Name: LYNN HAVEN CITY OF WATER SYS.

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Secondary - Iron	Quarterly - WP2	2021	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	9 years	2029	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially 2 nd set	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	2 nd week of February, May, August, and November 2021 at 109 CASHEL MARA 3203 AZALEA CIRCLE 1300 RHODE ISLAND 3431 CHERRY RIDGE for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30
--	--	-------------------------------	-------------	---------------	--

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030467

System Type: Community

PWS Name: MEXICO BEACH CITY OF

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	<u>SAMPLING PLAN REQUIRES UPDATING. CONTACT LEXIE WOODSON IMMEDIATELY**</u>	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos-Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.

- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030515

System Type: Community

PWS Name: PANAMA CITY BEACH CITY OF

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly		Monthly samples collected in 2021 at 5226 FINISTERE DR - SS264 112 GOLF DR - SS272 2225 THOMAS DR - SS141 9230 WIDENER ST - SS160 HERON TURN - SS266 12561 EMERALD LAKE DR - SS111 314 PIRATES COVE - SS76 17120 PCB PKWY - SS23 for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 30

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030517

System Type: Community

PWS Name: PANAMA CITY WATER SYSTEM

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	February 10 th , May 11 th , August 10 th , and November 9 th 2021 at JOHN PITTS & AMBER WAY (SITE 142) COLLEGIATE DR & N BAY DR (SITE 3) 8TH ST & PREMIER DR (SITE 17) GRAY AVE & 1ST PLAZA (SITE 29) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Biannually	Jan-Jun and Jul-Dec 2021	Sample at pre-approved sample plan sites; Number of sites required: 60

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.

- Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030520

System Type: Community

PWS Name: PARKER CITY OF WATER SYSTEM

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	2 nd week of February, May, August, and November 2021 at 5307 SOULE DR 4617 HYACINTH ST for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.

- Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030568

System Type: Community

PWS Name: CREEKSIDE ESTATES PC, LLC WATER SYSTEM

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	6 years Gross Alpha	2024	
			3 years Rad 226 & 228	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 <i>waivers are <u>not available during 2021 and 2022</u></i>)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2021 at 1403 29TH CT for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Biannually	Jan-Jun and Jul-Dec 2021	Sample at pre-approved sample plan sites; Number of sites required: 5
--	--	-------------------------------	------------	--------------------------	---

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030716

System Type: NTNC

PWS Name: WALLER ELEMENTARY SCHOOL

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	September 2021 at BUILDING 4 ROOM 104 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 10

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030774

System Type: NTNC

PWS Name: FLORIDA POWER AND LIGHT LANSING-SMITH PLANT

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Radionuclides	Wells 4 & 6	2024	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	July 2022 at UNIT 3 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests* (*waivers only available for 2nd set for systems with population over 3,300*) by **October 31st** to allow time for Department review. SOC form submittal does not

automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1030788

System Type: NTNC

PWS Name: AFRL AREA (TYNDALL AFB)

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at BUILDING 9720 LEFT RESTROOM for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034054

System Type: Community

PWS Name: DEER HAVEN PARK

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)* ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		August 2021 at LOT #23 for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)*** by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034106

System Type: NTNC

PWS Name: STACEY'S SWINGERS DAY CARE

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at AFTER SCHOOL BUILDING SINK #1 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034109

System Type: NTNC

PWS Name: FULL SCALE DRONE (TYNDALL AFB)

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2021 at BUILDING 9310 (OUTSIDE SPIGOT) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not

automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034141

System Type: NTNC

PWS Name: US FISH & WILDLIFE SERVICE

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <i>not</i> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	November 2022 at REAR SPIGOT MAINTENANCE YARD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Annually	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1034168

System Type: NTNC

PWS Name: PRECIOUS MEMORIES NO. 2

2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2022	
		Secondary Contaminants	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	
		Radionuclides	6 years Gross Alpha including Uranium	2025	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2) *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2022 at BACK ROOM SINK for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5

*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300)* by **October 31st** to allow time for Department review. SOC form submittal does not automatically waive sampling, which will be required if the request is not approved.

***Note on DBPs*: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

Important Reminders:

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click [here](#) for a contact list of Department personnel.



Northwest District Drinking Water Program Contacts

General #:(850) 595-8300

Fax #:(850) 595-8392

~Section Supervisor	Dana Vestal
	(850) 595-0659
	Dana.Vestal@FloridaDEP.gov
~Compliance/Enforcement	Angelia Butler
	(850) 595-0598
	Angelia.Butler@FloridaDEP.gov
~Stage 2 Disinfection Byproducts (DBP) Compliance ~Disinfectant Residual Reports	Lexie Woodson
	(850) 595-0640
	Alexandria.Woodson@FloridaDEP.gov
~Chemical Compliance (Nitrates/Nitrites, Inorganics, SOC, VOC, Asbestos, Secondaries, Rads)	Paula Smith
	(850) 595-0632
	Paula.Smith@FloridaDEP.gov
~Consumer Confidence Reports (CCR)	Mary Jehle
	(850) 595-0676
	Mary.Jehle@FloridaDEP.gov
~Lead and Copper Rule (LCR) Tap Monitoring ~Capacity Development (CD)	Nicole Hetzel
	(850) 595-0660
	Nicole.Hetzel@FloridaDEP.gov
~Boil Water Notices (BWNs) ~Monthly Operation Reports (MORs)	Steve Hafner
	(850) 595-0689
	Steve.Hafner@FloridaDEP.gov
	Email BWN info and clearance bacti-s to: NWDPWS@FloridaDEP.gov
	Email MORs to: DWRM_Data_Entry_Tal@dep.state.fl.us
~Bacteriological Compliance (Routine Bact. Sampling, Well & Tank Clearances, Revised Total Coliform & Ground Water Rules)	Ben Russell
	(850) 595-0678
	Ben.Russell@FloridaDEP.gov
~Cross-Connection Control (C3) Annual Reports	Email bact. compliance results to: NWDPWS@FloridaDEP.gov
	Email C3 reports to: NWDPWS@FloridaDEP.gov
~General Permits ~Permit Clearances	Katie Ates
	(850) 595-0656
	Katie.L.Ates@FloridaDEP.gov
Branch Office Environmental Administrator	Michael Fuller
	(850) 767-0040
	Michael.Fuller@FloridaDEP.gov

Panama City Branch Office Inspectors	Loran Jordan
	(850) 767-0044
	Loran.Jordan@FloridaDEP.gov
	Larry Couch
Tallahassee Branch Office Inspectors	(850) 767-0047
	Larry.Couch@FloridaDEP.gov
	Tracy White
	(850) 245-7628
Tallahassee Branch Office Inspectors	Tracy.A.White@FloridaDEP.gov
	Kevin Grace
	(850) 245-7629
	Kevin.T.Grace@FloridaDEP.gov