



Florida Department of Environmental Protection Northeast District

PWS ID: 2150243
PWS Name: CROSS CITY WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

| Chemical Monitoring | | | | | |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled | Date Sampled | Contaminant | Frequency | Next Due | Location & Comments |
| | | Nitrate & Nitrite | Annually | 2018 | Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance) |
| | | Primary Inorganics | Triennially | 2018 | |
| | | Secondary Contaminants | Triennially | 2018 | |
| | | Volatile Organics (VOCs) | Triennially | 2018 | |
| | | Radionuclides | 9 years | 2018 | |
| | | Asbestos | Every 9 years | 2021 | Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan* |
| | | Synthetic Organics (SOCs) – FULL SET | Triennially | 2018 | Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)* |
| | | Dalapon | Annually | Jul-Sep 2018 | |
| | | Stage 2 Disinfection Byproducts (S2 DBPs) | Annually | Jul-Sep 2018 at 74 NE 234 AVE for TTHMs and HAA5s** Jul-Sep 2018 at ELEM SCHOOL for TTHMs and HAA5s** | |
| | | Lead and Copper (tap samples) | Triennially | Jun-Sept 2018 | Sample at pre-approved sample plan sites |
| | | Water Quality Parameters (WQPs) | Every 2 weeks | | Sample at <u>each</u> Point of Entry to the distribution |

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

| Bacteriological Monitoring | |
|-----------------------------------|-------------------------------|
| Current Population on Record | 2850 |
| Monitoring Frequency | Monthly |
| Raw Sampling | 1 Raw (pretreatment) per well |
| Distribution Sampling | 3 |

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2150512

System Type: Community

PWS Name: HORSESHOE BEACH WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

| Chemical Monitoring | | | | | |
|---------------------|--------------|---|---------------|---|---|
| Date Scheduled | Date Sampled | Contaminant | Frequency | Next Due | Location & Comments |
| | | Nitrate & Nitrite | Annually | 2018 | Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance) |
| | | Primary Inorganics | Triennially | 2018 | |
| | | Secondary Contaminants | Triennially | 2018 | |
| | | Volatile Organics (VOCs) | Triennially | 2018 | |
| | | Radionuclides | 9 years | 2018 | |
| | | Asbestos | Every 9 years | 2021 | Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan* |
| | | Synthetic Organics (SOCs) | Triennially | 2018 | Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)* |
| | | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially | Jul-Sep 2018 at COUNTY PARK for TTHMs and HAA5s** | |
| | | Lead and Copper (tap samples) | Triennially | Jun-Sept 2020 | Sample at pre-approved sample plan sites |

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

| Bacteriological Monitoring | |
|-----------------------------------|-------------------------------|
| Current Population on Record | 313 |
| Monitoring Frequency | Monthly |
| Raw Sampling | 1 Raw (pretreatment) per well |
| Distribution Sampling | 1 |

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2150840
PWS Name: OLD TOWN SCHOOL

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

| Chemical Monitoring | | | | | |
|---------------------|--------------|---|---------------|---|---|
| Date Scheduled | Date Sampled | Contaminant | Frequency | Next Due | Location & Comments |
| | | Nitrate & Nitrite | Annually | 2018 | Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance) |
| | | Primary Inorganics | Triennially | 2019 | |
| | | Secondary Contaminants | Triennially | 2019 | |
| | | Volatile Organics (VOCs) | Triennially | 2019 | |
| | | Asbestos | Every 9 years | 2022 | Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan* |
| | | Synthetic Organics (SOCs) | Triennially | 2019 | Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)* |
| | | Stage 2 Disinfection Byproducts (S2 DBPs) | Annually | Jul-Sep 2018 at HAND SINK KITCHEN, BLDG 7 for TTHMs and HAA5s** Jul-Sep 2018 at BLDG. 10, OTEC for TTHMs and HAA5s** | |
| | | Lead and Copper (tap samples) | Triennially | Jun-Sept 2020 | Sample at pre-approved sample plan sites |
| | | Water Quality Parameters (WQPs) | Every 2 weeks | | Sample at <u>each</u> Point of Entry to the distribution |

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

| Bacteriological Monitoring | |
|-----------------------------------|-------------------------------|
| Current Population on Record | 595 |
| Monitoring Frequency | Quarterly |
| Raw Sampling | 1 Raw (pretreatment) per well |
| Distribution Sampling | 1 |

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2151026

System Type: Community

PWS Name: SHADY OAKS RV AND MHP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

| Chemical Monitoring | | | | | |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled | Date Sampled | Contaminant | Frequency | Next Due | Location & Comments |
| | | Nitrate & Nitrite | Annually | 2018 | Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance) |
| | | Primary Inorganics | Triennially | 2018 | |
| | | Secondary Contaminants | Triennially | 2018 | |
| | | Volatile Organics (VOCs) | Triennially | 2018 | |
| | | Radionuclides – Gross Alpha Including Uranium | 6 years | 2021 | |
| | | Radionuclides – Radium 226 & Radium 228 | Quarterly | 2018 | |
| | | Asbestos | Every 9 years | 2021 | Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan* |
| | | Synthetic Organics (SOCs) | Triennially | 2018 | Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)* |
| | | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially | Jul-Sep 2018 at LOT 97 for TTHMs and HAA5s** | |
| | | Lead and Copper (tap samples) | Triennially | Jun-Sept 2020 | Sample at pre-approved sample plan sites |

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

| Bacteriological Monitoring | |
|-----------------------------------|-------------------------------|
| Current Population on Record | 75 |
| Monitoring Frequency | Monthly |
| Raw Sampling | 1 Raw (pretreatment) per well |
| Distribution Sampling | 1 |

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2151140

System Type: Community

PWS Name: SUWANNEE WATER & SEWER DISTRICT

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

| Chemical Monitoring | | | | | |
|---------------------|--------------|---|---------------|---|---|
| Date Scheduled | Date Sampled | Contaminant | Frequency | Next Due | Location & Comments |
| | | Nitrate & Nitrite | Annually | 2018 | Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance) |
| | | Primary Inorganics | Triennially | 2018 | |
| | | Secondary Contaminants | Triennially | 2018 | |
| | | Volatile Organics (VOCs) | Triennially | 2018 | |
| | | Radionuclides | 9 years | 2018 | |
| | | Asbestos | Every 9 years | 2021 | Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan* |
| | | Synthetic Organics (SOCs) | Triennially | 2018 | Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)* |
| | | Stage 2 Disinfection Byproducts (S2 DBPs) | Annually | Jul-Sep 2018 at Barbary Circle for TTHMs and HAA5s** Jul-Sep 2018 at Colbert St. & CR349 for TTHMs and HAA5s** | |
| | | Lead and Copper (tap samples) | Triennially | Jun-Sept 2019 | Sample at pre-approved sample plan sites |

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

| Bacteriological Monitoring | |
|-----------------------------------|-------------------------------|
| Current Population on Record | 2090 |
| Monitoring Frequency | Monthly |
| Raw Sampling | 1 Raw (pretreatment) per well |
| Distribution Sampling | 2 |

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do **not** rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.