



Florida Department of Environmental Protection Northeast District

PWS ID: 2160046
PWS Name: BAE SYSTEMS SE SHIPYARDS JAX LLC

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Oct-Dec 2018 at Navy Support Building for TTHMs & HAA5s	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1000
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160053
PWS Name: BALDWIN WATER SYSTEM

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at Hydrant @Limann Rd (1095 US Why 90 W for TTHMs and HAA5s)	
		Lead and Copper (tap samples)	Annually	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1790
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160110
PWS Name: SUNNY PINES

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	Triennially	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Polychlorinated Biphenyl (SOC)	Annually	3 rd Q 2018	Sample at each Point of Entry to the distribution
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Lot 11 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	80
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160174
PWS Name: BACARDI BOTTLING CORPORATION

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Tap in the Back of the Administration Bldg for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	226
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160190

System Type: Non-Transient Non-Community

PWS Name: CREATIVE CHILDREN'S ACADEMY INC.

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Bathroom D sink 2 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	90
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160200

System Type: Community

PWS Name: ATLANTIC BEACH WATER SYSTEM

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	At 1735 Beach Ave for TTHMs and HAA5s At 133 Beach Ave for TTHMs and HAA5s At 1035 East Coast Drive for TTHMs and HAA5s At 2765 State Rd. A1A for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	23503
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	25

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160206
PWS Name: NEPTUNE BEACH

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at 1515 Florida Blvd for TTHMs only** Oct-Dec 2018 at 1515 Florida Blvd for HAA5s only** Apr-Jun 2018 at 2032 Mary Brant Loop for TTHMs only** Jul-Sep 2018 at 2032 Mary Brant Loop for HAA5s only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	7270
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	8

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160254
PWS Name: DANIEL MEMORIAL

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	Triennially	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Spigot Creekside Bldg for TTHMs and HAA5s **	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160375

System Type: Non-Transient Non-Community

PWS Name: GERDAU AMERISTEEL US INCORPORATED

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Men's Room Mill Services for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	300
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160390
PWS Name: CRYSTAL SPRINGS ESTATES MHP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Lot 168 for TTHMs and HAA5s	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	350
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160563

System Type: Community

PWS Name: JACKSONVILLE BEACH WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Radium 226 + 228 (Plant 2 only)	6 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	At 337 1 st Ave South for TTHMs and HAA5s** At 1954 10 th Street N for TTHMs and HAA5s** At 3760 3 rd Street S for TTHMs and HAA5s** At 1281 Laguna Villas for TTHMs and HAA5s** At 8 Hopson Road for TTHMs and HAA5s** At 612 Lower 8 th Ave for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	23279
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	25

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160568

System Type: Community

PWS Name: JACKSONVILLE UNIVERSITY

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Combined Uranium	6 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at Volleyball Court for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	3480
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	4

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160571

System Type: Non-Transient Non-Community

PWS Name: MONTGOMERY CORRECTIONAL CENTER

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at Spigot at Goat Pen for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	760
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160601

System Type: Community

PWS Name: YUKON INDUSTRIES LTD.

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	Triennially	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 6382 Yukon Rd for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	43
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160654

System Type: Community

PWS Name: STUDY ESTATES MHP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Lot 27 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160734
PWS Name: N.S. MAYPORT

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2020	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	At 1460 Patrol Road for TTHMs and HAA5s** At 992 El Dorado Rd for TTHMs and HAA5s** At 2085 Sea Control Dr for TTHMs and HAA5s** At 413 Baltimore for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	20500
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	20

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160735
PWS Name: JEA: MAYPORT WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at 4200 Ocean Street for TTHMs and HAA5s** Jul-Sep 2018 at 4870 Ocean Street for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	251
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160811

System Type: Community

PWS Name: NORMANDY VILLAGE UTILITY CO.

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at 8091 Lourdes Drive S for TTHMs and HAA5s **	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	3373
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	4

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2160824
PWS Name: OCEANWAY OAKS LLC

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Annually	2018	
		Radionuclides	Triennially	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Lot 56 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	75
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2161043
PWS Name: NEW KINGS MHP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Lot 6096 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	25
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2161212
PWS Name: N.A.S. JACKSONVILLE

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	At Bldg 118 Outside Spigot for TTHMs and HAA5s** At Bldg 985 for TTHMs and HAA5s** At 370 Swan for TTHMs and HAA5s** At Woodpecker Circle for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	22000
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	25

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2161276

System Type: Community

PWS Name: OAKS OF ATLANTIC BEACH

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at Spigot at Lot 233 for TTHMs and HAA5s** Jul-Sep 2018 at Office Bathroom for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	572
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2161328
PWS Name: JEA MAJOR GRID

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Dichloromethane	Annual @ Ridenour	1 st Q 2019	
		Radionuclides	Triennially	2020	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Di(2-ethylhexyl) phthalate	Annual	4 th Q 2018 @ Community Hall; 1 st Q 2019 @ Royal Lakes; 1 st Q 2019 @ Beacon Hills; 3 rd Q 2018 @ River Oaks Booster Station	Sample at the Point of Entry to the distribution
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	At 4728 Roanoke Blvd for TTHMs and HAA5s** At 238 Shamrock Ave for TTHMs and HAA5s** At 6505 Greenfern Lane for TTHMs and HAA5s** At 707 Mill Creek Rd for TTHMs and HAA5s** At 2624 Seneca Drive for TTHMs and HAA5s**	

				At 1908 Lyndhurst Drive for TTHMs and HAA5s** At 9170 Milton Drive for TTHMs and HAA5s** At 172 Wandering Woods Way for TTHMs and HAA5s**	
		Bromates	Monthly	2018	Sampled at Point of Entry at Main Street North, Arlington Booster Station, River Oaks Booster Station, and Greenland WTP
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs) pH only	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	739834
Monitoring Frequency	Monthly
Raw Sampling	1 Raw per raw confluence point
Distribution Sampling	240

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2161333

System Type: Community

PWS Name: BLAIR ROAD APARTMENTS

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at for 1553 Blair Road TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2161337

System Type: Community

PWS Name: BARCELONA APARTMENTS

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Apartment 8458 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	56
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164003

System Type: Community

PWS Name: SADDLE BROOK LANDINGS

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at Bldg 3042 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1000
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164182
PWS Name: HAPPY ACRES RANCH

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Barn Water Fountain for TTHMs and HAA5s **	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	140
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164200

System Type: Non-Transient Non-Community

PWS Name: INTERNATIONAL BALER CORP.

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Shop Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	70
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164241

System Type: Non-Transient Non-Community

PWS Name: SUNRISE DAY CARE CENTER

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Spigot Out Front for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	43
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164279

System Type: Community

PWS Name: NEIGHBORHOOD UTILITIES (TIMBER CREEK)

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Oct-Dec 2018 at Lot 38 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1015
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164331
PWS Name: JEA: ST JOHNS RIVER POWER PARK

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	At PWWW - 11201 New Berlin Road - WWTPF Control Room for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	270
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164348
PWS Name: BEVERLY HILLS DEVELOPMENT CENTER

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Lounge Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	115
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164352
PWS Name: MAXVILLE COMMUNITY CENTER

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Total Xylenes	Annual	4 th Q 2018	
		Radionuclides	Quarterly	2018	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at 1840 Penn Ave for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	275
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164398
PWS Name: WEST MEADOWS BAPTIST CHURCH

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Every 9 years	2025	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Church Men's RR for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	49
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164400
PWS Name: BELLE OAKS WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 10754 Scott Mill Road for TTHMs and HAA5s **	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164401

System Type: Community

PWS Name: THE TRANSITION HOUSE AT DINSMORE

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at STP Plant Tap for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	150
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164412
PWS Name: FIRST UNITED PENTECOSTAL CHURCH

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Spigot at Parsonage for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	300
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164438
PWS Name: JACKSONVILLE YOUTH ACADEMY

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Gross Alpha	Triennial	2018	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Oct-Dec 2018 at Maintenance Bldg Bathroom Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	65
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164494
PWS Name: BAILEY'S MHP (NORTH)

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Lot 3 Spigot for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Biannually	Jan-Jun 2018	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	75
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164497
PWS Name: HOPE CHAPEL

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Men's Room East Wall Bldg 3 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	438
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164522

System Type: Non-Transient Non-Community

PWS Name: TRAIL RIDGE LANDFILL

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Total Xylenes	Quarterly	1 st Q 2018	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Oct-Dec 2019 at Maintenance Bldg Spigot for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	40
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164524
PWS Name: WEST FRASER

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Admin's Men's Restroom for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	74
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164526

System Type: Non-Transient Non-Community

PWS Name: COUNTRY SCHOOL III

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Gross Alpha	Every 6 years	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Teacher's Lounge Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164602

System Type: Non-Transient Non-Community

PWS Name: METALPLATE GALVANIZING LP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Men's Breakroom Sink for TTHMs and HAA5s **	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	48
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164604

System Type: Non-Transient Non-Community

PWS Name: PABLO CREEK GOLF CLUB

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Club House Men's RR for TTHMs and HAA5s **	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	30
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164608
PWS Name: SUNESTA CANVAS PRODUCTS

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Breakroom Tap 3 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	40
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164617
PWS Name: OLD CASTLE PRECAST

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Office Kitchen Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	29
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164620
PWS Name: RIVER CITY FAMILY CHURCH

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Dalapon (SOC)	Annual	3 rd Q 2018	Sample at Point of Entry to the distribution
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at N Side Bldg Tap for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	100
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164626
PWS Name: SUNBELT RENTALS

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Picloram (SOC)	Annual	4 th Q 2019	Sample at Point of Entry to the distribution
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at 11004 Blasius Rd Service Bldg for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	29
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164636

System Type: Non-Transient Non-Community

PWS Name: GERDAU AMERISTEEL JAX SHREDDER

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at Supply Breakroom Kitchen for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	27
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164645

System Type: Non-Transient Non-Community

PWS Name: OLD PLANK ROAD BAPTIST CHURCH

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Dichloromethane (VOC)	Quarterly	2018	
		Radionuclides	Waiver	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Di(2-ethylhexyl) Phthalate	Quarterly	2018	Sample at <u>each</u> Point of Entry to the distribution.
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Building A School Receptionist Restroom for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	250
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2164655

System Type: Non-Transient Non-Community

PWS Name: DYNAREX WAREHOUSE WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Quarterly	2018	
		Radionuclides	Quarterly	2018	
		Asbestos	Every 9 years	2028	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Quarterly	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Mop Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Biannually	Jan-Jun 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	45
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.
-