

Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2180002 System Type: Community

PWS Name: BEVERLY BEACH WATER SYSTEM

### 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		455 N Oceashore Blvd and 79 Hawks r TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites	

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\*Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring			
Current Population on Record	1413		
Monitoring Frequency	Monthly		
Raw Sampling	1 Raw (pretreatment) per well		
Distribution Sampling	2		

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

#### Important Reminders:

> Failure to sample in accordance with rule requirements may result in enforcement action.

PWS Name: BEVERLY BEACH WATER SYSTEM

- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2180132 System Type: Community

PWS Name: BULOW PLANTATION

# 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments	
		Nitrate & Nitrite	Annually	2019		
		Primary Inorganics	Triennially	2021		
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will	
		Volatile Organics (VOCs)	Triennially	2021	not be accepted for compliance)	
		Radionuclides	9 years	2027		
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2019 at Ma	arina Cove for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites	

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**PWS Name: BULOW PLANTATION** 

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring				
Current Population on Record	1001			
Monitoring Frequency	Monthly			
Raw Sampling	1 Raw (pretreatment) per well			
Distribution Sampling	2			

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2180134 System Type: Community

PWS Name: BUNNELL WATER PLANT

### 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>
		Nitrate & Nitrite	Annually	2019	
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will
		Volatile Organics (VOCs)	Triennially	2021	not be accepted for compliance)
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at each Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*  9 at @ 355 Old Haw Creek Street for TTHMs and HAA5s**
		Dalapon (SOC)	Annually	2 <sup>nd</sup> Quarter 2019	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

<sup>\*</sup>Submit Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: BUNNELL WATER PLANT

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring				
Current Population on Record	2648			
Monitoring Frequency	Monthly			
Raw Sampling	1 Raw (pretreatment) per well			
Distribution Sampling	3			

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2180349 System Type: Community

PWS Name: FLAGLER BEACH WTP

# 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>	
		Nitrate & Nitrite	Annually	2019		
		Primary Inorganics	Triennially	2020		
		Secondary Contaminants	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will	
		Volatile Organics (VOCs)	Triennially	2020	not be accepted for compliance)	
		Radionuclides	6 years	2023		
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		Cean Palm Dr and 228 Lantana Rd for SHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites	

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: FLAGLER BEACH WTP

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring				
Current Population on Record	4858			
Monitoring Frequency	Monthly			
Raw Sampling	1 Raw (pretreatment) per well			
Distribution Sampling	5			

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2180722 System Type: Non-Transient Non-Community

PWS Name: MARINE PARK OF FLAGLER LP

### 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	*	19 at 241 Marine Center Dr for HMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites	

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by **October 31**st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\*Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring			
Current Population on Record	85		
Monitoring Frequency	Quarterly		
Raw Sampling	1 Raw (pretreatment) per well		
Distribution Sampling	1		

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

#### Important Reminders:

Failure to sample in accordance with rule requirements may result in enforcement action.

PWS Name: MARINE PARK OF FLAGLER LP

➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.

- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2180863 System Type: Community

PWS Name: PALM COAST UTILITY

### 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2019	
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will
		Volatile Organics (VOCs)	Triennially	2020	not be accepted for compliance)
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Dalapon (SOC)	Annually	1 <sup>st</sup> Quarter 2019	POE @ Plant 2
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		May 2019 at Lake Place Fire Hydrant TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Ev	ery 2 weeks	Sample at <u>each</u> Point of Entry to the distribution

PWS Name: PALM COAST UTILITY

\*Submit Asbestos Free Certification and SOC Waiver Requests by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\*Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring			
Current Population on Record	80325		
Monitoring Frequency	Monthly		
Raw Sampling	1 Raw (pretreatment) per well		
Distribution Sampling	80		

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2181288 System Type: Community

PWS Name: HOLIDAY TRAVEL PARK

### 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>
		Nitrate & Nitrite	Annually	2019	
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will
		Volatile Organics (VOCs)	Triennially	2021	not be accepted for compliance)
		Radionuclides	Triennially	2021	-
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at each Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*  Month*** at 158 Deer Run for THMs and HAA5s**
		Dalapon (SOC)	Annually	3 <sup>rd</sup> Quarter 2019	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: HOLIDAY TRAVEL PARK

\*\*\*An updated DBP sampling plan to reflect the designated week of sampling has not been submitted for review. Please submit a plan at least 45 days prior to sampling.

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring			
Current Population on Record	82		
Monitoring Frequency	Monthly		
Raw Sampling	1 Raw (pretreatment) per well		
Distribution Sampling	1		

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2184251 System Type: Community

PWS Name: PLANTATION BAY WTP

# 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>
		Nitrate & Nitrite	Annually	2019	
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will
		Volatile Organics (VOCs)	Triennially	2021	not be accepted for compliance)
		Radionuclides	6 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*  Iburry Lift Station and Aldenham Lift for TTHMs and HAA5s**
		Dalapon (SOC)	Annually	1 <sup>st</sup> quarter 2019	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: PLANTATION BAY WTP

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring			
Current Population on Record	3500		
Monitoring Frequency	Monthly		
Raw Sampling	1 Raw (pretreatment) per well		
Distribution Sampling	4		

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2184259 System Type: Community

PWS Name: DUNES COMMUNITY DEVELOPMENT DISTRICT

### 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>
		Nitrate & Nitrite	Annually	2019	
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will
		Volatile Organics (VOCs)	Triennially	2020	not be accepted for compliance)
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2026	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at each Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		at 170 Island Estates Pkwy for FHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: DUNES COMMUNITY DEVELOPMENT DISTRICT

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring			
Current Population on Record	4596		
Monitoring Frequency	Monthly		
Raw Sampling	1 Raw (pretreatment) per well		
Distribution Sampling	5		

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.



Northeast District, 8800 Baymeadows Way West, Suite 100, Jacksonville, FL 32256

PWS ID: 2184278 System Type: Community

PWS Name: DAYTONA NORTH WATER SYSTEM

### 2019 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

	Chemical Monitoring				
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	<b>Location &amp; Comments</b>
		Nitrate & Nitrite	Annually	2019	
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will
		Volatile Organics (VOCs)	Triennially	2021	not be accepted for compliance)
		Radionuclides	6 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Di(2- ethyhexyl)phthal ate (SOC)	Annually	3 <sup>rd</sup> Quarter 2019	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	August 2021 at	CCKR for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

<sup>\*</sup>Submit *Asbestos Free Certification* and *SOC Waiver Requests* by October 31<sup>st</sup> to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: DAYTONA NORTH WATER SYSTEM

Bacteriological requirements per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring			
Current Population on Record	100		
Monitoring Frequency	Monthly		
Raw Sampling	1 Raw (pretreatment) per well		
Distribution Sampling	1		

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- ➤ Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department</u>. Reports can be submitted to <u>DEP\_NED@dep.state.fl.us</u>.