



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1190013

System Type: Community

PWS Name: ALLIGATOR POINT WATER RESOURCE DISTRICT

## 2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2022	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2024	
		Secondary Contaminants	Triennially	2024	
		Volatile Organics (VOCs)	Triennially	2024	
		Radionuclides	Gross Alpha	2024 - Well 1&4, 2R&5 Blend and Well 6&7	
			Rad 226 & 228	2027 - Well 1&4, 2R&5 Blend and Well 6&7	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2024	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2021 at 482 BALD POINT RD for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10
--	--	-------------------------------	-------------	---------------	--

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

**Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1190118

System Type: Community

PWS Name: CARRABELLE CITY OF WATER SYS.

## 2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	August 2021 at 703 WELLBORN AVENUE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

\*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)*** by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1190150

System Type: Community

PWS Name: APALACHICOLA CITY OF

## 2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Radium 226/228	2023	
			Gross Alpha Incl. Uranium	2029	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	<b><u>SAMPLING PLAN REQUIRES UPDATING. CONTACT LEXIE WOODSON IMMEDIATELY**</u></b>	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20
--	--	-------------------------------	-------------	---------------	--

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

**Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1190236

System Type: Community

PWS Name: EASTPOINT WATER & SEWER DIST.

## 2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	3 years & 6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	May 2021 at EASTPOINT FIRE DEPARTMENT and August 2021 at FRANKLIN COUNTY JAIL (270 HWY 65) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required:10

\*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)*** by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click [here](#) for a contact list of Department personnel.





# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1190414

System Type: Community

PWS Name: LANARK VILLAGE (CITY OF CARRABELLE)

## 2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		VOC - Styrene	Annually	2021 1 <sup>st</sup> Qtr	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2021 at CART BARN-167 LAUGHING GULL LANE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 10

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1190789

System Type: Community

PWS Name: WATER MGMT SERVICES (ST. GEORGE ISLAND)

## 2021 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha	2029	
			Rad 226 & 228	2023	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	4 <sup>th</sup> week of January, April, July, and October 2021 at STATE PARK BUCK STREET for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Triennially	Jun-Sept 2023	Sample at pre-approved sample plan sites; Number of sites required: 20
--	--	-------------------------------	-------------	---------------	--

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



## Northwest District Drinking Water Program Contacts

**General #:(850) 595-8300**

**Fax #:(850) 595-8392**

~Section Supervisor	<b>Dana Vestal</b>
	(850) 595-0659
	<a href="mailto:Dana.Vestal@FloridaDEP.gov">Dana.Vestal@FloridaDEP.gov</a>
~Compliance/Enforcement	<b>Angelia Butler</b>
	(850) 595-0598
	<a href="mailto:Angelia.Butler@FloridaDEP.gov">Angelia.Butler@FloridaDEP.gov</a>
~Stage 2 Disinfection Byproducts (DBP) Compliance ~Disinfectant Residual Reports	<b>Lexie Woodson</b>
	(850) 595-0640
	<a href="mailto:Alexandria.Woodson@FloridaDEP.gov">Alexandria.Woodson@FloridaDEP.gov</a>
~Chemical Compliance (Nitrates/Nitrites, Inorganics, SOC, VOC, Asbestos, Secondaries, Rads)	<b>Paula Smith</b>
	(850) 595-0632
	<a href="mailto:Paula.Smith@FloridaDEP.gov">Paula.Smith@FloridaDEP.gov</a>
~Consumer Confidence Reports (CCR)	<b>Mary Jehle</b>
	(850) 595-0676
	<a href="mailto:Mary.Jehle@FloridaDEP.gov">Mary.Jehle@FloridaDEP.gov</a>
~Lead and Copper Rule (LCR) Tap Monitoring ~Capacity Development (CD)	<b>Nicole Hetzel</b>
	(850) 595-0660
	<a href="mailto:Nicole.Hetzel@FloridaDEP.gov">Nicole.Hetzel@FloridaDEP.gov</a>
~Boil Water Notices (BWNs) ~Monthly Operation Reports (MORs)	<b>Steve Hafner</b>
	(850) 595-0689
	<a href="mailto:Steve.Hafner@FloridaDEP.gov">Steve.Hafner@FloridaDEP.gov</a>
	Email BWN info and clearance bacti-s to: <a href="mailto:NWDPWS@FloridaDEP.gov">NWDPWS@FloridaDEP.gov</a>
	Email MORs to: <a href="mailto:DWRM_Data_Entry_Tal@dep.state.fl.us">DWRM_Data_Entry_Tal@dep.state.fl.us</a>
~Bacteriological Compliance (Routine Bact. Sampling, Well & Tank Clearances, Revised Total Coliform & Ground Water Rules)	<b>Ben Russell</b>
	(850) 595-0678
	<a href="mailto:Ben.Russell@FloridaDEP.gov">Ben.Russell@FloridaDEP.gov</a>
~Cross-Connection Control (C3) Annual Reports	Email bact. compliance results to: <a href="mailto:NWDPWS@FloridaDEP.gov">NWDPWS@FloridaDEP.gov</a>
	Email C3 reports to: <a href="mailto:NWDPWS@FloridaDEP.gov">NWDPWS@FloridaDEP.gov</a>
~General Permits ~Permit Clearances	<b>Katie Ates</b>
	(850) 595-0656
	<a href="mailto:Katie.L.Ates@FloridaDEP.gov">Katie.L.Ates@FloridaDEP.gov</a>
Branch Office Environmental Administrator	<b>Michael Fuller</b>
	(850) 767-0040
	<a href="mailto:Michael.Fuller@FloridaDEP.gov">Michael.Fuller@FloridaDEP.gov</a>

<b>Panama City Branch Office Inspectors</b>	<b>Loran Jordan</b>
	(850) 767-0044
	<a href="mailto:Loran.Jordan@FloridaDEP.gov">Loran.Jordan@FloridaDEP.gov</a>
	<b>Larry Couch</b>
<b>Tallahassee Branch Office Inspectors</b>	(850) 767-0047
	<a href="mailto:Larry.Couch@FloridaDEP.gov">Larry.Couch@FloridaDEP.gov</a>
	<b>Tracy White</b>
	(850) 245-7628
<b>Tallahassee Branch Office Inspectors</b>	<a href="mailto:Tracy.A.White@FloridaDEP.gov">Tracy.A.White@FloridaDEP.gov</a>
	<b>Kevin Grace</b>
	(850) 245-7629
	<a href="mailto:Kevin.T.Grace@FloridaDEP.gov">Kevin.T.Grace@FloridaDEP.gov</a>