



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1230545

System Type: Community

PWS Name: PORT ST. JOE CITY OF

## 2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		VOC - <b>Xylene</b>	Annually	2 <sup>nd</sup> Qtr 2020, 2021, 2022	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	*****	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are not available during 2021 and 2022</b> )
		SOC - <b>2,4-D</b>	Annually	2 <sup>nd</sup> Qtr 2020	
		SOC - <b>Dalapon</b>	Annually	4 <sup>th</sup> Qtr 2020	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	2 <sup>nd</sup> week of February, May, August, and November 2020 at 794 CHARLES AVE 3871 E HWY 98 STANDPIPE AT LILAC ST & W. BEATTY AVE 348 MARLIN ST	

				for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 30

\*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

**Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1230734

System Type: Community

PWS Name: WEWAHITCHKA CITY OF

## 2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	6 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at PRESBYTERIAN STREET (NEAR RISH) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 10

\*Submit **Asbestos Free Certification** and **SOC Waiver Requests** (*waivers only available for 2<sup>nd</sup> set for systems with population over 3,300*) by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\***Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1230848

System Type: Community

PWS Name: LIGHTHOUSE UTILITIES

## 2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2023	
		Secondary Contaminants	Triennially	2023	
		Volatile Organics (VOCs)	Triennially	2023	
		Radionuclides	Gross Alpha	<b>2023</b> - Well 3 <b>2026</b> - Well 2	
			Rad 226 & 228	<b>2020</b> - Well 3 <b>2026</b> - Well 2	
		Asbestos	Every 9 years	2029	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020 1 <sup>st</sup> set rcvd for Well 2, system has applied for a wavier for 2 <sup>nd</sup> set at Well 2 only	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>wavers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	3 <sup>rd</sup> week of February, May, August, and November 2020 at 561 BARRIER DUNES DRIVE 7182 SR-30 for TTHMs and HAA5s**	

		Lead and Copper (tap samples)	Biannually	Jan-Jun and Jul-Dec 2020	Sample at pre-approved sample plan sites; Number of sites required: 30
--	--	-------------------------------	------------	--------------------------	--

\*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1234011

System Type: Community

PWS Name: GULF FORESTRY WORK CAMP

## 2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	6 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2021 at WAREHOUSE for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

\*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.





# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1234013

System Type: Community

PWS Name: GULF CORRECTIONAL INSTITUTION

## 2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2020	Sample at <u>each</u> Point of Entry to the distribution
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	Gross Alpha	2023	
			Rad 226 & 228	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> )
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at TRAILER PARK LOT #20 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 20

\*Submit *Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



## Northwest District Drinking Water Program Contacts

**General #:(850) 595-8300**

**Fax #:(850) 595-8392**

~Section Supervisor	<b>Dana Vestal</b>
	(850) 595-0659
	<a href="mailto:Dana.Vestal@floridadep.gov">Dana.Vestal@floridadep.gov</a>
~Stage 2 Disinfection Byproducts (DBP) Compliance ~Disinfectant Residual Reports	<b>Lexie Woodson</b>
	(850) 595-0640
	<a href="mailto:Alexandria.Woodson@floridadep.gov">Alexandria.Woodson@floridadep.gov</a>
~Chemical Compliance (Nitrates/Nitrites, Inorganics, SOC, VOC, Asbestos, Secondaries, Rads)	<b>Paula Smith</b>
	(850) 595-0632
	<a href="mailto:Paula.Smith@floridadep.gov">Paula.Smith@floridadep.gov</a>
~Consumer Confidence Reports (CCR)	<b>Mary Jehle</b>
	(850) 595-0676
	<a href="mailto:Mary.Jehle@floridadep.gov">Mary.Jehle@floridadep.gov</a>
~Lead and Copper Rule (LCR) Tap Monitoring ~Capacity Development (CD)	<b>Nicole Hetzel</b>
	(850) 595-0660
	<a href="mailto:Nicole.Hetzel@floridadep.gov">Nicole.Hetzel@floridadep.gov</a>
~Monthly Operation Reports (MORs) ~Boil Water Notices (BWNs)	<b>Heather Stone</b>
	(850) 595-0587
	<a href="mailto:Heather.Stone@floridadep.gov">Heather.Stone@floridadep.gov</a>
	<b>Email MORs to:</b>
	<a href="mailto:DWRM_Data_Entry_Tal@dep.state.fl.us">DWRM_Data_Entry_Tal@dep.state.fl.us</a>
	<b>ALSO cc:</b> <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a>
<b>Email BWN info and clearance bacti-s to:</b>	
<a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a>	
~Bacteriological Compliance (Routine Bact. Sampling, Well & Tank Clearances, Revised Total Coliform & Ground Water Rules)	<b>Ben Russell</b>
	(850) 595-0678
	<a href="mailto:Ben.Russell@floridadep.gov">Ben.Russell@floridadep.gov</a>
	<b>Email bact. compliance results to:</b>
<a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a>	
~General Permits ~Permit Clearances	<b>Katie Ates</b>
	(850) 595-0656
	<a href="mailto:Katie.L.Ates@floridadep.gov">Katie.L.Ates@floridadep.gov</a>
Branch Office Environmental Administrator	<b>Michael Fuller</b>
	(850) 767-0040
	<a href="mailto:Michael.Fuller@floridadep.gov">Michael.Fuller@floridadep.gov</a>

<b>Panama City Branch Office Inspectors</b>	<b>Loran Jordan</b>
	(850) 767-0044
	<a href="mailto:Loran.Jordan@floridadep.gov">Loran.Jordan@floridadep.gov</a>
	<b>Larry Couch</b>
<b>Tallahassee Branch Office Inspectors</b>	(850) 767-0047
	<a href="mailto:Larry.Couch@floridadep.gov">Larry.Couch@floridadep.gov</a>
	<b>Tracy White</b>
	(850) 245-7628
	<a href="mailto:Tracy.A.White@floridadep.gov">Tracy.A.White@floridadep.gov</a>
	<b>Kevin Grace</b>
(850) 245-7629	
<a href="mailto:Kevin.T.Grace@floridadep.gov">Kevin.T.Grace@floridadep.gov</a>	
<b>Lucas Grantham</b>	
(850) 245-7626	
<a href="mailto:Lucas.Grantham@floridadep.gov">Lucas.Grantham@floridadep.gov</a>	