



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

A & L Septic Tank Products

P. O. Box 677878

Orlando, FL 32867

Orange

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		USE	APPROVAL	
				WIDTH	LENGTH			(Pump Tanks)			DATE	FAMILY
48-029-03D-C4	C4	6.00	46.00	60	100	2	750	1,060	B		11/9/2010	
REMARKS: HS20 traffic rated, slide-in baffle												
48-029-03S-C4	C4	6.00	46.00	60	100	2	750	1,060	B		11/9/2010	
REMARKS: HS20 traffic rated												
48-029-10D-C4	C4	6.00	48.00	72	102	2	1050	1,340	B		11/2/2015	
REMARKS: HS20 traffic rated, mid-seam, slide-in baffle												
48-029-10S-C4	C4	6.00	48.00	72	102	2	1050	1,400	B		11/2/2015	
REMARKS: HS20 traffic rated, mid-seam												
48-029-15D-C4	C4	6.00	59.00	72	102	2	1250	1,543	B		11/9/2010	
REMARKS: C4 and HS20 traffic rated, mid-seam, slide-in baffle												
48-029-15S-C4	C4	6.00	59.00	72	102	2	1250	1,543	B		11/9/2010	
REMARKS: C4 and HS20 traffic rated												

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

AA Precast Products Inc.

8300 W. Beaver

Jacksonville, FL 32220-2301

Duval

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks) USE		
16-065-03D-C4	C4	6.00	32.00	48	136		750	905	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-03S-C4	C4	6.00	32.00	48	136		750	905	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-04D-C4	C4	6.00	40.00	48	136		900	1,101	2/22/2011	
REMARKS: Tank rated for HS20 traffic4S										
16-065-04S-C4	C4	6.00	40.00	48	136		900	1,101	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-14D-C4	C4	6.00	48.00	71	108		1250	1,525	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-14S-C4	C4	6.00	48.00	71	108		1250	1,525	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-15D-C4	C4	6.00	47.00	60	136		1050	1,269	1/31/2011	
REMARKS: Also HS20 traffic rating										
16-065-15S-C4	C4	6.00	47.00	60	136		1050	1,307	1/31/2011	
REMARKS: Also HS20 traffic rating										
16-065-19D-C4	C4	6.00	47.00	83	108		1900	2,189	1/31/2011	
REMARKS: Also HS20 rating										
16-065-19S-C4	C4	6.00	47.00	83	108		1900	2,274	1/31/2011	
REMARKS: Also HS20 rating										
16-065-21D-C4	C4	6.00	58.00	83	108		1500	1,830	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-21S-C4	C4	6.00	58.00	83	108		1500	1,830	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-41D-C4	C4	6.00	63.00	83	157		2500	3,096	2/22/2011	
REMARKS: Tank rated for HS20 traffic										
16-065-41S-C4	C4	6.00	63.00	83	157		2500	3,096	2/22/2011	
REMARKS: Tank rated for HS20 traffic										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

All American Precast Manufacturing

1300 NW 4th Street
Homestead FL 33030

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL	DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE			
13-159-07D-C4	C4	6.00	63.00	54	84	2.5	750	860 GI	12/9/2020		
REMARKS: Secondary pour baffle. HS20 traffic loading rated when installed with 2 ft of cover. Approved for use as a grease interceptor only. Lid # 210. Waterstop, watertightness testing per rule 64E-6.013(10)(d), FAC, required.											
13-159-12D-C4	C4	6.00	74.00	60	108	2.5	1200	1,580 GI	12/9/2020		
REMARKS: Secondary pour baffle. HS20 traffic loading rated when installed with 2 ft of cover. Approved for use as a grease interceptor only. Lid # 211. Waterstop, watertightness testing per rule 64E-6.013(10)(d), FAC, required.											
13-159-15D-C4	C4	6.00	62.00	84	108	2.5	1500	2,010 GI	12/9/2020		
REMARKS: Secondary pour baffle. HS20 traffic loading rated when installed with 2 ft of cover. Approved for use as a grease interceptor only. Lid # 212. Waterstop, watertightness testing per rule 64E-6.013(10)(d), FAC, required.											
13-159-20D-C4	C4	6.00	60.00	72	150	2.5	2000	2,460 GI	12/9/2020		
REMARKS: Secondary pour baffle. HS20 traffic loading rated when installed with 2 ft of cover. Approved for use as a grease interceptor only. Lid # 213. Waterstop, watertightness testing per rule 64E-6.013(10)(d), FAC, required.											

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Alpha General Services, Inc.

Post Office Box 3331

Sebring, FL 33871

Highlands

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)			
28-004-40D-C4	C4	0.50	53.75	70	97	2.5	750		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-40S-C4	C4	0.50	53.75	70	97	2.5	750		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-41D-C4	C4	0.50	57.75	70	97	2.5	900		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-41S-C4	C4	0.50	57.75	70	97	2.5	900		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-42D-C4	C4	0.50	60.75	70	103	2.5	1050		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-42S-C4	C4	0.50	60.75	70	103	2.5	1050		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-43D-C4	C4	0.50	55.75	70	114	2.5	1200		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; mid-seam testing after installation not required when factory testing seal is present; length+width at inside edge of flange											
28-004-43S-C4	C4	0.50	55.75	70	114	2.5	1200		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; mid-seam testing after installation not required when factory testing seal is present; length+width at inside edge of flange											
28-004-44D-C4	C4	0.50	55.75	70	125	2.5	1350		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-44S-C4	C4	0.50	55.75	70	125	2.5	1350		B	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-45D-C4	C4	0.50	54.00	70	135	2.5	1500		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-45S-C4	C4	0.50	54.00	70	135	2.5	1500		B	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-46D-C4	C4	0.50	55.75	70	146	2.5	1650		B,GI	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											
28-004-46S-C4	C4	0.50	55.75	70	146	2.5	1650		B	7/29/2013	
REMARKS: HS20 rated with at least 18" burial; no mid-seam test after install needed with Alpha sticker; length+width at inside edge of flange											

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Averett Septic Tank Co.

Post Office Box 266

Eaton Park, FL 33840

Polk

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks) USE		
53-037-50D-C4	C4	6.00	40.00	69	113		900	1,132	3/27/2008	
REMARKS: Slide-in baffle. Rated for AASHTO HS20 traffic. Revised 08/19/2009										
53-037-50S-C4	C4	6.00	40.00	69	113		900	1,132	3/27/2008	
REMARKS: Rated for AASHTO HS20 traffic. Revised 08/19/2009										
53-037-51D-C4	C4	6.00	45.50	69.5	113.5		1050	1,273	3/27/2008	
REMARKS: Slide-in baffle. Rated for AASHTO HS20 traffic. Revised 08/19/2009										
53-037-51S-C4	C4	6.00	45.50	69.5	113.5		1050	1,273	3/27/2008	
REMARKS: Rated for AASHTO HS20 traffic. Revised 08/19/2009										
53-037-52D-C4	C4	6.00	52.38	70.5	114.25		1250	1,467	3/27/2008	
REMARKS: Slide-in baffle. Rated for AASHTO HS20 traffic. Revised 08/19/2009										
53-037-52S-C4	C4	6.00	52.38	70.5	114.25		1250	1,467	3/27/2008	
REMARKS: Rated for AASHTO HS20 traffic. Revised 08/19/2009										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Bates Precast Concrete, Incorporated

6431 Ocean Pond Avenue

Lake Park, GA 31636

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
61-074-10D-C4	C4	6.00	42.25	84	96	2.5	1050	1,250	b,gi	10/20/2015	3
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover											
61-074-10S-C4	C4	6.00	42.25	84	96	2.5	1100	1,300	b,gi	10/20/2015	3
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover											
61-074-125D-C4	C4	6.00	50.25	84	96	2.5	1250	1,550	b, GI	8/23/2019	
REMARKS: Slide-in baffle. Mid-seam; HS20 traffic loading rated when installed with 1.5 to 4 ft of cover. Also approved for use as a grease interceptor.											
61-074-125G-C4	C4	6.00	50.25	84	96	2.5	1250	1,550	GI	8/23/2019	
REMARKS: 2 x 626 gallons compartments; Slide-in baffle. Mid-seam; HS20 traffic loading rated when installed with 1.5 to 4 ft of cover. Grease interceptor.											
61-074-125S-C4	C4	6.00	50.25	84	96	2.5	1250	1,550	b	8/23/2019	
REMARKS: Mid-seam; HS20 traffic loading rated when installed with 1.5 to 4 ft of cover.											
61-074-12D-C4	C4	6.00	48.25	84	96	2.5	1200	1,400	b,gi	10/20/2015	3
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover											
61-074-12S-C4	C4	6.00	48.25	84	96	2.5	1250	1,450	b,gi	10/20/2015	3
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover											
61-074-13D-C4	C4	6.00	54.25	84	96	2.5	1350	1,550	b,gi	10/20/2015	3
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover											
61-074-13S-C4	C4	6.00	54.25	84	96	2.5	1400	1,650	b	10/20/2015	3
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover											
61-074-14D-C4	C4	6.00	60.25	84	96	2.5	1500	1,700	b,gi	10/20/2015	3
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover											
61-074-14S-C4	C4	6.00	60.25	84	96	2.5	1550	1,800	b	10/20/2015	3
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover											
61-074-16D-C4	C4	6.00	66.25	84	96	2.5	1650	1,900	b,gi	10/20/2015	3
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover											
61-074-16S-C4	C4	6.00	66.25	84	96	2.5	1700	1,950	b	10/20/2015	3
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover											
61-074-19D-C4	C4	5.00	43.75	82	154	2.5	1900	2,290	b	5/17/2016	2
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete											
61-074-19S-C4	C4	5.00	43.75	82	154	2.5	1900	2,350	b	5/17/2016	2
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete											
61-074-22D-C4	C4	5.00	50.50	82	154	2.5	2200	2,600	b	5/17/2016	2
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete											
61-074-22S-C4	C4	5.00	50.50	82	154	2.5	2200	2,700	b	5/17/2016	2
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete											

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Bates Precast Concrete, Incorporated

6431 Ocean Pond Avenue

Lake Park, GA 31636

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
61-074-25D-C4	C4	5.00	57.50	82	154	2.5	2500	3,040	b		8/23/2019	
REMARKS: Slide-in baffle. Mid-seam; HS20 traffic loading rated when installed with 1.5 to 3 ft of cover and 5000 psi concrete is used.												
61-074-25G-C4	C4	5.00	57.50	82	154	2.5	2500	3,040	GI		8/23/2019	
REMARKS: 2 x 1250 gallons compartments; Slide-in baffle. Mid-seam; HS20 traffic loading rated when installed with 1.5 to 3 ft of cover and 5000 psi concrete is used. Grease interceptor.												
61-074-25S-C4	C4	5.00	57.50	82	154	2.5	2500	3,040	b		8/23/2019	
REMARKS: Mid-seam; HS20 traffic loading rated when installed with 1.5 to 3 ft of cover and 5000 psi concrete is used.												
61-074-27D-C4	C4	5.00	62.00	82	154	2.5	2700	3,200	b		5/17/2016	2
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete												
61-074-27S-C4	C4	5.00	62.00	82	154	2.5	2700	3,290	b		5/17/2016	2
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete												
61-074-30D-C4	C4	5.00	68.75	82	154	2.5	3000	3,500	b		5/17/2016	2
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete												
61-074-30S-C4	C4	5.00	68.75	82	154	2.5	3000	3,600	b		5/17/2016	2
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; 5000 psi concrete												
61-074-37D-C4	C4	8.00	43.64	115	235	2.5	3700	4,200	b		5/17/2016	1
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-37S-C4	C4	8.00	43.64	115	235	2.5	3700	4,300	b		5/17/2016	1
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-43D-C4	C4	8.00	50.77	115	235	2.5	4300	4,900	b		5/17/2016	1
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-43S-C4	C4	8.00	50.77	115	235	2.5	4300	5,000	b		5/17/2016	1
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-48D-C4	C4	8.00	56.64	115	235	2.5	4800	5,500	b		5/17/2016	1
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-48S-C4	C4	8.00	56.64	115	235	2.5	4800	5,600	b		5/17/2016	1
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-53D-C4	C4	8.00	62.53	115	235	2.5	5300	6,100	b		5/17/2016	1
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-53S-C4	C4	8.00	62.53	115	235	2.5	5300	6,200	b		5/17/2016	1
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-58D-C4	C4	8.00	68.41	115	235	2.5	5800	6,600	b		5/17/2016	1
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-58S-C4	C4	8.00	68.41	115	235	2.5	5800	6,800	b		5/17/2016	1
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Bates Precast Concrete, Incorporated

6431 Ocean Pond Avenue

Lake Park, GA 31636

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
61-074-63D-C4	C4	8.00	74.28	115	235	2.5	6300	7,200	b	5/17/2016	1	
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-63S-C4	C4	8.00	74.28	115	235	2.5	6300	7,400	b	5/17/2016	1	
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-68D-C4	C4	8.00	80.16	115	235	2.5	6800	7,800	b	5/17/2016	1	
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-68S-C4	C4	8.00	80.16	115	235	2.5	6800	7,900	b	5/17/2016	1	
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-71D-C4	C4	8.00	83.68	115	235	2.5	7100	8,100	b	5/17/2016	1	
REMARKS: mid-seam; slide-in baffle; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												
61-074-71S-C4	C4	8.00	83.68	115	235	2.5	7100	8,300	b	5/17/2016	1	
REMARKS: mid-seam; HS20, when installed with 1.5 to 4 ft of cover; octagonal shape												

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Del Zotto Mfg. Co.

4575 W. Highway 40

Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
42-007-14S-C4	C4	7.00	85.00	86	86		1350	1,350 D	3/27/2012	
REMARKS: Dosing tank only, circular, 7000 PSI, HS20 traffic loading rated with HS20 lid, post-installation watertightness testing required per 64E-6.013(10)(d) FAC										
42-007-50D-C4	C4	6.00	47.00	60	96		750	1,030	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-50S-C4	C4	6.00	47.00	60	96		750	1,030	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-51D-C4	C4	6.00	44.00	72	96		900	1,222	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-51S-C4	C4	6.00	44.00	72	96		900	1,222	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-52D-C4	C4	6.00	46.00	72	108		1050	1,446	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-52S-C4	C4	6.00	46.00	72	108		1050	1,446	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-53D-C4	C4	6.00	44.00	72	132		1250	1,745	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-53S-C4	C4	6.00	44.00	72	132		1250	1,745	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-54D-C4	C4	6.00	48.00	84	162		2000	2,805	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-54S-C4	C4	6.00	48.00	84	162		2000	2,805	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-55D-C4	C4	6.00	64.00	84	162		2800	3,366	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-55S-C4	C4	6.00	64.00	84	162		2800	3,366	7/6/2009	
REMARKS: 4" or 6" inlets and outlets, HS20 traffic loading rated										
42-007-G30D-C4	C4	6.00	56.00	116.5	150.75	2.5	3000	3,750	2/2/2009	
REMARKS: Approved for HS20 traffic loading; April 2014, changed inlet for 2.5" drop. Can house SludgeHammer S-1000 ATU. Remarks updated 1/29/2025.										
42-007-G30S-C4	C4	6.00	56.00	116.5	150.75	2	3000	3,888	2/2/2009	
REMARKS: Approved for HS20 traffic loading.										
42-007-G32D-C4	C4	6.00	60.00	116.8	151		3200	3,995	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G32S-C4	C4	6.00	60.00	116.8	151		3200	4,144	2/2/2009	
REMARKS: Approved for HS20 traffic loading										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Del Zotto Mfg. Co.

4575 W. Highway 40

Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks) USE		
42-007-G35D-C4	C4	6.00	65.00	117	151		3500	4,297	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G35S-C4	C4	6.00	65.00	117	151		3500	4,459	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G37D-C4	C4	6.00	68.00	117	151		3700	4,478	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G37S-C4	C4	6.00	68.00	117	151		3700	4,648	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G40D-C4	C4	6.00	73.00	117.4	151.5		4000	4,257	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G40S-C4	C4	6.00	73.00	117.4	151.5		4000	5,111	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G43D-C4	C4	6.00	78.00	117.6	151.63		4300	5,093	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G43S-C4	C4	6.00	78.00	117.6	151.63		4300	5,291	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G45D-C4	C4	6.00	81.00	117.9	151.88		4500	5,472	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G45S-C4	C4	6.00	81.00	117.9	151.88		4500	5,678	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G48D-C4	C4	6.00	69.00	117.1	187.38		4800	5,778	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G48S-C4	C4	6.00	69.00	117.1	187.38		4800	5,951	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G50D-C4	C4	6.00	72.00	117.3	187.38		5000	6,006	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G50S-C4	C4	6.00	72.00	117.3	187.38		5000	6,187	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G53D-C4	C4	6.00	76.00	117.5	187.63		5300	6,323	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G53S-C4	C4	6.00	76.00	117.5	187.63		5300	6,515	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G55D-C4	C4	6.00	78.00	117.6	187.63		5500	6,476	2/2/2009	
REMARKS: Approved for HS20 traffic loading										

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Del Zotto Mfg. Co.

4575 W. Highway 40

Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks) USE		
42-007-G55S-C4	C4	6.00	78.00	117.6	187.63		5500	6,674	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G58D-C4	C4	6.00	82.00	117.9	187.88		5800	7,029	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G58S-C4	C4	6.00	82.00	117.9	187.88		5800	7,238	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G60D-C4	C4	6.00	73.00	117.4	217.5		6000	7,173	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G60S-C4	C4	6.00	73.00	117.4	217.5		6000	7,357	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G65D-C4	C4	6.00	78.00	117.6	217.63		6500	7,628	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G65S-C4	C4	6.00	78.00	117.6	217.63		6500	7,826	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G70D-C4	C4	6.00	84.00	118	218		7000	8,465	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G70S-C4	C4	6.00	84.00	118	218		7000	8,679	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G75D-C4	C4	6.00	77.00	117.5	253.63		7500	8,884	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G75S-C4	C4	6.00	77.00	117.5	253.63		7500	9,079	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G80D-C4	C4	6.00	81.00	117.9	253.88		8000	9,670	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G80S-C4	C4	6.00	81.00	117.9	253.88		8000	9,876	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G85D-C4	C4	6.00	77.00	117.5	283.63		8500	10,151	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G85S-C4	C4	6.00	77.00	117.5	283.63		8500	10,308	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G90D-C4	C4	6.00	81.00	117.6	283.63		9000	11,011	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G90S-C4	C4	6.00	81.00	117.6	283.63		9000	11,179	2/2/2009	
REMARKS: Approved for HS20 traffic loading										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Del Zotto Mfg. Co.

4575 W. Highway 40

Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL USE DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)		
42-007-G95D-C4	C4	6.00	76.00	117.5	319.63		9500	11,382	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-G95S-C4	C4	6.00	76.00	117.5	319.63		9500	11,536	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA1D-C4	C4	6.00	79.00	117.6	319.75		10000	11,687	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA1S-C4	C4	6.00	79.00	117.6	319.75		10000	11,887	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA2D-C4	C4	6.00	83.00	118	320		10500	12,669	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA2S-C4	C4	6.00	83.00	118	320		10500	12,880	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA3D-C4	C4	6.00	79.00	117.6	349.75		11000	12,853	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA3S-C4	C4	6.00	79.00	117.6	349.75		11000	13,053	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA4D-C4	C4	6.00	83.00	118	349.88		11500	13,926	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA4S-C4	C4	6.00	83.00	118	349.88		11500	14,137	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA5D-C4	C4	6.00	78.00	117.6	385.75		12000	14,088	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA5S-C4	C4	6.00	78.00	117.6	385.75		12000	14,286	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA6D-C4	C4	6.00	81.00	117.9	385.88		12500	15,103	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA6S-C4	C4	6.00	81.00	117.9	385.88		12500	15,309	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA7D-C4	C4	6.00	84.00	118	386		13000	15,601	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA7S-C4	C4	6.00	84.00	118	386		13000	15,815	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA8D-C4	C4	6.00	82.00	117.9	409.88		13500	16,266	2/2/2009	
REMARKS: Approved for HS20 traffic loading										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Del Zotto Mfg. Co.

4575 W. Highway 40

Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks) USE		
42-007-GA8S-C4	C4	6.00	82.00	117.9	409.88		13500	16,475	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA9D-C4	C4	6.00	78.00	117.6	445.63		14000	16,388	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GA9S-C4	C4	6.00	78.00	117.6	445.63		14000	16,586	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GB1D-C4	C4	6.00	81.00	117.9	445.88		14500	17,366	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GB1S-C4	C4	6.00	81.00	117.9	445.88		14500	17,778	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-GB2D-C4	C4	6.00	84.00	118	446		15000	18,152	2/2/2009	
REMARKS: Approved for HS20 traffic loading-										
42-007-GB2S-C4	C4	6.00	84.00	118	446		15000	18,366	2/2/2009	
REMARKS: Approved for HS20 traffic loading										
42-007-H01S-C4	C4	6.00	50.00	65	46		300	400 Pump t	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover.										
42-007-H02D-C4	C4	6.00	42.00	65	103		750	923	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover.										
42-007-H02S-C4	C4	6.00	42.00	65	103		750	923	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover.										
42-007-H03D-C4	C4	6.00	50.00	65	103		900	1,060	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover.										
42-007-H03S-C4	C4	6.00	50.00	65	103		900	1,060	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover.										
42-007-H04D-C4	C4	6.00	42.00	65	141		1050	1,314	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H04S-C4	C4	6.00	42.00	65	141		1050	1,314	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H05D-C4	C4	6.00	50.00	65	141		1250	1,512	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H05S-C4	C4	6.00	50.00	65	141		1250	1,512	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H06D-C4	C4	6.00	45.00	87	113		1350	1,469	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Del Zotto Mfg. Co.

4575 W. Highway 40

Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks) USE		
42-007-H06S-C4	C4	6.00	45.00	87	113		1350	1,469	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H07D-C4	C4	6.00	50.00	87	113		1500	1,605	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H07S-C4	C4	6.00	50.00	87	113		1500	1,605	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H08D-C4	C4	6.00	55.00	87	113		1650	1,741	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H08S-C4	C4	6.00	55.00	87	113		1650	1,741	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover.										
42-007-H09D-C4	C4	6.00	42.00	87	164		1900	2,102	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H09S-C4	C4	6.00	42.00	87	164		1900	2,102	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H10D-C4	C4	6.00	45.00	87	164		2000	2,224	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H10S-C4	C4	6.00	45.00	87	164		2000	2,224	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H11D-C4	C4	6.00	49.00	87	164		2200	2,388	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H11S-C4	C4	6.00	49.00	87	164		2200	2,388	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H12D-C4	C4	6.00	51.00	87	164		2300	2,471	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H12S-C4	C4	6.00	51.00	87	164		2300	2,471	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H13D-C4	C4	6.00	56.00	87	164		2500	2,677	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H13S-C4	C4	6.00	56.00	87	164		2500	2,677	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H14D-C4	C4	6.00	60.00	87	164		2700	2,847	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										
42-007-H14S-C4	C4	6.00	60.00	87	164		2700	2,842	3/10/2010	
REMARKS: Tank rated for HS20 traffic loading and C4 burial cover										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Del Zotto Mfg. Co.

4575 W. Highway 40

Ocala, FL 34482

Marion

ACTIVE

TANK NUMBER	CATEGORY	WALL	LIQUID	TOP EXTERIOR		IN-OUT	EFFECTIVE	TOTAL	APPROVAL		
		THICKNESS	DEPTH	WIDTH	LENGTH	DROP	GALLONS	GALLONS (Pump Tanks)	USE	DATE	FAMILY
42-007-H15D-C4	C4	6.00	56.00	116.5	150.75		3000	3,700		5/8/2012	
REMARKS: slide-in baffle attached by manufacturer; designed for HS20 and 6 feet burial depth; 10" lid; 6,000 psi concrete; 4",6"or 8" inlet and outlet											
42-007-H15S-C4	C4	6.00	56.00	116.5	150.75		3000	3,700		5/3/2012	
REMARKS: designed for HS20 and 6 feet burial depth; 10" lid; 6,000 psi concrete; 4",6"or 8" inlet and outlet											
42-007-H16D-C4	C4	6.00	78.00	117.6	151.63		4300	5,000		5/8/2012	
REMARKS: slide-in baffle attached by manufacturer; designed for HS20 and 6 feet burial depth; 10" lid; 6,000 psi concrete; 4",6"or 8" inlet and outlet											
42-007-H16S-C4	C4	6.00	78.00	117.6	151.63		4300	5,000		5/3/2012	
REMARKS: designed for HS20 and 6 feet burial depth; 10" lid; 6,000 psi concrete; 4",6"or 8" inlet and outlet											

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Florida Septic, Inc.Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
01-011-02D-C4	C4	4.00	53.00	49.25	95.5	2.5	750	925	B, GI	5/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-02S-C4	C4	4.00	53.00	49.25	95.5	2.5	750	925	B, GI	5/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-06D-C4	C4	6.00	53.00	53.25	99.5	2.5	750	925	B, GI	10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-06S-C4	C4	6.00	53.00	53.25	99.5	2.5	750	925	B, GI	10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-11D-C4	C4		44.00	72.5	104.5	2.5	1050	1,348	B, GI	3/17/2003	
REMARKS: Houses Bionest BNC-400 ATU. Wall thickness can be either 4" or 6". AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-11S-C4	C4		44.00	72.5	104.5	2.5	1050	1,348	B, GI	3/17/2003	
REMARKS: Wall thickness can be either 4" or 6". AASHTO HS20 traffic loading rated when buried between 18" to 48". Approved as pretreatment tank for the AK12S245C ATU (NSF245 certified) when the ATU is housed in the 01-011-AK10-C3. Approved 03/17/2003. Updated 11/19/2024.											
01-011-13D-C4	C4		52.00	73	105	2.5	1250	1,564	B, GI	3/17/2003	
REMARKS: Houses Bionest BNC-500 ATU. Wall thickness can be either 4" or 6". AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-13S-C4	C4		52.00	73	105	2.5	1250	1,564	B, GI	3/17/2003	
REMARKS: Wall thickness can be either 4" or 6". AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-27D-C4	C4	6.00	53.00	73	137	2.5	1500	1,918	B, GI	10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house Bionest BNC-600 ATU. Can house SludgeHammer S-400 ATU. Remarks updated 1/29/2025.											
01-011-27P-C4	C4	6.00	53.00	73	137	2.5	1500	1,918	D	2/28/2011	
REMARKS: ASSHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-27S-C4	C4	6.00	53.00	73	137	2.5	1500	1,918		10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-29D-C4	C4	4.00	44.00	75.25	151.5	2.5	1650	2,000	B, GI	7/30/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-29N-C4	C4	4.00	4.00	75.25	151.5	42.5	0	2,000		10/3/2013	
REMARKS: Modification of 01-011-29S-C4 for Florida Onsite Sewage Nitrogen Reduction Strategy Study. Media tank: liquid level =4"; add flow-through hole in second structural rib. AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-29P-C4	C4	4.00	44.00	75.25	151.5	2.5	1650	2,000	D	2/28/2011	
REMARKS: lowered pass-through hole for dosing tank; AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-29S-C4	C4	4.00	44.00	75.25	151.5	2.5	1650	2,000	B	7/30/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											
01-011-30D-C4	C4	6.00	44.00	79.25	155.5	2.5	1650	2,000	B, GI	5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"											

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Florida Septic, Inc.Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)		APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH							
01-011-30P-C4	C4	5.00	44.00	79.25	155.5	2.5	1650	2,000	D		2/28/2011	
REMARKS: ASSHTO HS20 traffic rating when buried between 18" to 48"												
01-011-30S-C4	C4	6.00	44.00	19.25	155.5	2.5	1650	2,000			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-39D-C4	C4	6.00	53.00	80.25	156.75	2.5	2000	2,400	B		5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house Bionest BNC-750 ATU. Can house SludgeHammer S-600 ATU. Remarks updated 1/29/2025.												
01-011-39P-C4	C4	6.00	53.00	80.25	156.75	2.5	2000	2,400	D		2/28/2011	
REMARKS: ASSHTO HS20 traffic rating when buried between 18" to 48"												
01-011-39S-C4	C4	6.00	53.00	80.25	156.75	2.5	2000	2,400			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-49D-C4	C4	6.00	65.50	82	158.5	2.5	2500	3,023			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house SludgeHammer S-800 ATU. Remarks updated 1/29/2025.												
01-011-49P-C4	C4	6.00	65.50	82	158.5	2.5	2500	3,023	D		2/28/2011	
REMARKS: AASHTO HS20 traffic rating when buried between 18" to 48"												
01-011-49S-C4	C4	6.00	65.50	82	158.5	2.5	2500	3,023			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-53D-C4	C4	6.00	42.50	103.3	190.75	2.5	2800	3,518	B		10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-53P-C4	C4	6.00	42.50	103.3	190.75	2.5	2800	3,518	D		2/28/2011	
REMARKS: ASSHTO HS20 traffic rating when buried between 18" to 48"												
01-011-53S-C4	C4	6.00	42.50	103.3	190.75	2.5	2800	3,518			10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-57D-C4	C4	6.00	45.50	103.5	191.63	2.5	3000	3,733	B		10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Can house SludgeHammer S-1000 ATU. Remarks updated 1/29/2025.												
01-011-57P-C4	C4	6.00	45.50	103.5	191.63	2.5	3000	3,733	D		2/28/2011	
REMARKS: AASHTO HS20 traffic rating when buried between 18" to 48"												
01-011-57S-C4	C4	6.00	45.50	103.5	191.63	2.5	3000	3,733			10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-60D-C4	C4	6.00	60.00	81.25	157	2.5	2300	2,752	B		5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-60P-C4	C4	6.00	60.00	81.25	157	2.5	2300	2,752	D		2/28/2011	
REMARKS: AASHTO HS20 traffic rating when buried between 18" to 48"												
01-011-60S-C4	C4	6.00	60.00	81.25	157	2.5	2300	2,752			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Florida Septic, Inc.Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
01-011-65D-C4	C4	6.00	49.50	103.8	192	2.5	3300	4,023	B		10/31/2001	
REMARKS: Houses Bionest BNC-1250 ATU. AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-65S-C4	C4	6.00	49.50	103.8	192	2.5	3300	4,023			10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-69D-C4	C4	6.00	55.75	104.1	192.5	2.5	3700	4,461	B		5/29/2002	
REMARKS: Houses Bionest BNC-1500 ATU. AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-69P-C4	C4	6.00	55.75	104.1	192.5	2.5	3700	4,461	D		2/28/2011	
REMARKS: ASSHTO HS20 traffic rating when buried between 18" to 48"												
01-011-69S-C4	C4	6.00	55.75	104.1	192.5	2.5	3700	4,461			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-73D-C4	C4	6.00	64.00	105.1	193.5	3	4300	5,107			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-73P-C4	C4	6.00	64.00	105.1	193.5	3	4300	5,107	D		2/28/2011	
REMARKS: ASSHTO HS20 traffic rating when buried between 18" to 48"												
01-011-73S-C4	C4	6.00	64.00	105.1	193.5	3	4300	5,107			5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-77D-C4	C4	6.00	73.50	106	194.75	2.75	5000	5,910	B		5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-77P-C4	C4	6.00	73.50	106	194.75	2.75	5000	5,910	D		2/28/2011	
REMARKS: ASSHTO HS20 traffic rating when buried between 18" to 48"												
01-011-77S-C4	C4	6.00	73.50	106	194.75	2.75	5000	5,910	B		5/29/2002	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-90D-C4	C4	4.00	43.00	68.13	131.25	2.5	1250	1,500	B, GI		7/30/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48" with 8" lid. Approved for GI use 5/22/2020												
01-011-90P-C4	C4	4.00	43.00	68.13	131.25	2.5	1250	1,500	D		2/28/2011	
REMARKS: lowered pass-through hole for dosing tank; AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-90S-C4	C4	4.00	43.00	68.13	131.13	2.5	1250	1,500			7/30/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-92D-C4	C4	6.00	46.00	72.5	136.13	2.5	1350	1,688	B, GI		10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												
01-011-92P-C4	C4	6.00	46.00	72.5	136.13	2.5	1350	1,688	D		2/28/2011	
REMARKS: AASHTO HS20 TRAFFIC LOADING RATED WHEN BURIED BETWEEN 18" TO 48"												
01-011-92S-C4	C4	6.00	46.00	72.5	136.13	2.5	1350	1,688			10/31/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"												



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Florida Septic, Inc.

Post Office Box 545
Hawthorne, FL 32640

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks) USE		
01-011-93S-C4	C4	4.00	42.00	47.75	55.75	1	300	373	12/14/2001	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48"										
01-011-BM10-C4	C4	6.00	63.00	82	158.5	2.5	2400	3,021	3/28/2012	
REMARKS: Converted 02-05-2012. Houses Bio-Microbics MicroFAST 1.5 ATU (NSF 40-certified units only).. AASHTO HS20 traffic loading rated when buried between 18" to 48".										
01-011-BM11-C4	C4	6.00	66.00	106	194.75	3	4500	5,909 ATU	3/28/2012	
REMARKS: Used to house Bio-Microbics MicroFAST 3.0F and 3.0FS ATU. AASHTO HS20 traffic loading rated when buried between 18" to 48"										
01-011-BM12-C4	C4	6.00	65.00	106	194.75	11	4400	5,913 ATU	3/28/2012	
REMARKS: AASHTO HS20 traffic loading rated when buried between 18" to 48". Used to house Bio-Microbics MicroFAST 4.5F ATU										
01-011-BM9-C4	C4	6.00	53.00	73	137	2.5	1500	1,919 ATU	10/31/2001	
REMARKS: Converted 01-011-27D-C4, Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: 0.5, 0.625, 0.75, 0.9. NSF 245-certified units: 0.5, 0.625, 0.75.. AASHTO HS20 traffic loading rated when buried between 18" to 48"										
01-011-E100H-C4	C4	6.00	53.00	73	137	2.5	1500	1,920 ATU	4/8/2021	
REMARKS: Originally approved as 01-011-27S-C4, Houses the Delta EcoPod E100-N ATU (1,000 gpd). Minimum pretreatment tank effective capacity required is 1,000 gal; maximum allowed is 2,500 gal unless specified by the design engineer. The Delta EcoPod is NSF 245-certified. Lid # 223. HS20										
01-011-E150H-C4	C4	6.00	60.00	81.25	157	2.5	2300	1,920 ATU	4/8/2021	
REMARKS: Originally approved as 01-011-60S-C4, Houses the Delta EcoPod E150-N ATU (1,500 gpd). Minimum pretreatment tank effective capacity required is 1,500 gal; maximum allowed is 3,750 gal unless specified by the design engineer. The Delta EcoPod is NSF 245-certified. Lid #224. HS20										
01-011-E200H-C4	C4	6.00	49.50	103.8	192	2.5	3300	4,024 ATU	4/8/2021	
REMARKS: Originally approved as 01-011-65S-C4, Houses the Delta EcoPod E200-DCA (2,000 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 2,000 gal. Lid # 225. HS20										
01-011-E250H-C4	C4	6.00	55.75	104.1	192.5	2.5	3700	4,460 ATU	4/8/2021	
REMARKS: Originally approved as 01-011-69S-C3, modified structural rib. Houses the Delta EcoPod E250-DCA (2,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 2,500 gal. Lid # 225. HS20										
01-011-E300H-C4	C4	6.00	64.00	105.1	193.5	3	4300	5,100 ATU	4/8/2021	
REMARKS: Originally approved as 01-011-73S-C3, Houses the Delta EcoPod E300-DCA (3,000 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,000 gal. Lid # 225. HS20										
01-011-E350H-C4	C4	6.00	73.50	106	194.75	2.75	5000	5,900 ATU	4/8/2021	
REMARKS: Originally approved as 01-011-77S-C3, Houses the Delta EcoPod E350-DCA (3,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,500 gal. Lid # 225. HS20										
01-011-E400H-C4	C4	6.00	73.50	106	194.75	2.75	5000	5,900 ATU	4/8/2021	
REMARKS: Originally approved as 01-011-77S-C3, Houses the Delta EcoPod E350-DCA (3,500 gpd) engineer-designed ATU. Minimum pretreatment tank effective capacity required is 3,500 gal. Lid # 225. HS20										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

George W.Shepard & Son, Inc.

Collier

PO Box 202

ACTIVE

Naples FL 34106

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
11-149-21D-C4	C4	6.00	45.00	66	123	2.5	1050	1,300	B, GI		3/6/2019	
REMARKS: HS20 traffic. Slide-in baffle Formerly manufactured by Southeastern Septic approval 53-152-21D-C4												
11-149-21S-C4	C4	6.00	45.00	66	123	2.5	1050	1,300	B, GI		3/6/2019	
REMARKS: HS20 traffic. Formerly manufactured by Southeastern Septic approval 53-152-21S-C4												
11-149-22D-C4	C4	6.00	45.00	66	143	2.5	1250	1,500	B, GI		3/6/2019	
REMARKS: HS20 traffic. Slide-in baffle Formerly manufactured by Southeastern Septic approval 53-152-22D-C4												
11-149-22S-C4	C4	6.00	45.00	66	143	2.5	1250	1,500	B, Gi		3/6/2019	
REMARKS: HS20 traffic. Formerly manufactured by Southeastern Septic approval 53-152-22S-C4												



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Hanson Pipe & Precast

12781 US Hwy 41 South

Gibson, FL 33534

Hillsborough

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	APPROVAL		
				WIDTH	LENGTH				USE	DATE	FAMILY
29-139-01D-C4	C4	8.00	58.68	115	187		4300			11/28/2007	

REMARKS: Rated for HS20 traffic loading.

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Highland TanksOne Highland Road
Stoystown PA 15563

Active

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)	USE		
70-151-01102-C4	C4	0.18	42.00	64	84	6	800	1,169	GI	3/12/2021	
REMARKS: coated steel; 2 COMPARTMENTS - Highland Model No. PGI-800 FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab											
70-151-01302-C4	C4	0.18	46.00	64	94	6	1000	1,309	GI	3/12/2021	
REMARKS: coated steel; 2 COMPARTMENTS - Highland Model No. PGI-1000 FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab											
70-151-01802-C4	C4	0.18	49.00	64	132	5	1500	1,838	GI	3/12/2021	
REMARKS: coated steel; 2 COMPARTMENTS - Highland Model No. PGI-1500 FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab											
70-151-02602-C4	C4	0.18	48.00	64	180	6	2000	2,506	GI	3/12/2021	
REMARKS: coated steel; 2 COMPARTMENTS - Highland Model No. PGI-2000 FL; up to 60" burial; HS20 rated with 52" of fill and 8" reinforced concrete slab											
70-151-026B2-C4	C4	0.25	48.00	64	180	6	2000	2,506	GI	3/12/2021	
REMARKS: coated steel; 2 COMPARTMENTS - Highland Model No. PGI-2000 FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab											
70-151-F012D1-C	C4	0.18	52.00	64	104	3	1250	1,400	GI, B	9/19/2016	
REMARKS: coated steel; 1 Compartment - Highland Model PGI-1250-FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab											
70-151-F025D2-C	C4	0.25	51.00	64	212	3	2500	2,900	GI	9/19/2016	
REMARKS: coated steel; 2 Compartments - Highland Model PGI-2500-FL 2; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab											
70-151-F025H2-C	C4	0.18	51.00	64	212	3	2500	2,900	GI	9/19/2016	
REMARKS: coated steel; 2 Compartments - Highland Model PGI-2500-FL; up to 60" burial; HS20 rated with 52" of fill and 8" reinforced concrete slab											
70-151-F030D3-C	C4	0.25	51.00	64	252	3	3000	3,500	GI	9/19/2016	
REMARKS: coated steel; 3 Compartments - Highland Model PGI-3000-FL; up to 120" burial; HS20 rated with at least 52" of fill and 8" reinforced concrete slab											
70-151-H040D4-C	C4	0.25	57.00	72	268	3	4000	4,700	GI	9/19/2016	
REMARKS: coated steel; 4 Compartments - Highland Model PGI-4000-FL; up to 120" burial; HS20 rated with at least 52" of fill and 8" reinforced concrete slab											
70-151-K050D4-C	C4	0.25	69.00	84	238	3	5000	5,700	GI	9/19/2016	
REMARKS: coated steel; 4 Compartments - Highland Model PGI-5000-FL; up to 120" burial; HS20 rated with at least 52" of fill and 8" reinforced concrete slab											
70-151-K060D5-C	C4	0.31	69.00	84	285	3	6000	6,800	GI	9/19/2016	
REMARKS: coated steel; 5 Compartments - Highland Model PGI-6000-FL 2; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab											
70-151-K060H5-C	C4	0.25	69.00	84	285	3	6000	6,800	GI	9/19/2016	
REMARKS: coated steel; 5 Compartments - Highland Model PGI-6000-FL; up to 60" burial; HS20 rated with 52" of fill and 8" reinforced concrete slab											
70-151-K062D5-C	C4	0.31	70.00	84	286	3	6250	6,850	GI	4/15/2016	1
REMARKS: coated steel; 5 Compartments - Highland Model PGI-6250-FL 120" burial; HS20 rated with at least 18" of fill and 8" reinforced concrete slab											
70-151-K062H5-C	C4	0.25	70.00	84	286	3	6250	6,850	GI	4/15/2016	2
REMARKS: coated steel; 5 Compartments - Highland Model PGI-6250-FL 60" burial; HS20 rated with at least 18" of fill and 8" reinforced concrete slab											

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Highland TanksOne Highland Road
Stoystown PA 15563

Active

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
70-151-K075D6-C	C4	0.31	69.00	84	357	3	7500	8,500	GI		9/19/2016	
REMARKS: coated steel; 6 Compartments - Highland Model PGI-7500-FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab												
70-151-K100D8-C	C4	0.38	68.00	84	484	5	10000	11,600	GI		9/19/2016	
REMARKS: coated steel; 8 Compartments - Highland Model PGI-10000-FL 2; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab												
70-151-K100H8-C	C4	0.31	68.00	84	484	5	10000	11,600	GI		9/19/2016	
REMARKS: coated steel; 8 Compartments - Highland Model PGI-10000-FL; up to 60" burial; HS20 rated with 52" of fill and 8" reinforced concrete slab												
70-151-K120D10-	C4	0.38	66.00	84	600	7	12000	14,300	GI		9/19/2016	
REMARKS: coated steel; 10 Compartments - Highland Model PGI-12000-FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab												
70-151-L150D12-	C4	0.38	72.00	90	636	7	15000	17,500	GI		9/19/2016	
REMARKS: coated steel; 12 Compartments - Highland Model PGI-15000-FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab												
70-151-L175D14-	C4	0.38	75.00	96	672	7	17500	21,000	GI		9/19/2016	
REMARKS: coated steel; 14 Compartments - Highland Model PGI-17500-FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab												
70-151-L200D16-	C4	0.38	75.00	96	768	8	20000	24,000	GI		9/19/2016	
REMARKS: coated steel; 16 Compartments - Highland Model PGI-20000-FL; up to 120" burial; HS20 rated with 52"-112" of fill and 8" reinforced concrete slab												

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Lindsay Precast, Inc., Southern Division

Alachua

13365 Southern Precast Drive

ACTIVE

Alachua FL 32615

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
01-132-11D-C4	C4	6.00	40.00	60	108		750	1,007 GI, B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading; 5,500 psi concrete; slide-in baffle										
01-132-11S-C4	C4	6.00	40.00	60	108		750	1,032 GI, B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading; 5,500 psi concrete										
01-132-12D-C4	C4	6.00	55.00	60	108		1050	1,298 GI, B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading; 5,500 psi concrete; slide-in baffle										
01-132-12S-C4	C4	6.00	55.00	60	108		1050	1,332 GI, B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading; 5,500 psi concrete										
01-132-13D-C4	C4	6.00	40.00	72	138		1250	1,663 GI, B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading; 5,500 psi concrete; slide-in baffle										
01-132-13S-C4	C4	6.00	40.00	72	138		1250	1,694 GI, B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete										
01-132-14D-C4	C4	6.00	40.00	84	120	2.5	1250	1,700 GI, B	8/1/2013	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; slide-in baffle										
01-132-14S-C4	C4	6.00	40.00	84	120	2.5	1250	1,742 GI, B	8/1/2013	2
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete										
01-132-15D-C4	C4	6.00	46.00	84	120		1500	1,901 GI, B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; slide-in baffle										
01-132-15S-C4	C4	6.00	46.00	84	120		1500	1,944 B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete										
01-132-20D-C4	C4	6.00	61.50	84	120		2000	2,408 B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; slide-in baffle										
01-132-20S-C4	C4	6.00	61.50	84	120		2000	2,466 B	1/9/2008	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete										
01-132-25S-C4	C4	6.00	81.00	120	240		10000	11,968	4/10/2009	
REMARKS: Approved for AASHTO HS20 traffic loading; 5000 psi concrete; mid-seam; holding tank only										
01-132-34D-C4	C4	6.00	40.00	84	120	2.5	1250	1,700 GI	4/13/2016	2
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; monolithic baffle										
01-132-35D-C4	C4	6.00	46.00	84	120	2.5	1500	1,900 GI	4/13/2016	2
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; monolithic baffle										
01-132-40D-C4	C4	6.00	61.50	84	120	2.5	2000	2,400 GI, B	4/13/2016	2
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; monolithic baffle										
01-132-44D-C4	C4	6.00	42.00	84	120	2.5	1360	1,900 GI	4/13/2016	2
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; 4" slide-in baffle										



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Lindsay Precast, Inc., Southern Division

13365 Southern Precast Drive
Alachua FL 32615

Alachua

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		USE	APPROVAL	
				WIDTH	LENGTH			(Pump Tanks)			DATE	FAMILY
01-132-45D-C4	C4	6.00	47.00	84	120	2.5	1500	2,100	GI		4/13/2016	2
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; 4" slide-in baffle												
01-132-46D-C4	C4	6.00	33.50	66	114	2.5	750	1,054	GI		5/31/2018	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; monolithic baffle												
01-132-47D-C4	C4	6.00	46.00	66	114	2.5	1050	1,329	GI		5/31/2018	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; monolithic baffle												
01-132-48D-C4	C4	6.00	55.50	66	114	2.5	1250	1,535	GI		5/31/2018	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; monolithic baffle												
01-132-49D-C4	C4	6.00	65.50	66	114	2.5	1500	1,764	GI		5/31/2018	
REMARKS: Approved for AASHTO HS20 traffic loading with 1 ft minimum soil cover; 5,500 psi concrete; monolithic baffle												



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Mid-State Precast, Inc.

8037 Commercial Blvd.

Sebring FL 33870

Highlands

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR WIDTH	TOP EXTERIOR LENGTH	IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	APPROVAL USE	DATE	FAMILY
28-O15-10D-C4	C4	6.00	53.30				1050			4/22/2002	
REMARKS: Houses Bionest BNC-400 ATU. HS20 traffic rated											
28-O15-10S-C4	C4	6.00	53.30				1050			4/22/2002	
REMARKS: HS20 traffic rated											
28-O15-15D-C4	C4	6.00	57.80	67.6	109.4		1250	1,456		8/24/2010	
REMARKS: HS20 traffic rated; slide-in baffle											
28-O15-15S-C4	C4	6.00	57.80	67.6	109.4		1250	1,483		8/24/2010	
REMARKS: HS20 traffic rated											
28-O15-24D-C4	C4	6.00	42.00	90	130		1500			4/22/2002	
REMARKS: Without slide-in baffle, houses Bio-Microbics MicroFAST 1.5 ATU when used with 713 gallon min pretreatment tank (02/26/10) (NSF 40-certified units only). HS20 traffic rated.											
28-O15-24S-C4	C4	6.00	42.00	90	130		1500			4/22/2002	
REMARKS: Houses Bio-Microbics MicroFAST 1.5 ATU when used with 713 gallon min pretreatment tank (02/26/10) (NSF 40-certified units only). HS20 traffic rated.											
28-O15-34D-C4	C4	6.00	56.00				2000			4/22/2002	
REMARKS: Houses Bionest BNC-750 ATU. HS20 traffic rated											
28-O15-34S-C4	C4	6.00	56.00				2000			4/22/2002	
REMARKS: HS20 traffic rated											
28-O15-46D-C4	C4	6.00	70.00				2500			12/12/2000	
REMARKS: Houses Bionest BNC-1000 ATU. HS20 traffic rated											
28-O15-46S-C4	C4	6.00	70.00				2500			12/12/2000	
REMARKS: HS20 traffic rated											
28-O15-58D-C4	C4	6.00	83.00				3000			4/22/2002	
REMARKS: HS20 traffic rated. Mid-seam											
28-O15-58S-C4	C4	6.00	83.00				3000			4/22/2002	
REMARKS: HS20 traffic rated. Can also be used as 3650 gallon pump tank. Mid-seam											
28-O15-75D-C4	C4	6.00	40.00	68	109.88	2.5	800	1,050	B, GI	12/16/2013	
REMARKS: HS20 traffic rated. Slide-in baffle											
28-O15-75S-C4	C4	6.00	40.00	68	109.88	2.5	800	1,050	B, GI	12/16/2013	
REMARKS: HS20 traffic rated											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Modern Welding Company of Florida, INC.

Orange

Post Office Box 568678

ACTIVE

Orlando FL 32856-8678

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL	USE	DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks)				
48-158-D011H1-C	C4	0.17	40.00	48	163	2.5	1126	1,250	GI		2/8/2018	1
REMARKS: Coated steel; 1 Compartment - Modern Welding Drawing # 9281994; up to 60" burial; HS20 rated with minimum cover of 32", including at least 8 " of concrete. Not enough air space for septic tank use.												
48-158-F021H2-C	C4	0.17	50.50	64	180	2.5	2100	2,500	GI		12/21/2018	2
REMARKS: Coated steel; 2 Compartment - Modern Welding Drawing # 711991; up to 60" burial; HS20 rated with minimum cover of 27", including at least 8 " of concrete.												

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Oldcastle Precast, Inc. Orlando

690 W Taft-Vineland Rd

Orlando FL 32824

Orange

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
48-106-075D-C4	C4	5.00	51.00	58	88	2.5	750	900	GI		2/20/2017	
REMARKS: slide-in baffle, flow-through hole invert 13.5"; not for septic tank use; 6,000 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-48x78-DOH												
48-106-075S-C4	C4	5.00	51.00	58	88	2.5	750	950	B,GI		2/20/2017	
REMARKS: 6,000 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-48x78-DOH												
48-106-076D-C4	C4	6.00	40.00	60	108	2.5	750	950	GI		2/20/2017	
REMARKS: slide-in baffle, flow-through hole invert 16.5"; not for septic tank use; 5,500 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-48x96-DOH												
48-106-076S-C4	C4	6.00	40.00	60	108	2.5	750	1,000	B,GI		2/20/2017	
REMARKS: 5,500 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-48x96-DOH												
48-106-100D-C4	C4	6.00	48.00	72	96	2.5	1000	1,200	GI		2/20/2017	
REMARKS: slide-in baffle, flow-through hole invert 15.5"; not for septic tank use; 6,000 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-60x84-DOH												
48-106-100S-C4	C4	6.00	48.00	72	96	2.5	1000	1,250	B,GI		2/20/2017	
REMARKS: 6,000 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-60x84-DOH												
48-106-125D-C4	C4	6.00	40.00	72	138	2.5	1250	1,650	GI		2/20/2017	
REMARKS: slide-in baffle, flow-through hole invert 13.5"; not for septic tank use; 5,500 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-60x126-DOH_B												
48-106-125S-C4	C4	6.00	40.00	72	138	2.5	1250	1,700	B,GI		2/20/2017	
REMARKS: 5,500 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-60x126-DOH_B												
48-106-126D-C4	C4	6.00	44.00	84	108	2.5	1250	1,550	GI		2/20/2017	
REMARKS: slide-in baffle, flow-through hole invert 14.5"; not for septic tank use; 6,000 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-72x96-DOH												
48-106-126S-C4	C4	6.00	44.00	84	108	2.5	1250	1,600	B,GI		2/20/2017	
REMARKS: 6,000 psi concrete; HS20, 0-4 ft of cover; drawing 374-GT750-72x96-DOH												
48-106-175D-C4	C4	6.00	40.00	84	156	2.5	1750	2,300	GI		2/20/2017	
REMARKS: slide-in baffle, flow-through hole invert 11"; not for septic tank use; 5,500 psi concrete; HS20, 0-4 ft of cover												
48-106-175S-C4	C4	6.00	40.00	84	156	2.5	1750	2,350	B,GI		2/20/2017	
REMARKS: 5,500 psi concrete; HS20, 0-4 ft of cover												

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Rick's Pre Fab

8450 SW 43 Terrace

Miami FL 33155

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)			
13-045-31D-C4	C4	6.00	51.00	66	96	2.5	900		B, GI	9/22/2009	
REMARKS: HS20 traffic rating											
13-045-31S-C4	C4	6.00	51.00	66	96	2.5	900		B, GI	9/22/2009	
REMARKS: HS20 traffic rating. Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); NSF 245 units: MicroFAST 0.5, (475 to 750 gal. settling tank required); RetroFAST 0.25 and 0.375 as Alternative Drainfield Repair.											
13-045-32D-C4	C4	6.00	51.00	66	110	2.5	1050		B, GI	9/22/2009	
REMARKS: HS20 traffic rating											
13-045-32S-C4	C4	6.00	51.00	66	110	2.5	1050		B, GI	9/22/2009	
REMARKS: HS20 traffic rating. Also houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required); NSF 245-certified units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal. settling tank required). Houses HS 1.0 with 500 gallon min. pretreatment tank. Houses RetroFAST 0.25 and 0.375 as Alternative Drainfield Repair.											
13-045-33D-C4	C4	6.00	51.00	74	108	2.5	1200		B, GI	9/22/2009	
REMARKS: HS20 traffic rating											
13-045-33S-C4	C4	6.00	51.00	74	108	2.5	1200		B, GI	9/22/2009	
REMARKS: HS20 traffic rating. Also houses RetroFAST 0.25, 0.375 as Alternative Drainfield Repair. Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required). NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal. settling tank required); MicroFAST 0.9 (689 to 1088 gal min. settling tank required).											
13-045-34D-C4	C4	6.00	51.00	77	126	2.5	1500		B, GI	9/22/2009	
REMARKS: HS20 traffic rating											
13-045-34S-C4	C4	6.00	51.00	77	126	2.5	1500		B	9/22/2009	
REMARKS: HS20 traffic rating. Houses Bio-Microbics MicroFAST ATU. NSF 40-certified units: MicroFAST 0.5 (333 gal min. settling tank required); MicroFAST 0.625, 0.75 (356 gal min. settling tank required); MicroFAST 0.9 (475 gal min. settling tank required) Microfast 1.5 (713 gal. min settling tank required); NSF 245 units: MicroFAST 0.5, 0.625, 0.75 (475 to 750 gal. settling tank required); MicroFAST 0.9 (689 to 1088 gal. settling tank required). Can house HS 1.0.											
13-045-35S-C4	C4	6.00	42.00	51	59	2.5	300		D	9/22/2009	
REMARKS: HS20 traffic rating.											



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

Standard Precast

PO Box 61839

Jacksonville FL 32236

Duval

ACTIVE

Jacksonville FL 32236

TANK NUMBER	CATEGORY	WALL	LIQUID	<u>TOP EXTERIOR</u>		IN-OUT	EFFECTIVE	TOTAL	APPROVAL			
		THICKNESS	DEPTH	WIDTH	LENGTH	DROP	GALLONS	GALLONS	(Pump Tanks)	USE	DATE	FAMILY
16-145-06D-C4	C4	6.00	62.00	96	152		3021				4/15/2009	

REMARKS: 2700 gallon septic tank for fire station #28----approved for HS20 traffic loading



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

U.S. Concrete Products Corporation

1888 N.W. 21st Street

Pompano Beach, FL 33069

Broward

Active

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	USE	APPROVAL	
				WIDTH	LENGTH			GALLONS (Pump Tanks)		DATE	FAMILY
06-096-07D-C4	C4	6.00	54.00	60	84	2.5	750	904	GI	6/4/2019	
REMARKS: HS20 traffic loading rated when buried at least 18" below grade and used with 8" traffic lid											
06-096-12D-C4	C4	6.00	42.00	68	144	2.5	1250	1,605	GI	6/4/2019	
REMARKS: HS20 traffic loading rated when buried at least 18" below grade and used with 8" traffic lid											

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

United Concrete Products, LLC (Medley)8351 N.W. 93rd Street
Medley, FL 33166

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH			GALLONS (Pump Tanks) USE		
13-094-13S-C3	C3	8.00	63.00	24	192		1250	1,496	6/19/2007	
REMARKS: grease trap-8" wall thickness-Rated for HS20 traffic loading										
13-094-25D-C4	C4	6.00	66.50	60	108	2.5	1250	1,500	B, GI	6/26/2013
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-51D-C4	C4	6.00	61.50	54	84	2.5	750	900	B, GI	12/18/2015
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-51S-C4	C4	6.00	61.50	54	84	2.5	750	900	B, GI	12/18/2015
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-52D-C4	C4	6.00	61.50	54	84	2.5	900	1,100	B, GI	12/18/2015
REMARKS: monolithic baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-52S-C4	C4	6.00	61.50	54	84	2.5	900	1,100	B, GI	12/18/2015
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-53D-C4	C4	6.00	55.50	60	108	2.5	1050	1,300	B, GI	12/18/2015
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-53S-C4	C4	6.00	55.50	60	108	2.5	1050	1,300	B, GI	12/18/2015
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-54D-C4	C4	6.00	64.50	60	108	2.5	1200	1,500	B, GI	12/18/2015
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-54S-C4	C4	6.00	64.50	60	108	2.5	1200	1,500	B, GI	12/18/2015
REMARKS: HS20 traffic rated; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-55D-C4	C4	6.00	66.50	60	108	2.5	1250	1,500	B, GI	12/18/2015
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-55S-C4	C4	6.00	67.50	60	108	2.5	1250	1,500	B, GI	12/18/2015
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-56D-C4	C4	6.00	72.50	60	108	2.5	1350	1,600	B, GI	12/18/2015
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										
13-094-56S-C4	C4	6.00	72.50	60	108	2.5	1350	1,600	B	12/18/2015
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)										

**DEPARTMENT OF ENVIRONMENTAL PROTECTION**

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

United Concrete Products, LLC (Medley)

8351 N.W. 93rd Street

Medley, FL 33166

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
13-094-57D-C4	C4	6.00	53.50	84	108	2.5	1500	1,900	B, GI		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-57S-C4	C4	6.00	53.50	84	108	2.5	1500	1,900	B		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-58D-C4	C4	6.00	72.50	84	108	2.5	2000	2,400	B		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-58S-C4	C4	6.00	72.50	84	108	2.5	2000	2,400	B		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-59D-C4	C4	6.00	58.50	84	156	2.5	2500	3,100	B		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-59S-C4	C4	6.00	58.50	84	156	2.5	2500	3,100	B		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-60D-C4	C4	6.00	69.50	84	156	2.5	3000	3,600	B		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-60S-C4	C4	6.00	69.50	84	156	2.5	3000	3,600	B		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions; water stop requires water-tightness test after field installation per 64E-6.013(10)(d)												
13-094-61D-C4	C4	6.00	61.50	54	84	2.5	750	900	B, GI		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-61S-C4	C4	6.00	61.50	54	84	2.5	750	900	B, GI		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-62D-C4	C4	6.00	61.50	54	84	2.5	900	1,100	B, GI		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-62S-C4	C4	6.00	61.50	54	84	2.5	900	1,100	B, GI		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-63D-C4	C4	6.00	55.50	60	108	2.5	1050	1,300	B, GI		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-63S-C4	C4	6.00	55.50	60	108	2.5	1050	1,300	B, GI		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-64D-C4	C4	6.00	64.50	60	108	2.5	1200	1,500	B, GI		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

United Concrete Products, LLC (Medley)

8351 N.W. 93rd Street

Medley, FL 33166

Dade

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
13-094-64S-C4	C4	6.00	64.50	60	108	2.5	1200	1,500	B, GI		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-65D-C4	C4	6.00	67.50	60	108	2.5	1250	1,500	B, GI		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-65S-C4	C4	6.00	67.50	60	108	2.5	1250	1,500	B, GI		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-66D-C4	C4	6.00	72.50	60	108	2.5	1350	1,600	B, GI		12/18/2015	
REMARKS: secondary pour baffle; HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												
13-094-66S-C4	C4	6.00	72.50	60	108	2.5	1350	1,600	B, GI		12/18/2015	
REMARKS: HS20 traffic rated with 12" minimum cover; engineer of record for installation to verify design assumptions												



DEPARTMENT OF ENVIRONMENTAL PROTECTION

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 9/18/2025

Searching for: HS20

WPR, INC.

4175 Briarglen Rd
Milton, FL 32583

Santa Rosa

ACTIVE

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		IN-OUT DROP	EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH			(Pump Tanks)				
57-101-25G-C4	C4	6.00	40.00	104.2	182.2	4	2500	3,700	GI		6/3/2016	
REMARKS: HS20 traffic rated with 1.5 feet of cover required. Secondary pour baffle in center of tank. No septic tank use												
57-101-30D-C4	C4	6.00	48.00	104.2	182.2	2.5	3000	3,700	B		4/4/2014	
REMARKS: HS20 traffic rated with 1.5 feet of cover required. Monolithic baffle.												