



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1300066

System Type: NTNC

PWS Name: BETHLEHEM HIGH SCHOOL

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |  |   |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due   | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022   | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2022   |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2022   |   |
|                     |              | Asbestos                                  | Every 9 years | 2022   | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2022   | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are <i>not</i> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially   | August 2022 at NURSE'S STATION (RR SINK) for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023  | Sample at pre-approved sample plan sites; Number of sites required: 5   |

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1300083

System Type: Community

PWS Name: BONIFAY CITY OF WATER DEPT.

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |   |   |
|---------------------|--------------|---|---------------|---|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due  | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022  | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2023  |   |
|                     |              | Secondary Contaminants                    | Triennially   | 2023  |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2023  |   |
|                     |              | Radionuclides                             | 9 years       | 2029  |   |
|                     |              | Asbestos                                  | Every 9 years | 2029  | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2023  | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Annually      | August 2022 at<br>950 E. HWY 90 (GILS AUTOMEDIC)<br>for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023   | Sample at pre-approved sample plan sites; Number of sites required: 10  |

\*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)*** by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1300214

System Type: Community

PWS Name: JOYCE E. SNARE WATER WORKS

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |   |   |
|---------------------|--------------|---|---------------|---|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due  | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022  | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2024  |   |
|                     |              | Secondary Contaminants                    | Triennially   | 2024  |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2024  |   |
|                     |              | Radionuclides                             | 9 years       | 2027  |   |
|                     |              | Asbestos                                  | Every 9 years | 2030  | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2024  | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially   | August 2024 at<br>1934 COUNTRY CLUB DRIVE (COUNTRY CLUB)<br>for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023   | Sample at pre-approved sample plan sites; Number of sites required: 5   |

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department. Click [here](#) for a contact list of Department personnel.





# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1300247

System Type: Community

PWS Name: ESTO TOWN OF

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |   |   |
|---------------------|--------------|---|---------------|---|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due  | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022  | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2024  |   |
|                     |              | Secondary Contaminants                    | Triennially   | 2024  |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2024  |   |
|                     |              | Radionuclides                             | 9 years       | 2027  |   |
|                     |              | Asbestos                                  | Every 9 years | 2030  | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2024  | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially   | August 2024 at<br>3285 JOHN CLARK ROAD<br>for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023   | Sample at pre-approved sample plan sites; Number of sites required: 5   |

\*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)*** by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.





# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1300498

System Type: Community

PWS Name: NOMA WATER WORKS

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |  |   |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due   | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022   | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2024   |   |
|                     |              | Secondary Contaminants                    | Triennially   | 2024   |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2024   |   |
|                     |              | VOC - <b>Xylene</b>                       | Annually      | 2 <sup>nd</sup> Qtr - 2022                               |   |
|                     |              | VOC - <b>Ethylbenzene</b>                 | Annually      | 2 <sup>nd</sup> Qtr - 2022                               |   |
|                     |              | Radionuclides                             | 9 years       | 2027   |   |
|                     |              | Asbestos                                  | Every 9 years | 2030   | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2024   | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially   | September 2024 at ST. MARKS STREET for TTHMs and HAA5s** |   |

|  |  |                               |             |               |   |
|--|--|-------------------------------|-------------|---------------|---|
|  |  | Lead and Copper (tap samples) | Triennially | Jun-Sept 2023 | Sample at pre-approved sample plan sites; Number of sites required: 5 |
|--|--|-------------------------------|-------------|---------------|---|

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1300544

System Type: NTNC

PWS Name: POPLAR SPRINGS HIGH SCHOOL

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |  |   |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due   | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022   | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2022   |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2022   |   |
|                     |              | Asbestos                                  | Every 9 years | 2022   | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2022   | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)</a> *; Population under 3,300 <b>waivers are <i>not</i> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially   | August 2022 at ADMIN BUILDING (OUTSIDE SPIGOT) for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023  | Sample at pre-approved sample plan sites; Number of sites required: 5   |

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1302006

System Type: Community

PWS Name: TEEN CHALLENGE WEST FLORIDA

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |  |   |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due   | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022   | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2024   |   |
|                     |              | Secondary Contaminants                    | Triennially   | 2024   |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2024   |   |
|                     |              | Radionuclides                             | Gross Alpha   | 2027   |   |
|                     |              |   | Rad 226 & 228 | 2024   |   |
|                     |              | Asbestos                                  | Every 9 years | 2030   | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2024   | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially   | August 2024 at OFFICE (FRONT PORCH SPIGOT) for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023  | Sample at pre-approved sample plan sites; Number of sites required: 5   |

\*Submit *Asbestos Plan or Asbestos Free Certification* and *SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)* by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

\*\**Note on DBPs:* TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.





# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1304033

System Type: Community

PWS Name: WESTVILLE TOWN OF

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |  |   |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due   | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022   | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2024   |   |
|                     |              | Secondary Contaminants                    | Triennially   | 2024   |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2024   |   |
|                     |              | Radionuclides                             | 9 years       | 2027   |   |
|                     |              | Asbestos                                  | Every 9 years | 2030   | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2024   | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Triennially   | August 2024 at<br>2480 HAWKINS STREET<br>for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023  | Sample at pre-approved sample plan sites; Number of sites required: 5   |

\*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)*** by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.



# FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1304034

System Type: Community

PWS Name: PONCE DE LEON TOWN OF

## 2022 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. Monitoring requirements can be found under [Rule 62-550 of the Florida Administrative Code](#) (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

*It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements.* Please review the monitoring information below and contact our office with any questions.

| Chemical Monitoring |              |   |               |  |   |
|---------------------|--------------|---|---------------|--|---|
| Date Scheduled      | Date Sampled | Contaminant                               | Frequency     | Next Due   | Location & Comments   |
|                     |              | Nitrate & Nitrite                         | Annually      | 2022   | Sample at <u>each</u> Point of Entry to the distribution  |
|                     |              | Primary Inorganics                        | Triennially   | 2024   |   |
|                     |              | Secondary Contaminants                    | Triennially   | 2024   |   |
|                     |              | Volatile Organics (VOCs)                  | Triennially   | 2024   |   |
|                     |              | Radionuclides                             | 9 years       | 2027   |   |
|                     |              | Asbestos                                  | Every 9 years | 2030   | Sample within distribution or certification if no asbestos pipes within the system, use <a href="#">Form 62-555.900(10)</a> for Asbestos Free Certification or Asbestos Sampling Plan*  |
|                     |              | Synthetic Organics (SOCs)                 | Triennially   | 2024   | Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 <sup>nd</sup> set of samples using <a href="#">Form 62-560.545(2)*</a> ; Population under 3,300 <b>waivers are <u>not</u> available during 2021 and 2022</b> ) |
|                     |              | Stage 2 Disinfection Byproducts (S2 DBPs) | Annually      | August 2022 at SHADY TREE LANE (END OF LINE) for TTHMs and HAA5s** |   |
|                     |              | Lead and Copper (tap samples)             | Triennially   | Jun-Sept 2023  | Sample at pre-approved sample plan sites; Number of sites required: 10  |

\*Submit ***Asbestos Plan or Asbestos Free Certification*** and ***SOC Waiver Requests (waivers only available for 2<sup>nd</sup> set for systems with population over 3,300)*** by **October 31<sup>st</sup>** to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**\*\*Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1<sup>st</sup> week of 2<sup>nd</sup> month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.


### **Bacteriological Monitoring**

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
  - A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
  - Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
  - Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at [CFR Subpart Y - Revised Total Coliform Rule](#). If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of E. coli bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as “P” in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

### ***Important Reminders:***

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: <https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical>.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.** Click [here](#) for a contact list of Department personnel.

|    | <b>Drinking Water Program</b>   | DEP Northwest District Potable Water Office<br>160 W. Government Street, Suite 308<br>Pensacola, FL 32502  |
|--|---|--|
| <b>DEP NW District Contacts</b>  | <b>General #:(850) 595-8300</b><br><b>Fax #:(850) 595-8392</b>  | <b>Important Reminders</b>   |
| <b>-Environmental Manager</b>  | <b>Earl Whibbs</b><br>(850) 595-0636<br><a href="mailto:Earl.Whibbs@floridadep.gov">Earl.Whibbs@floridadep.gov</a>  |  |
| <b>-Stage 2 Disinfection Byproducts (DBP) Compliance</b><br><b>-Disinfectant Residuals Reports</b><br><b>-Precautionary Boil Water Notices</b>                         | <b>Alyssa Tessier</b><br>(850) 595-0685<br><a href="mailto:Alyssa.Tessier@floridadep.gov">Alyssa.Tessier@floridadep.gov</a><br><b>Email DBP results to:</b><br><a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a>   | <b>Email DBP results to:</b> <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a><br><br>Community and NTNC Systems should be monitoring according to their most current Stage 2 DBP monitoring plan. Contact Alyssa if you have any questions concerning your monitoring plan.  |
| <b>-Chemical Compliance (Nitrates/Nitrites, Inorganics, SOC, VOC, Asbestos, Secondaries, Rads)</b>   | <b>Paula Smith</b><br>(850) 595-0632<br><a href="mailto:Paula.Smith@floridadep.gov">Paula.Smith@floridadep.gov</a>  | <b>Call if you have any questions on requirements</b><br><br><b>Email Chem results to Paula at her individual account</b> ( <a href="mailto:Paula.Smith@floridadep.gov">Paula.Smith@floridadep.gov</a> )   |
| <b>-Consumer Confidence Reports (CCR)</b>  | <b>Mary Jehle</b><br>(850) 595-0676<br><a href="mailto:Mary.Jehle@FloridaDEP.gov">Mary.Jehle@FloridaDEP.gov</a>   | <b>For community water systems, CCRs must be delivered to customers by July 1st every year.</b>  |
| <b>-Potable Water Compliance &amp; Enforcement, Cross Connection Control</b>   | <b>Angelia Butler</b><br>(850) 595-0598<br><a href="mailto:Angelia.Butler@floridadep.gov">Angelia.Butler@floridadep.gov</a>   | <b>If you ever need help with something regarding DEP potable water regulations, please consider using our Public Outreach Request Form at:</b> <a href="http://www.surveygizmo.com/s3/878438/Request-DEP-Northwest-District-Compliance-Assistance">http://www.surveygizmo.com/s3/878438/Request-DEP-Northwest-District-Compliance-Assistance</a>  |
| <b>-Lead and Copper Rule (LCR) Tap Monitoring</b><br><b>-Precautionary Boil Water Notices</b>  | <b>Roger Thomas</b><br>(850) 595-0660<br><a href="mailto:Roger.N.Thomas@floridadep.gov">Roger.N.Thomas@floridadep.gov</a>   | <b>Lead &amp; Copper tap sampling sites should be verified ahead of sampling to ensure homes are not vacant and that homeowners are still willing to participate.</b><br><br><b>Email LCR results to</b> <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a>  |
| <b>-Monthly Operation Reports (MORs)</b><br><b>-Boil Water Notices (BWNs)</b>  | <b>Any Drinking Water NWD Staff</b><br><br><b>Email MORs to:</b><br><a href="mailto:DWRM_Data_Entry_Tal@dep.state.fl.us">DWRM_Data_Entry_Tal@dep.state.fl.us</a><br><b>ALSO cc: <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a></b><br><br><b>Email BWN info and clearance bacti-s to:</b><br><a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a> | <b>Email MORs to:</b> <a href="mailto:DWRM_Data_Entry_Tal@dep.state.fl.us">DWRM_Data_Entry_Tal@dep.state.fl.us</a> ( cc: <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a> )<br><b>Email BWNs (issuances, rescissions, and clearance results) to:</b> <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a><br><br>Notify this office of Boil Water Notices or other abnormal operating conditions as soon as possible, but never later than noon of the next business day. Planned events that may adversely affect finished-water quality, interrupt water service to 150 or more service connections or 350 or more people, interrupt water service to any one service connection for more than eight hours, or necessitate the issuance of a precautionary "boil water" notice in accordance with the Department of Health's "Guidelines for the Issuance of Precautionary Boil Water Notices" must be reported to this office no later than the <b>previous</b> business day. |
| <b>-Bacteriological Compliance (Routine Bact. Sampling, Well &amp; Tank Clearances, Revised Total Coliform &amp; Ground Water Rules)</b>                               | <b>Steve Hafner</b><br>(850) 595-0689<br><a href="mailto:Steve.Hafner@floridadep.gov">Steve.Hafner@floridadep.gov</a><br><br><b>Email Bact. compliance results (routine and repeat) to:</b> <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a>  | <b>Email Bact. compliance results (routine and repeat) to:</b> <a href="mailto:NWDPWS@floridadep.gov">NWDPWS@floridadep.gov</a><br><br>Please sample <b>EARLY</b> to prevent last-minute mix-ups and allow resampling within the monitoring period if necessary! Lab results are due within the first 10 days following the end of the required monitoring period. Reporting forms that are incomplete, incorrect, or illegible may be considered invalid.   |
| <b>-General Permits</b><br><b>-Permit Clearances</b>   | <b>Katie Ates</b><br>(850) 595-0656<br><a href="mailto:Katie.L.Ates@floridadep.gov">Katie.L.Ates@floridadep.gov</a>   | The Department is committed to the expeditious review of applications and issuance of permits. 1) Water systems must verify that written clearance has been granted by this office before providing water to (placing into permanent operation) any permitted PWS construction project; 2) Please notify this office in writing before modifying any permitted work so it can be determined whether a supplemental permit application will be required.  |
| <b>Panama City Office</b>  | <b>Loran Jordan</b><br>(850) 767-0044<br><a href="mailto:Loran.Jordan@floridadep.gov">Loran.Jordan@floridadep.gov</a><br><br><b>Larry Couch</b><br>(850) 767-0047<br><a href="mailto:Larry.Couch@floridadep.gov">Larry.Couch@floridadep.gov</a>   |  |
| <b>Tallahassee Branch Office</b>   | <b>Tracy White</b><br>(850) 245-7628<br><a href="mailto:Tracy.A.White@floridadep.gov">Tracy.A.White@floridadep.gov</a><br><br><b>Jesse Massey</b><br>(850) 245-7627<br><a href="mailto:Kevin.T.Grace@floridadep.gov">Kevin.T.Grace@floridadep.gov</a>   |  |
| <b>Branch Office Environ. Administrator</b>  | <b>Michael Fuller</b><br>850-767-0400<br><a href="mailto:michael.j.fuller@floridadep.gov">michael.j.fuller@floridadep.gov</a>   |  |
| <b>Important Numbers and Websites</b>  |   |  |
| <b>State Watch Office</b>  | <b>1-(800)-320-0519</b>   |  |
| <b>FDEP Operator Certification</b>   | <b>(850) 245-7500</b>   |  |
| <b>FDEP State Revolving Fund</b>   | <b>(850) 245-2835</b>   |  |
| <b>FDEP Website</b>  | <a href="https://floridadep.gov/">https://floridadep.gov/</a>   |  |
| <b>FDEP Northwest District Website</b>   | <a href="https://floridadep.gov/northwest/">https://floridadep.gov/northwest/</a>   |  |
| <b>Water Tracker Website: Please email <a href="mailto:watertracker@floridadep.gov">watertracker@floridadep.gov</a> if you do not have a user name and/or password</b> | <a href="https://flwatertracker.com">https://flwatertracker.com</a>   |  |
| <b>OCULUS - FDEP electronic document management system</b>   | <a href="https://depdms.dep.state.fl.us/Oculus/">https://depdms.dep.state.fl.us/Oculus/</a>   |  |
| <b>Florida Rural Water Association, (FRWA)</b>   | <a href="https://www.frwa.net">https://www.frwa.net</a>   |  |
| <b>Floridan Newsletter</b>   | <a href="https://floridadep.gov/subscribe">https://floridadep.gov/subscribe</a>   |  |
| <b>Tapline Newsletter</b>  | <a href="http://www.floridadep.gov/northwest/nw-outreach/content/northwest-district-newsletters">http://www.floridadep.gov/northwest/nw-outreach/content/northwest-district-newsletters</a>   |  |