

Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320011 System Type: Community

PWS Name: ALFORD TOWN OF

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2020				
		Primary Inorganics	Triennially	2021				
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution			
		Volatile Organics (VOCs)	Triennially	2021	distribution			
		Radionuclides	9 years	2027				
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		August 2020 at DRD PUBLIC WORKS TTHMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5			

PWS Name: ALFORD TOWN OF

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320025 System Type: Community

PWS Name: APALACHEE CORRECTIONAL INSTITUTION

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2020				
		Primary Inorganics	Triennially	2021				
		Secondary Contaminants	Triennially	2021	Sample at each Daint of Entry to the			
		Volatile Organics (VOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution			
		Radionuclides	Gross Alpha	2024 - Well 3 2027 - Wells 2, 2A				
			Rad 226 & 228	2027 - All Wells				
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)</u> *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	for T	July 2020 at DAIRY FARM THMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 10			

PWS Name: APALACHEE CORRECTIONAL INSTITUTION

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320111 System Type: Community

PWS Name: CAMPBELLTON WATER DEPARTMENT

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2020				
		Primary Inorganics	Triennially	2021				
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution			
		Volatile Organics (VOCs)	Triennially	2021	distribution			
		Radionuclides	9 years	2027				
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)</u> *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	for '	August 2021 at 2251 HWY 2 TTHMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5			

PWS Name: CAMPBELLTON WATER DEPARTMENT

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320143 System Type: Community

PWS Name: COTTONDALE WATER SYSTEM

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2020			
		Primary Inorganics	Triennially	2021			
		Secondary Contaminants	Triennially	2021	Sample of each Daint of Entry to the		
		Volatile Organics (VOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution		
		VOC - Vinyl chloride	Annually	4 th Qtr Well 3 - 2021, 2022, 2023			
		Radionuclides	9 years	2027			
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)*</u> ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	CITY	August 2020 at RECREATION PARK THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10		

PWS Name: COTTONDALE WATER SYSTEM

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320145 System Type: Community

PWS Name: GRACEVILLE CITY OF

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2020				
		Primary Inorganics	Triennially	2020				
		Secondary Contaminants	Triennially	2020	Sample at <u>each</u> Point of Entry to the			
		Volatile Organics	Triennially	2020	distribution			
		(VOCs)	Quarterly	2 nd & 3 rd Qtr - Well 8				
		Radionuclides	9 years	2026				
		Radionucides	Quarterly	2 nd & 3 rd Qtr - Well 8				
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)</u> *; Population under 3,300 <i>waivers are not available during</i>			
			Quarterly	2 nd & 3 rd Qtr - Well 8	2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	for T	July 2020 at 5565 HWY 77 THMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 20			

PWS Name: GRACEVILLE CITY OF

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320263 System Type: NTNC

PWS Name: DOT MAINTENANCE YARD

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2020				
		Primary Inorganics	Triennially	2022	Sample at each Point of Entry to the			
		Volatile Organics (VOCs)	Triennially	2022	distribution			
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)</u> *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	WA	eptember 2022 at AREHOUSE SHED THMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5			

^{*}Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: DOT MAINTENANCE YARD

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320311 System Type: Community

PWS Name: GREENWOOD WATER SYSTEM

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2020				
		Primary Inorganics	Triennially	2021				
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution			
		Volatile Organics (VOCs)	Triennially	2021	distribution			
		Radionuclides	9 years	2027				
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2020 at OVE NEST LANE TTHMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10			

PWS Name: GREENWOOD WATER SYSTEM

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320440 System Type: Community

PWS Name: MALONE TOWN OF WATER SYSTEM

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
	-	Nitrate & Nitrite	Annually	2020				
			Quarterly	2 nd , 3 rd , 4 th Qtr-Well 2				
		Primary Inorganics	Triennially	2021				
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution			
		Volatile Organics (VOCs)	Triennially	2021	distribution			
		Radionuclides	9 years	2021 - Well 2				
		Radionucides	9 years	2027 - Well 4				
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)*</u> ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	3RD AVE	August 2020 at & COLLINS CHAPEL RD THMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 10			

PWS Name: MALONE TOWN OF WATER SYSTEM

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at CFR Subpart Y Revised Total Coliform Rule. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320444 System Type: NTNC

PWS Name: ADMINISTRATIVE SERVICE CENTER - REGION 1

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments				
		Nitrate & Nitrite	Annually	2020					
		Primary Inorganics	Triennially	2022	Sample at <u>each</u> Point of Entry to the				
		Volatile Organics (VOCs)	Triennially	2022	distribution				
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*				
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)				
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	for 7	July 2022 at WWTP FTHMs and HAA5s**				
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5				

^{*}Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: ADMINISTRATIVE SERVICE CENTER - REGION 1

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320449 System Type: Community

PWS Name: MARIANNA CITY OF

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring								
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2021				
		Primary Inorganics	Triennially	2023				
		Secondary Contaminants	Triennially	2023	Sample of each Daint of Entwy to the			
		Volatile Organics (VOCs)	Triennially	2023	Sample at <u>each</u> Point of Entry to the distribution			
			Gross Alpha	2026				
		Radionuclides	Rad 226 & 228	2023 - Well 5 2026 - Wells 1, 6, 7				
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2020 1 set rcvd, system has applied for a waiver for the 2 nd set	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	3741	October 2020 at I INDUSTRIAL PK THMs and HAA5s**			
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 20			

PWS Name: MARIANNA CITY OF

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320686 System Type: Community

PWS Name: GRAND RIDGE TOWN OF

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. The requirements listed are general monitoring requirements and do not supersede more stringent monitoring requirements that may have been imposed by this office. Any errors below do not exempt your system from state or federal monitoring requirements. Please review the monitoring information below and contact our office with any questions.

Chemical Monitoring

Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
	_	Nitrate & Nitrite	Annually	2021	
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Volatile Organics (VOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution
			Gross Alpha	2024 - Wells 1, 3	
		Radionuclides	Gloss Alpha	2027 - Wells 2, 4	
		Radionachaes	Rad 226 & 228	2021 - Wells 1, 3	
			Kau 220 & 228	2027 - Wells 2, 4	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)</u> *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	September 2020 at LIFT STATION #1 for TTHMs and HAA5s**	

PWS Name: GRAND RIDGE TOWN OF

	Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 20
--	-------------------------------------	-------------	---------------	--

^{*}Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320689 System Type: Community

PWS Name: SNEADS TOWN OF WATER SYSTEM

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2021			
		Primary Inorganics	Triennially	2021			
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution		
		Volatile Organics (VOCs)	Triennially	2021	distribution		
		Radionuclides	9 years	2027			
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	PAULA	August 2020 at STREET (DEAD END) THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10		

PWS Name: SNEADS TOWN OF WATER SYSTEM

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1320879 System Type: Community

PWS Name: QUIET HAVEN TRAILER PARK

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2021			
		Primary Inorganics	Triennially	2021			
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution		
		Volatile Organics (VOCs)	Triennially	2021	distribution		
		Radionuclides	9 years	2027			
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)</u> *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	LOT 40	August 2021 at 2745 FLEETWOOD LN THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5		

PWS Name: QUIET HAVEN TRAILER PARK

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324027 System Type: NTNC

PWS Name: SPANISH TRAIL LUMBER

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

			Chemical	Monitoring	
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2021	
		Primary Inorganics	Triennially	2022	
		Volatile Organics (VOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution
			Gross Alpha	2028 - Well 3	
		Radionuclides	D 1006 0 000	2024 - Well 1	
		-	Rad 226 & 228	2028 - Well 3	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62- 560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)
		SOC - DEHP	Annually	1 st Qtr 2021, 2022 - Well 3	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	BR	August 2022 at REAK BUILDING THMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 5

PWS Name: SPANISH TRAIL LUMBER

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324031 System Type: Community

PWS Name: JACOB CITY OF

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2021			
		Primary Inorganics	Triennially	2021			
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the		
		Volatile Organics (VOCs)	Triennially	2021	distribution		
		VOC - Xylene	Annually	3 rd Qtr 2020, 2021, 2022			
		Radionuclides	9 years	2027			
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	4100	August 2021 at 0 JACKSON ROAD THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites; Number of sites required: 10		

PWS Name: JACOB CITY OF

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at CFR Subpart Y Revised Total Coliform Rule. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324046 System Type: NTNC

PWS Name: ALONG THE WAY DAYCARE

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2020			
		Primary Inorganics	Triennially	2020	Sample at <u>each</u> Point of Entry to the		
		Volatile Organics (VOCs)	Triennially	2020	distribution		
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)*</u> ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		eptember 2022 at HALL BATH THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5		

^{*}Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

PWS Name: ALONG THE WAY DAYCARE

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324064 System Type: Community

PWS Name: BLUE SPRINGS MHP (AKA SPRINGSIDE)

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2020			
		Primary Inorganics	Triennially	2021			
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution		
		Volatile Organics (VOCs)	Triennially	2021	distribution		
		Radionuclides	9 years	2027			
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	5	September 2021 at 5147 GOLD LANE FTHMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5		

PWS Name: BLUE SPRINGS MHP (AKA SPRINGSIDE)

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324074 System Type: Community

PWS Name: JACKSON CORRECTIONAL INSTITUTION

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Quarterly	2020			
		Primary Inorganics	Triennially	2021			
		Secondary Contaminants	Triennially	2021			
		Volatile Organics (VOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution		
			G 41.1	2021 - Well 2			
		Radionuclides	Gross Alpha	2027 - Well 1			
			Rad 226 & 228	2027			
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	July 2020 at MOBILE HOME PARK (MRT #1) for TTHMs and HAA5s**			

PWS Name: JACKSON CORRECTIONAL INSTITUTION

Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 10
-------------------------------------	-------------	---------------	--

^{*}Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - O Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- > Failure to sample in accordance with rule requirements may result in enforcement action.
- > Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324092 System Type: NTNC

PWS Name: TIPPY TOES DAYCARE (DEE'S EARTH ANGELS)

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments			
		Nitrate & Nitrite	Annually	2021				
		Primary Inorganics	Triennially	2022				
		Volatile Organics (VOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution			
		Radionuclides	9 years	2028				
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*			
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)</u> *; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)			
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2020 at KITCHEN SINK THMs and HAA5s**			
		Lead and Copper (tap samples)	Biannually	Jan-Jun and Jul-Dec 2020	Sample at pre-approved sample plan sites; Number of sites required: 5			

^{*}Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive

PWS Name: TIPPY TOES DAYCARE (DEE'S EARTH ANGELS)

sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324098 System Type: Community

PWS Name: JACKSON COUNTY UTILITIES NO. 1

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2020			
		Primary Inorganics	Triennially	2021			
		Secondary Contaminants	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution		
		Volatile Organics (VOCs)	Triennially	2021	distribution		
		Radionuclides	9 years	2027			
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		July 2020 at L PARK DRIVE HYDRANT #12 THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5		

PWS Name: JACKSON COUNTY UTILITIES NO. 1

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324101 System Type: NTNC

PWS Name: SPRINGHILL REGIONAL LANDFILL

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

	Chemical Monitoring						
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2020			
		Primary Inorganics	Triennially	2022			
		Volatile Organics (VOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution		
		VOC - Dichloromethane	Quarterly	3rd, 4th, Qtr 2020			
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using Form 62-560.545(2)*; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	HOSE	August 2022 at BIB AT OLD SCALE THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2021	Sample at pre-approved sample plan sites; Number of sites required: 5		

^{*}Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive

PWS Name: SPRINGHILL REGIONAL LANDFILL

sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do **not** rely on the laboratory to submit monitoring results to the Department. Click here for a contact list of Department personnel.</u>



Northwest District, 160 West Government St., Suite 308, Pensacola, FL 32502

PWS ID: 1324199 System Type: NTNC

PWS Name: JACKSON COUNTY UTILITIES NO. 2

2020 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is <u>subject to change</u>. Monitoring requirements can be found under <u>Rule 62-550 of the Florida Administrative Code</u> (Fla. Admin. Code). We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical Monitoring							
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments		
		Nitrate & Nitrite	Annually	2021			
		Primary Inorganics	Triennially	2022	Sample at <u>each</u> Point of Entry to the		
		Volatile Organics (VOCs)	Triennially	2022	distribution		
		VOC - Dichloromethane	Quarterly	2 nd , 3 rd Qtr 2020			
		VOC - Xylene	Annual	3 rd Qtr 2020, 2021, 2022			
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*		
		Synthetic Organics (SOCs)	Triennially	2022	Sample at <u>each</u> Point of Entry to the distribution (Population >3,300 must take 2 quarterly samples at least 60 days apart, can request to waive 2 nd set of samples using <u>Form 62-560.545(2)*</u> ; Population under 3,300 waivers are <u>not</u> available during 2021 and 2022)		
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially		July 2022 at VY 231 HYDRANT #11 THMs and HAA5s**		
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2022	Sample at pre-approved sample plan sites; Number of sites required: 5		

PWS Name: JACKSON COUNTY UTILITIES NO. 2

*Submit Asbestos Free Certification and SOC Waiver Requests (waivers only available for 2nd set for systems with population over 3,300) by October 31st to allow time for Department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

**Note on DBPs: TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations and timeframes above are based on the current approved sampling plan. Plans must specify the month of sampling for annual or triennial monitoring and the week of sampling for quarter monitoring (i.e. 1st week of 2nd month). An updated plan will be required if monitoring frequency is adjusted. Any plan changes must be submitted and approved by the Department *prior* to sampling.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Bacteriological Monitoring

- Required per Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.
- Community and NTNC Public Water Systems must sample during each month.
 - o A raw (pre-treatment,) sample from each active well must be collected under the Ground Water Rule.
 - o Distribution samples must be collected under the Revised Total Coliform Rule, and a disinfection residual reading must be recorded along with each one.
 - o Sampling should be taken in accordance with your approved Bacteriological Sampling Plan locations when possible.
- The minimum number of distribution samples is based on population and available in 141.857 Code of Federal Regulations, available at <u>CFR Subpart Y Revised Total Coliform Rule</u>. If current, your bacteriological sampling plan should specify the same number.
- If you suspect that your bacteriological sampling plan is out of date, contact us.
- Contact our office immediately and consult with us if the reporting form indicates a positive result or presence of <u>E. coli</u> bacteria. If Total Coliform is detected, you are encouraged to inform us and discuss how to proceed. The presence of either is typically shown as "P" in the appropriate column on the form.

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code

- Failure to sample in accordance with rule requirements may result in enforcement action.
- ➤ Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- ➤ All samples must be taken during the required monitoring period <u>and</u> from the correct location(s) to be accepted for compliance. Samples for DBPs and Lead and Copper Tap Sampling must be taken in accordance with the approved plans to be accepted for compliance.
- Chemical Reports must follow the required format to be accepted for compliance, which includes system cover page, lab cover page, chains of custody, results page, and lab certification pages. A copy of the format is available at: https://floridadep.gov/water/source-drinking-water/forms/62-550730-format-be-used-reporting-all-drinking-water-chemical.
- Reports are due to the Department *within 10 days* following the end of sample period <u>or</u> following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. <u>Do not rely on the laboratory to submit monitoring results to the Department</u>. Click <u>here</u> for a contact list of Department personnel.



Northwest District Drinking Water Program Contacts

General #:(850) 59	General #:(850) 595-8300 Fax #:(850) 595-8392	
~Section Supervisor	Dana Vestal	
	(850) 595-0659	
	Dana.Vestal@floridadep.gov	
~Stage 2 Disinfection Byproducts (DBP) Compliance ~Disinfectant Residual Reports	Lexie Woodson	
	(850) 595-0640	
	Alexandria.Woodson@floridadep.gov	
~Chemical Compliance (Nitrates/Nitrites, Inorganics, SOC, VOC, Asbestos, Secondaries, Rads)	Paula Smith	
	(850) 595-0632	
	Paula.Smith@floridadep.gov	
~Consumer Confidence Reports (CCR)	Mary Jehle	
	(850) 595-0676	
	Mary.Jehle@floridadep.gov	
~Lead and Copper Rule (LCR) Tap Monitoring ~Capacity Development (CD)	Nicole Hetzel	
	(850) 595-0660	
	Nicole.Hetzel@floridadep.gov	
~Monthly Operation Reports (MORs) ~Boil Water Notices (BWNs)	Heather Stone	
	(850) 595-0587	
	Heather.Stone@floridadep.gov	
	Email MORs to:	
	DWRM Data Entry Tal@dep.state.fl.us	
	ALSO cc: NWDPWS@floridadep.gov	
	Email BWN info and clearance bacti-s to:	
	NWDPWS@floridadep.gov	
~Bacteriological Compliance (Routine Bact. Sampling, Well & Tank Clearances, Revised Total Coliform & Ground Water Rules)	Ben Russell	
	(850) 595-0678	
	Ben.Russell@floridadep.gov	
	Email bact. compliance results to:	
	NWDPWS@floridadep.gov	
~General Permits ~Permit Clearances	Katie Ates	
	(850) 595-0656	
	Katie.L.Ates@floridadep.gov	
Branch Office Environmental Administrator	Michael Fuller	
	(850) 767-0040	
	Michael.Fuller@floridadep.go	

Panama City Branch Office Inspectors	Loran Jordan
	(850) 767-0044
	<u>Loran.Jordan@floridadep.gov</u>
	Larry Couch
	(850) 767-0047
	<u>Larry.Couch@floridadep.gov</u>
Tallahassee Branch Office Inspectors	Tracy White
	(850) 245-7628
	<u>Tracy.A.White@floridadep.gov</u>
	Kevin Grace
	(850) 245-7629
	Kevin.T.Grace@floridadep.gov
	Lucas Grantham
	(850) 245-7626
	Lucas.Grantham@floridadep.gov