



Department of Environmental Protection

Central District

PWS ID #: 3350005

PWS NAME: FORTY-EIGHT ESTATES

POPULATION: 87

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Triennial testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407)897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351402

PWS NAME: UMATILLA WATER WORKS (2 WPS)

POPULATION: 3,894

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	Both WTPs - 2017	Sample POE at <u>both</u> WPS in 2017.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System will begin <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) beginning July 2014. Report disinfectant residuals.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350044

PWS NAME: ST. JOHN'S RIVER UTILITY INC

POPULATION: 2,498

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly 3 raw & 2 distribution monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at <u>each POE*</u> every year.
Primary Inorganics	2018	Sample at <u>each POE</u> every 3 years.
Secondaries	2018	Sample at <u>each POE</u> every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at <u>each POE</u> every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at <u>each POE</u> every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at <u>each POE</u> every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System will continue <u>reduced</u> (annual) testing at <u>1 site</u> for both T/H (dual samples) in 2017. Report disinfectant residuals.
Asbestos	2020-21	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350062

PWS NAME: CYPRESS COVE MHP

POPULATION: 60

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Triennial testing begins. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350094

PWS NAME: BLUE PARROT RV PARK

POPULATION: 100

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>triennial</u> testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350427

PWS NAME: FRUITLAND PARK, CITY OF (4 WPS)

POPULATION: 5,127

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 4 WPs in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years. It is best to test all 4 WPs at the same time to simplify.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System will continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) beginning July 2014. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350812

PWS NAME: MASCOTTE WATER DEPARTMENT (2 WPS)

POPULATION: 6,426

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 2 WPs in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System will continue <u>routine</u> (annual) testing at <u>2</u> sites for both T/H (dual samples) beginning July 2014. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350977

PWS NAME: LADY LAKE CENTRAL

POPULATION: 8,141

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 3 WPs in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System will continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351566

PWS NAME: LEESBURG EAST

POPULATION: 8,964

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 2 WPs in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual	System is now on annual monitoring for both sites. “11237 Fountain Lake Road” during the 3rd quarter (dual sample set) & “8135 Centralia” 1st quarter (dual sample set).
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350316

PWS NAME: DURA STRESS INC

POPULATION: 350

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Total Xylene (Special Monitoring)	Quarterly	Sample at the POE quarterly until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Dalapon (Special Monitoring)	Jan-March 2017	Sample at the POE annually during the 1st quarter until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

** NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350454

PWS NAME: FLORIDA'S NATURAL GROWERS

POPULATION: 100

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Quarterly	Continue quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Total Xylene (Special Monitoring)	Quarterly	Sample at the POE quarterly until further notice.
Ethylbenzene (Special Monitoring)	Quarterly	Sample at the POE quarterly until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for Di(2-ethylhexyl)phthalate annually.</i>	3 rd Quarter 2017 (annual)	Annual monitoring required until 3 consecutive years below Regulatory Detection Limit (0.6 ug/L).
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Begin reduced (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

** NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350551

PWS NAME: HOLIDAY TRAVEL RESORT

POPULATION: 2,395

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for Toluene</i>	Jan-March 2017	Continue to sample annually during the 1 st quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350838

PWS NAME: MISSION INN GOLF & TENNIS RESORT

POPULATION: 175

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

** NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351189

PWS NAME: SILVER SPRINGS CITRUS

POPULATION: 264

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing July – Sept. 2014. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

** NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351565

PWS NAME: FL. UNITED METHODIST LIFE ENRC. CTR.

POPULATION: 90

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Quarterly	Sample at each POE quarterly until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for</i> Di(2-ethylhexyl)phthalate	Oct.-Dec. Annually	Sample at each <u>POE</u> annually during the 4 th quarter until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354000

PWS NAME: ASTATULA ELEMENTARY SCHOOL

POPULATION: 900

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Quarterly	Sample at each POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Special Monitoring for Xylenes (total)	2nd Quarter 2017 (annual)	Sample at POE annually during the 2nd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Dalapon (Special Monitoring)	Quarterly	Sample at the POE quarterly until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue <u>routine</u> (annual) sampling. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354020

PWS NAME: CUTRALE CITRUS JUICES – LEESBURG

POPULATION: 250

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Quarterly	Sample at each POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Special monthly monitoring for trichloroethylene shall continue	Monthly	Sample monthly until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the responsible personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354645

PWS NAME: THOUSAND TRAILS ORLANDO PARK

POPULATION: 1835

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Continue <u>routine</u> (annual) testing July – Sept. 2016. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354654

PWS NAME: CROTHALL LAUNDRY

POPULATION: 65

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354663

PWS NAME: ALTOONA SCHOOL

POPULATION: 90

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Quarterly	Sample at each POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Special Monitoring for 1,2-Dichloropropane	Annually	Sample at the POE annually during the 3rd quarter until further notice.
<i>Special Monitoring for Ethylbenzene</i>	Annually	Sample at each <u>POE</u> annually during the 3rd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354666

PWS NAME: TRIANGLE INDUSTRIAL PARK

POPULATION: 50

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	2024	Sample at each POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354724

PWS NAME: Lake Dorr, LLC

POPULATION: 75

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354761

PWS NAME: CHILDREN'S HOUSE OF SORRENTO

POPULATION: 53

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	2025	Sample at each POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for</i> Di(2-ethylhexyl)phthalate	4 th Quarter 2019 (Annual)	Sample at POE annually during the 4 th quarter 2019.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354812

PWS NAME: WOLVERINE ADVANCED MATERIALS

POPULATION: 59

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	2025	Sample at each POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354818

PWS NAME: SEMINOLE SPRINGS ELEMENTARY

POPULATION: 900

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Quarterly	Sample at each POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System is on Schedule 4. System will continue <u>routine</u> (annual) testing during the 3 rd quarter.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354849

PWS NAME: SILVER SAND COMPANY

POPULATION: 40

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample for SOCs at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the responsible personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354868

PWS NAME: JON'S NURSERY

POPULATION: 100

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate (quarterly) and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354870

PWS NAME: COVANTA LAKE

POPULATION: 35

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for Total Xylene</i>	Quarterly	Sample at the POE quarterly until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354902

PWS NAME: SPRING CREEK ELEMENTARY

POPULATION: 640

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Quarterly	Sample at each POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample for at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System will begin <u>routine</u> (annual) testing at <u>1 site</u> for both T/H (dual samples) beginning July 2017. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354904

PWS NAME: MACK CONCRETE INDUSTRIES

POPULATION: 55

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354919

PWS NAME: PAISLEY OAKS CHILD LEARNING CTR.

POPULATION: 41

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354928

PWS NAME: SUNRISE ARC OF LAKE COUNTY

POPULATION: 80

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for Total Xylenes</i>	Annually	Sample at each <u>POE</u> for annually during 2nd quarter (April-June) until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354930

PWS NAME: BOGGY CREEK GANG CAMP

POPULATION: 360

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for Dalapon</i>	<i>Quarterly</i>	<i>Sample at the POE quarterly until further notice.</i>
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354931

PWS NAME: CHERRY LAKE FARMS #1

POPULATION: 38

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354942

PWS NAME: ROUND LAKE ELEMENTARY

POPULATION: 900

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Quarterly	Sample at the POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue <u>routine</u> (annual) testing at <u>1 site</u> for both T/H (dual samples).
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354946

PWS NAME: COUNTY MATERIALS CORPORATION

POPULATION: 40

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354959

PWS NAME: WOODLANDS LUTHERAN CHURCH

POPULATION: 440

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354962

PWS NAME: HILLCREST

POPULATION: 30

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for Xylenes, total</i>	2 nd Quarter 2017	Sample annually at the POE during the 2 nd quarter until further notice.
<i>Special Monitoring for Ethylbenzene</i>	2 nd Quarter 2017	Sample annually at the POE during the 2 nd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample for SOCs at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	2019	Begin <u>reduced</u> (triennial) testing July – Sept. 2016. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354970

PWS NAME: BUILDING BLOCKS CHILD DEV. CENTER

POPULATION: 50

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354976

PWS NAME: BRIDGE TO ABILITY

POPULATION: 26

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring Di(2-ethylhexyl)adipate</i>	Annual 1 st quarter	Sample at the POE annually during the 1 st quarter until further noticed.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June –Sept 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354983

PWS NAME: CARLTON PALMS GILBERT CMNTY RESIDENCE

POPULATION: 26

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<i>Special Monitoring for Dalapon</i>	Oct.-Dec. 2017	Sample at the POE during the 4 th quarter annually until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System is <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan-June 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354986

PWS NAME: PHILLIPS MANUFACTURING

POPULATION: 28

2017 DRINKING WATER MONITORING REQUIREMENTS (New Non-transient Non-community system 11/14)

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”) Satisfactory results needed: 1 raw & 2 distribution baces monthly.	Quarterly	Continue <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each <u>POE</u> * every year.
Primary Inorganics	2019	Sample at each <u>POE</u> every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each <u>POE</u> annually.
Synthetic Organic Contaminants (SOCs)	2017	Sample at each <u>POE</u> annually.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2019	Sample at each <u>POE</u> every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	System on <u>reduced</u> (triennial) testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos (If the distribution system has no asbestos-cement pipe, complete Sections I and II of the form and submit it to our office. No test nec.)	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with a recently <u>approved</u> sampling plan annually June-September.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350215

PWS NAME: CLERMONT, CITY OF (3 WPS)

POPULATION: 11,265

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every yr. 3 WPs in system
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System is on Schedule 3. System continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test system)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350346

PWS NAME: CITY OF EUSTIS, 3 WTPS

POPULATION: 35,089

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 3 WPS in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
<i>Special Monitoring</i> 1st annual Ethylbenzene 2nd Q 2014	3 rd Qtr 2017- C.R. 44 WP (April-June)	Sample at POE C.R. 44 WP annually until further notice. <u>Annual</u> testing is now required during the 3 rd quarters of 2015, 2016, and 2017, minimum.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	1 st & 2 th quarter 2017	1 dual sample 1 st quarter at “13106 Biscayne Drive”, and 1 dual sample 2 nd quarter at “2065 Morris Street”.
Asbestos	2020 (test system)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

GRAND ISLAND WTP		
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 4 WPS in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	1 st & 2 nd quarter 2017	1 dual sample 1 st quarter at “13106 Biscayne Drive”, and 1 dual sample 2 nd quarter at “2065 Morris Street”.
Asbestos	2020 (test system)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350476

PWS NAME: GROVELAND WATER DEPARTMENT

POPULATION: 12,243

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 3WPs in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at POE WPs 1, 2, and 5 during 2017.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual	System will continue <u>reduced</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) during the 1 st quarter of 2017. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350745

PWS NAME: LEESBURG, CITY OF

POPULATION: 35,466

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
<i>Special monitoring for Di(2-ethylhexyl)phthalate</i>	Annual 3 rd quarter	Sample at the POE annually during the 3 rd quarter until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Begin annual monitoring	2 dual sample sets: one at the location and during the quarter with the highest TTHM single measurement, one at the location and during the quarter with the highest HAA5 single measurement.
Asbestos	2020-2021	Certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350836

PWS NAME: MINNEOLA WATER DEPARTMENT (2 WPS)

POPULATION: 14,182

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite (Quarterly nitrate – Eastridge WP)	2017	Sample at each POE* every year. 2 WPs in sys. Sample quarterly for nitrate at the Eastridge WP.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual 3 rd quarter	System is on Schedule 3. System will continue on reduced (annual) testing at 2 sites for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan. Testing is required again in 2014 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350858

PWS NAME: MOUNT DORA, CITY OF - NEW WTP 2

POPULATION: 29,996

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required. Send annual Acrylamide & Epichlorohydrin statement at end of year.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Begin triennial monitoring
Volatile Organic Contaminants (VOCs)	2017	Begin triennial monitoring
Synthetic Organic Contaminants (SOCs)	2017	Begin triennial monitoring
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System will continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required. Send annual Acrylamide & Epichlorohydrin statement at end of year.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System will continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350942

PWS NAME: VILLAGES OF LAKE – SUMTER

POPULATION: 24,583

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year; 3WTPs in system
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017 (see comments)	Sample at WTP #3 quarterly until further notice. (New source). Sample at WTP 1 & 5 at the POE once by the end of 2017.
Volatile Organic Contaminants (VOCs)	2017 (see comments)	Sample at WTP #3 quarterly until further notice. (New source). Sample at WTP 1 & 5 at the POE once by the end of 2017.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017 (see comments)	Sample at WTP #3 quarterly until further notice. (New source). Sample at WTP 1 & 5 at the POE during 2 quarters by the end of 2017. Samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports	Annual (2 nd quarter 2017)	System approved for reduced monitoring. Monitor at 2 sites (710 Bayhill Ct. and 500 Morse Blvd.) during 2 nd quarter 2017.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	*see comments	The system is on routine biannual (Jan.-June 2017) testing, because of replacement well #3. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351333

PWS NAME: TAVARES WATER DEPARTMENT

POPULATION: 25,746

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every yr. 4 WPs
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual	System qualifies for reduced monitoring. System will monitor 2 sites, 1000 Waterman way during 1st quarter 2017, and 18406 Blue Heron circle during 4th quarter 2017. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan. Testing is required again in 2017 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354779

PWS NAME: CLERMONT EAST WATER SYSTEM (2 WPS)

POPULATION: 32,286

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every yr. 2 WPs in system
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
<i>Special Monitoring for Ethylene Dibromide @ Greater Hills WP-wells 1 & 2</i>	1 st Qtr 2017 (Annual)	Sample at Greater Hills WP- wells 1 & 2 annually during the 1 st Quarter (Jan-March) until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual	System will continue with reduced (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan. Testing is required again in 2014 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354881

PWS NAME: LAKE UTILITY SERVICES SOUTH

POPULATION: 10,266

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. Has 1 plant, Greater Groves WP.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years. The special annual monitoring for dichloromethane may stop; results have been below detection limits for 3 years. This is per Rule 62-550.515(3)(b), F. A. C.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System will continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354883

PWS NAME: LAKE UTILITY SERVICES NORTH (8 WPS)

POPULATION: 21,518

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 8 WPs in sys.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years. It is highly recommended that all WPs be tested in 2014 to keep the plants on the same monitoring schedule.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Special Monitoring <i>Total Xylene</i>	Annual	Sample for <i>Total Xylene</i> annually 2016, 2017, 2018 due to a 5/2014 detect at the Crescent Bay (3 rd quarter), Lake Ridge Club, and Clermont #2/Carr WTP (both during the 2 nd quarter).
Special Monitoring <i>Ethylbenzene</i>	Annual	Sample for <i>Ethylbenzene</i> annually @ WTPs 8 & 9 during the 7/17-9/17 qtr.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue <u>quarterly</u> testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354650

PWS NAME: LEESBURG/THE PLANTATION

POPULATION: 5,141

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual 7/17-9/17	System is on annual monitoring at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354916

PWS NAME: SOUTHLAKE UTILITIES

POPULATION: 8,300

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
<i>Special Monitoring for Di(2-ethylhexyl)phthalate</i>	Annual (2 nd quarter)	Sample at the POE annually during the 2 nd quarter (April-June) until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System will begin <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) beginning July 2014. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan. Testing is required again in 2014 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350102

PWS NAME: BONFIRE MOBILE HOME PARK

POPULATION: 270

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue triennial testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350117

PWS NAME: BRITTANY ESTATES

POPULATION: 383

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350152

PWS NAME: CARLTON VILLAGE

POPULATION: 577

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2021 (test)	May sample at 7/18/12 site if suitable: 40025 PALM ST. Use Form 62-555.900(10), F.A.C., Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350172

PWS NAME: GRAND ISLAND RESORT (2WPS)

POPULATION: 680

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 2 WPs in system.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>annual</u> testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350191

PWS NAME: LEISURE MEADOWS MH RANCH

POPULATION: 300

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350240

PWS NAME: CORLEY ISLAND MOBILE MANOR

POPULATION: 250

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350249

PWS NAME: COUNTRY SQUIRE MHP

POPULATION: 240

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample VOCs at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 2, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350319

PWS NAME: EAGLE'S NEST MOBILE HOME ESTATE

POPULATION: 340

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350322

PWS NAME: EAST LAKE HARRIS ESTATES

POPULATION: 458

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample for VOCs at each POE every 3 years. Note that the special annual monitoring for xylenes (total) and ethylbenzene has ended.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	System is on (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report the disinfectant residual.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350370

PWS NAME: FERN TERRACE S/D

POPULATION: 283

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350417

PWS NAME: FORESTER HAVEN II

POPULATION: 64

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350426

PWS NAME: FRIENDLY CENTER S/D

POPULATION: 80

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350474

PWS NAME: GRIFFWOOD MHP

POPULATION: 295

2017 DRINKING WATER MONITORING REQUIREMENTS (New source 7/2016)

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	1/17, 4/17	Sample at each POE every 3 years. Currently on quarterly monitoring due to new source.
Volatile Organic Contaminants (VOCs)	1/17, 4/17	Sample at each POE every 3 years. Currently on quarterly monitoring due to new source
Synthetic Organic Contaminants (SOCs)	1/17, 4/17	Sample at each POE every 3 years. Currently on quarterly monitoring due to new source.
Benzo(a)pyrene (<i>special monitoring</i>)	Quarterly 2017	Continue sampling quarterly until further notice due to a detect during the 3 rd quarter of 2016.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan. – June 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350481

PWS NAME: HAINES CREEK MHP

POPULATION: 220

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350495

PWS NAME: HARBOR OAKS MHP

POPULATION: 421

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample for VOCs at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July-Sept 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350506

PWS NAME: HASELTON VILLAGE

POPULATION: 500

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Due to an MCL exceedance, continue to monitor quarterly at both locations (dual sample sets) until further notice.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan in 2012. All systems are testing in accordance with DEP’s standard monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171.. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350507

PWS NAME: HAWTHORNE AT LEESBURG

POPULATION: 1886

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350523

PWS NAME: HICKORY HOLLOW ESTATES

POPULATION: 223

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE every year*.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years for all VOCs.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 dual TTHM and HAA5 sample from the <u>sewer plant</u> . Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350536

PWS NAME: HIGHLANDS MHP

POPULATION: 130

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350544

PWS NAME: HOBBY HILL S/D

POPULATION: 265

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	Quarterly (see comments)	Sample at each POE every quarter for nitrate until further notice. You may sample for nitrite annually.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350573

PWS NAME: **HOWEY IN THE HILLS (2 WPS)**

POPULATION: **1,150**

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. 2 WPS in system.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue on quarterly monitoring for TTHMs and HAA5s until further notice. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350584

PWS NAME: IMPERIAL TERRACE WEST

POPULATION: 498

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350655

PWS NAME: KING'S COVE SUBDIVISION

POPULATION: 732

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171.. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: **3350679**

PWS NAME: **LADY LAKE MHP**

POPULATION: **270**

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July-Sept 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350690

PWS NAME: LAKE CORRECTIONAL INSTITUTION

POPULATION: 2000

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Total Xylene Special Monitoring</i>	Annual (see comments)	Sample at the POE during the 2 nd quarter annually until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July-Sept 2017	Continue <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. Report disinfectant residuals.
Asbestos	2021 (test)	Sample at a site in the distribution system where asbestos contamination is most likely to occur. Use Form 62-555.900(10), F.A.C., Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	Jan-June 2017	Test in accordance with the most recently approved sampling plan, due to WQP excursion.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350691

PWS NAME: SUNSHINE PARKWAY SYSTEMS

POPULATION: 1,368

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan-June & July-Dec. 2017	Sample biannual due to new well.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350730

PWS NAME: LAKEVIEW TERRACE RET. SERVICES

POPULATION: 330

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350744

PWS NAME: LAKESIDE VILLAGE I

POPULATION: 280

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring for Di(2-ethylhexyl)phthalate</i>	1st Quarter 2017 (Annual)	Sample at POE annually until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350760

PWS NAME: LITTLE LAKE HARRIS SHORES

POPULATION: 297

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2021 (test)	May test same site tested 10/21/03 if suitable: RECREATION CENTER. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171.. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350783

PWS NAME: YOUTH WITH A MISSION

POPULATION: 100

2017 DRINKING WATER MONITORING REQUIREMENTS

(Changed from TNC to CWS effective 7/1/2016)

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly (3 raw, 1 distribution)	Disinfectant residuals must be reported individually on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228 minimum</i>) North Water Treatment Plant	1/17, 4/17, 7/17, & 10/17	Due to missed 4 th quarter 2016 monitoring at the North WTP, restart quarterly monitoring. Sample at each POE.
Radiologicals (<i>Gross Alpha & Radium 228 minimum</i>) South Water Treatment Plant	1/17, 4/17	Sample at POE for four consecutive quarters. 7/16 sample counts as the first quarter.
Volatile Organic Contaminants (VOCs) North Water Treatment Plant	1/17, 4/17, 7/17, & 10/17	Due to missed 4 th quarter 2016 monitoring at the North WTP, restart quarterly monitoring. Sample at each POE.
Volatile Organic Contaminants (VOCs) South Water Treatment Plant	1/17, 4/17	Sample at POE for four consecutive quarters. 7/16 sample counts as the first quarter.
Synthetic Organic Contaminants (SOCs) North Water Treatment Plant	1/17, 4/17, 7/17, & 10/17	Due to missed 4 th quarter 2016 monitoring at the North WTP, restart quarterly monitoring. Sample at each POE.
Synthetic Organic Contaminants (SOCs) South Water Treatment Plant	1/17, 4/17	Sample at POE for four consecutive quarters. 7/16 sample counts as the first quarter.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling) <i>Collect 5 samples</i>	Jan – Jun 2017	Sample in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350825

PWS NAME: MID-FLORIDA LAKES YACHT CLUB

POPULATION: 3,065

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June - Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350842

PWS NAME: MOLOKAI MOBILE COMMUNITY

POPULATION: 500

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring for Xylenes (total)</i>	3rd Quarter 2017	Sample at POE annually during the 3 rd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue annual testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. . This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350846

PWS NAME: MONTVERDE MOBILE HOME SD

POPULATION: 800

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring for Total Xylene</i>	April-June 2017	Sample at POE annually until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan per 7/19/11 email guidance. Note that requirements have changed from last year’s schedule.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350847

PWS NAME: MONTVERDE WATER DEPT

POPULATION: 1,198

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. (2 WTPs)
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue Annual testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350851

PWS NAME: MORGAN'S MHP & FISH CAMP

POPULATION: 30

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Total Xylenes Special Monitoring</i>	Jan-March 2017	Sample at the POE annually until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350852

PWS NAME: MORNINGVIEW SUBDIVISION

POPULATION: 123

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350900

PWS NAME: OAK LANE TRAILER PARK

POPULATION: 89

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350907

PWS NAME: OAK SPRINGS MHP

POPULATION: 993

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350980

PWS NAME: PALM GARDENS MHP

POPULATION: 75

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350981

PWS NAME: PALM MOBILE HOME ESTATES

POPULATION: 158

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3350984

PWS NAME: PALM SHORES RV RESORT

POPULATION: 80

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) sampling 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351009

PWS NAME: PICCIOLA ISLAND SUBDIVISION

POPULATION: 374

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos sampled 9/20/11 at 5127 ALBERT RD.-LOT 9. Use Form 62-555.900(10), F.A.C., Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351021

PWS NAME: PINEY WOODS S/D – 2 WPS

POPULATION: 630

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Total Xylenes (special monitoring)</i>	April-June 2017	Begin annual monitoring at the POE of WTP #2 during the 2 nd quarter, until further notice.
<i>Ethylbenzene (special monitoring)</i>	April-June 2017	Begin annual monitoring at the POE of WTP #2 during the 2 nd quarter, until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351022

PWS NAME: FLORIDIAN GARDENS RESORT

POPULATION: 27

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at the POE annually
Primary Inorganics	2018	Sampling was missed in 2015. Makeup samples taken 11/3/16. Sample next in 2018 at the POE.
Secondaries	2018	Sampling was missed in 2015. Makeup samples taken 11/3/16. Sample next in 2018 at the POE.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sampling was missed in 2015. Makeup samples taken 11/3/16. Sample next in 2018 at the POE.
Volatile Organic Contaminants (VOCs)	2018	Sampling was missed in 2015. Makeup samples taken 11/3/16. Sample next in 2018 at the POE.
Synthetic Organic Contaminants (SOCs)	2018	Sampling was missed in 2015. Makeup samples taken 11/3/16. Sample next in 2018 at the POE.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	*	Please contact The Department to determine your sampling schedule for these contaminants.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	*	Please contact The Department to determine your sampling schedule for these contaminants.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm . Please contact The Department for your CCR requirements for 2017.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: **3351062**

PWS NAME: **RAVENSWOOD**

POPULATION: **161**

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring for Total Xylenes</i>	2 nd Quarter 2017 (Annual)	Sample at POE annually during the 2 nd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351115

PWS NAME: SANDPIPER MOBILE HOME MANOR

POPULATION: 270

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years. The annual monitoring for ethylbenzene may stop; there were no detects in 2009, 2010, 2011. This is per Rule 62-550.515(3)(b), F.A.C.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351182

PWS NAME: SILVER LAKE ESTATES

POPULATION: 2,400

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals. (“35027 Haines Creek” location)
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351205

PWS NAME: SKYCREST SUBDIVISION

POPULATION: 295

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351254

PWS NAME: SPRINGS PARK AREA

POPULATION: 334

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021 (test)	May sample at 7/8/03 site if suitable: HYD. ON MAGNOLIA LANE. Use Asbestos Sampling Plan Form 62-555.900(10), F.A.C. (Sections I & III).
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351331

PWS NAME: TARA VILLAGE

POPULATION: 283

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring for Total Xylene</i>	3rd Quarter 2017 (Annual)	Sample at POE annually during the 3rd Quarter (July-Sept) until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351335

PWS NAME: RIDGECREST RESORT COMMUNITY

POPULATION: 476

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Total Xylenes (Special monitoring)</i>	April-June 2017	Sample at the POE annually during the 2 rd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351348

PWS NAME: THE HILL

POPULATION: 90

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351366

PWS NAME: **TIMBER VILLAGE MHP**

POPULATION: 176

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special monitoring for tot Xylenes</i>	Jan-March 2017	Begin quarterly monitoring during the 1 st quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171.. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351376

PWS NAME: TORCHLIGHT TRAILER PARK

POPULATION: 50

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351421

PWS NAME: VALENCIA TERRACE

POPULATION: 750

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue Annual sampling July-Sept 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351426

PWS NAME: VENETIAN VILLAGE

POPULATION: 440

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351464

PWS NAME: WESTERN SHORES SUBDIVISION

POPULATION: 963

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351555

PWS NAME: SUNLAKE ESTATES

POPULATION: 637

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351561

PWS NAME: CYPRESS CREEK

POPULATION: 100

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351563

PWS NAME: WOODLANDS CHURCH LAKE

POPULATION: 286

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample for VOCs at ea. POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July-Sept 2018	Begin <u>reduced</u> (triennial) testing 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351564

PWS NAME: CITRUS CIRCLE MH S/D

POPULATION: 88

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3351567

PWS NAME: BAYWOOD CONDOMINIUMS

POPULATION: 200

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring for Total Xylene</i>	April – June 2017	Sample at each POE April – June annually until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897-4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354005

PWS NAME: COVE WATER SYSTEM

POPULATION: 300

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring for Total Xylene</i>	July – September 2017 (Annual)	Sample at each POE July – September annually until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354010

PWS NAME: WATER OAK COUNTRY CLUB ESTATES

POPULATION: 1,539

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354027

PWS NAME: CENTURY ESTATES UTILITIES

POPULATION: 343

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354028

PWS NAME: SHANGRI LA BY THE LAKE

POPULATION: 328

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue quarterly monitoring due to an MCL exceedance in 2015, until further notice. Collect a dual sample set from the “Sewer Plant” location.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354038

PWS NAME: THE MEADOWS OF ASTATULA

POPULATION: 122

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354043

PWS NAME: BRENDENWOOD WATER SYSTEM

POPULATION: 130

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354044

PWS NAME: LAKE JOANNA ESTATES

POPULATION: 140

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Total Xylenes (Special Monitoring)</i>	Jan.-March 2017	Continue annual monitoring at the POE during the 1 st quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals. Submit Stage 2 D/DBP Monitoring Plan by 5/31/14.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354053

PWS NAME: CITRUS COVE SUBDIVISION

POPULATION: 130

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354054

PWS NAME: LAKE GRIFFIN ISLES (2WPS)

POPULATION: 1212

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 2 WPs in system
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354055

PWS NAME: WATERWOOD SUBDIVISION

POPULATION: 295

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354104

PWS NAME: CLERBROOK RV RESORTS (2WPS)

POPULATION: 3142

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017 Plant 1 & 2	Sample at each POE* every year. 2 WPs in system
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals. (Lot #420)
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354106

PWS NAME: BEE'S RV RESORT

POPULATION: 158

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan. Testing is required again in 2012 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354110

PWS NAME: LAKESIDE VILLAGE II

POPULATION: 191

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354112

PWS NAME: SUMMIT CHASE VILLAS

POPULATION: 770

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354142

PWS NAME: COUNTRY LIFE FAMILY PARK

POPULATION: 215

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354644

PWS NAME: PINE HARBOUR WATER UTILITY

POPULATION: 132

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Total Xylenes (Special Monitoring)</i>	July-Sept. 2017	Begin annual monitoring at the POE during the 3 rd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354646

PWS NAME: ORANGE LAKE MH COMMUNITY

POPULATION: 615

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354647

PWS NAME: FOUR LAKES AND HARBOR OAKS

POPULATION: 228

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite Quarterly nitrate	2017	Sample at each POE* every year. Test nitrate quarterly until further notice; nitrite annually.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354651

PWS NAME: HAINES CREEK RV PARK

POPULATION: 215

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running ann.avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring</i> Xylenes (total)	3rd Quarter 2017 (Annual)	Sample at each POE annually during the 3 rd Quarter (June-Sept) until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	On reduced annual monitoring. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354653

PWS NAME: PENNBROOKE FAIRWAYS

POPULATION: 2488

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue quarterly monitoring for TTHMs and HAA5s. Sample at BOTH locations, taking dual sample sets, until further notice.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354655

PWS NAME: CARLTON PALMS EDUCATIONAL CENTER

POPULATION: 145

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354656

PWS NAME: LAKE IDLEWILD ESTATES

POPULATION: 170

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354657

PWS NAME: **DIAMOND POINTE**

POPULATION: 250

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact Monica Busam at (407) 897- 4171. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354660

PWS NAME: SILVER OAKS SUBDIVISION

POPULATION: 123

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Total Xylene (Special monitoring)	April-June 2017	Sample at the POE annually during the 2 nd quarter until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>routine</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354661

PWS NAME: PICCIOLA LANDING

POPULATION: 125

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354662

PWS NAME: LAKE BEAUCLAIRE S/D

POPULATION: 98

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample for VOCs at ea. POE every 3 yrs.
Special Monitoring for Total Xylene and Ethylbenzene	2nd Quarter 2017 (Annual)	Sample at POE during the 2 nd quarter (April-June) annually until further notice.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan-June 2017	Sample January-June 2017 due to copper exceedance. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354664

PWS NAME: TREASURE COVE

POPULATION: 126

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue <u>increased</u> (quarterly) testing until further notice. Collect dual sample sets from both locations.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354687

PWS NAME: RAIN TREE HARBOR

POPULATION: 265

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite Quarterly nitrate	2017	Sample at ea. POE ev. year*. Test for nitrate quarterly until further notice, nitrite annually.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample for SOCs at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June –September 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354688

PWS NAME: LAKE YALE ESTATES

POPULATION: 101

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354695

PWS NAME: LAKE SAUNDERS

POPULATION: 161

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354697

PWS NAME: GRAND TERRACE S/D

POPULATION: 256

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2015. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354701

PWS NAME: WEDGEWOOD S/D

POPULATION: 980

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354781

PWS NAME: HARBOR HILLS – 2 WTPS

POPULATION: 1219

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*. 2 WPs in system
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354836

PWS NAME: **Bishops Gate Property Company, LLC**

POPULATION: 244

2017 DRINKING WATER MONITORING REQUIREMENTS

[[New Well Cleared for service 9/4/15 increased monitoring due to new source]]

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average. (2 raw and 2 distribution)
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE annually due to new source.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	July – Dec. 2018 Jan. – June 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354867

PWS NAME: QUAIL RIDGE ESTATES

POPULATION: 240

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354869

PWS NAME: LEESBURG/HIGHLAND LAKES

POPULATION: 2442

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	1 st & 3 rd quarter 2017	Continue <u>routine</u> (annual) testing July – Sept. 2017 & Jan-March 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354877

PWS NAME: PALISADES COUNTRY CLUB

POPULATION: 1967

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue annual testing July – Sept. 2017. Collect 1 dual sample set from each location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354886

PWS NAME: HOLIDAY HAVEN (CONSEC.)

POPULATION: 295

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	Not Required	Sample at each POE every year*.
Primary Inorganics	Not Required	Sample at each POE every 3 years.
Secondaries	Not Required	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Not Required	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	Not Required	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	Not Required	Sample at each POE every 3 years.
Stage 1 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Not Required	Sample at MRT** location(s) – Report disinfectant residual.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020 - 2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354926

PWS NAME: LAKES OF LADY LAKE EXEC. GOLF COURSE

POPULATION: 100

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354929

PWS NAME: LEESBURG/ROYAL HIGHLANDS

POPULATION: 3,246

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354935

PWS NAME: THE PARK AT WOLF BRANCH OAKS

POPULATION: 406

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354938

PWS NAME: BLACK BEAR RESERVE

POPULATION: 625

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354943

PWS NAME: POMEROSA PARK

POPULATION: 53

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-September 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354944

PWS NAME: LAS COLINAS

POPULATION: 260

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354945

PWS NAME: FAIRWAYS AT MT. PLYMOUTH

POPULATION: 843

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> annual testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354953

PWS NAME: EUSTIS EASTERN WTP

POPULATION: 2,180

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Oct.-Dec. 2017	Begin <u>reduced</u> (annual) testing Oct. – Dec. 2017 (TTHMs) and Jan-March (HAA5s). Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354954

PWS NAME: HEATHROW COUNTRY ESTATES

POPULATION: 819

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>reduced</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354956

PWS NAME: PINE ISLAND

POPULATION: 40

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan. Testing is required again in 2012 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3354969

PWS NAME: COLINA BAY

POPULATION: 175

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”) Complete a bacte sampling plan	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs) – to be completed by a certified operator	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results/plan due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan. – June 2018	Test in accordance with the most recently approved lead and copper sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**MRT= Maximum residence time. Sample at one designated MRT distribution location per plant in accordance with the Stage 1 D/DBP Monitoring Plan.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**