



Florida Department of Environmental Protection Northeast District

PWS ID: 2380178
PWS Name: CEDAR KEY WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	6 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec 2018 at HODGSON & JERNIGAN AVE SM1 and GULF BLVD & HODGES AVE SM2 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1500
Monitoring Frequency	Monthly
Raw Sampling	4-log: Raw not required, recommend quarterly
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2380188
PWS Name: MANATEE UTILITIES

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at NW 110TH ST. AND NW 92ND CT for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	290
Monitoring Frequency	Monthly
Raw Sampling	4-log: Raw not required, recommend quarterly
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2380189
PWS Name: CHIEFLAND WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at SW 18TH AVE & SW 5TH ST for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	2031
Monitoring Frequency	Quarterly
Raw Sampling	4-log: Raw not required, recommend quarterly
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2380387

System Type: Community

PWS Name: FOWLERS BLUFF WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 15677 NW 46TH LANE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	300
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2380854
PWS Name: OTTER CREEK

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 273 SW 6 th Lane for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	135
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381178
PWS Name: BRONSON WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		DEHP (SOC)	Annually	Jul-Sep 2018	Sample at <u>each</u> Point of Entry to the distribution
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at HYDRANT AT AGRICULTURE BUILDING for TTHMs only and HOSE BIB AT BRONSON FIRE DEP for HAA5s only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1125
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381208

System Type: Community

PWS Name: UNIVERSITY OAKS MHP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at CORNER OF 10TH CT AND NE 112TH LANE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	369
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381409
PWS Name: FIMC HIDEAWAY INC

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	Triennially	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 11496 NW 112TH TERRACE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	275
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381411
PWS Name: FANNING SPRINGS WS

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at TRI COUNTY NURSING HOME MEN'S for TTHMs only and HISTORICAL PARK BATHROOM for HAA5s only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	900
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381421

System Type: Non-Transient Non-Community

PWS Name: IMAGINATION STATION I

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019	at BATHROOM SINK for TTHMs and HAA5s**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	65
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381456
PWS Name: NATURE COAST MIDDLE SCHOOL

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Staff Sink for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	40
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381459
PWS Name: CLYATT HOUSE LEARNING CENTER

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at WEST BATHROOM for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	216
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381465
PWS Name: LEVY COUNTY SOLID WASTE MGMT

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at WASTE TIRE for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	36
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2381469

System Type: Non-Transient Non-Community

PWS Name: VISION CHRISTIAN ACADEMY

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate	Quarterly	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Nitrite	Annually	2018	
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at BATHROOM SINK - PORTABLE #2 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	35
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 6382055
PWS Name: WILLISTON WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides WTP #1	9 years	2024	
		Radionuclides WTP #2	6 years	2018	
		Radionuclides WTP #3	9 years	2018	
		Radionuclides WTP #4	9 years	2022	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at 2089 SW 7TH ST. for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological Monitoring

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1250
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 6382056
PWS Name: INGLIS WATER DEPT.

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at 9 NOTTINGHAM LN for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1500
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 6382108

System Type: Community

PWS Name: INGLEWOOD ESTATES MH S/D

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 19481 SE 59TH CT for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	150
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 6382116
PWS Name: YANKEETOWN WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at 6241 HARMONY LANE TOWNHALL RESTROOM for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	711
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 6384621

System Type: Non-Transient Non-Community

PWS Name: FLORIDA SHERIFFS YOUTH RANCH CARUTH CAMP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at STAFF SINK for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at each Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	200
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.
-