



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420095

PWS NAME: BLUE SKIES ESTATES

POPULATION: 195

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years for SOCs.
Special Monitoring <i>Annual heptachlor & heptachlor epoxide</i>	3 rd qtr. 2017	Test for heptachlor and heptachlor epoxide annually until there are no detections for 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT 134) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June - Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420124

PWS NAME: BUCKSKIN LAKE MANOR

POPULATION: 203

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (24525 NE 189th St) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420162

PWS NAME: CEDAR HILLS

POPULATION: 1404

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L-2 (3400 SE 30th Terr.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420216

PWS NAME: CLIFTWOOD MOBILE HOME PARK

POPULATION: 54

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each <u>POE</u> * every year.
Primary Inorganics	2018	Sample at each <u>POE</u> every 3 years.
Secondaries	2018	Sample at each <u>POE</u> every 3 years.
Volatile Organic Contaminants (VOCs)	Jan. – March 2017	Sample at each <u>POE</u> yearly.
Synthetic Organic Contaminants (SOCs)	Jan. – March 2018	Sample at each <u>POE</u> every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Jan. – March 2021	Sample at each <u>POE</u> every 6 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect one dual sample set for TTHMs and HAA5s from L-1 (Club house dish sink) location. Report disinfectant residuals
Asbestos	2024	Certification or results with plan due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	Jan.-June 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420340

PWS NAME: EMIL – MAR SUBDIVISION

POPULATION: 270

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate (quarterly) and Nitrite	2017	Sample at each POE* every year. Test quarterly for nitrate and annually for nitrite.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect one dual sample set for TTHMs and HAA5s from L-1 (3604 NE 22 nd Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420386

PWS NAME: LOWELL CORRECTIONAL INSTITUTION ANNEX

POPULATION: 2800

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (annual) testing at <u>2 sites</u> (Camp Jones Lift Station and Bld. 31642102) for both TTHMS and HAA5 (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420074

PWS NAME: BELLEVIEW, CITY OF (2 WPS)

POPULATION: 8,433

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 2 WPs in sys.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Routine (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (10868 SE 73rd Ct.) and L2 (12066 SE 60th Ave.) location. Report disinfectant residuals.
Asbestos	2020	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June - Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424897

PWS NAME: STONECREST SUBDIVISION (4WPS)

POPULATION: 8,128

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017 ea. POE	Sample at each POE* every year.
Primary Inorganics	2017 ea. POE	Sample at each POE every 3 years.
Secondaries	2017 ea. POE	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017 ea. POE	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017 ea. POE	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017 ea. POE	Sample at each POE for 2 quarters every 3 years; take samples at least 60 days apart.
Special Monitoring <i>Di(2-Ethylhexyl)phthalate</i>	April – June 2017	Annual special monitoring. Sample 2017 and 2018.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (12701 SE Sunset Harbor Rd.) location. Report disinfectant residuals.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425020

PWS NAME: SPRUCE CREEK GOLF AND COUNTRY CLUB

POPULATION: 6,745

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 2 WPs in sys.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Reduced (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (11307 SE 128 th Pl.) location. Report disinfectant residuals.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424652

PWS NAME: SPRUCE CREEK UTILITY CO. INC.

POPULATION: 7,732

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; sample at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 4 Blk 19) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420387

PWS NAME: MARION CORRECTIONAL INSTITUTION

POPULATION: 1,500

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly 2017	<u>Increased</u> (quarterly) testing at <u>2 sites</u> (Wastewater shop sink and Horse Farm NW corner stable) for both TTHMS and HAA5 (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420408

PWS NAME: SALT SPRINGS VILLAGE

POPULATION: 342

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (25285 NE 136 Loop Sales Office) location. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420411

PWS NAME: FLOYD CLARK SUBDIVISION

POPULATION: 224

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (3611 NE 15th Ave.) location. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420922

PWS NAME: OCALA, CITY OF (2 WTPS)

POPULATION: 50,924

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs) <i>Submit annual Acrylamide & Epichlorohydrin letter in accordance with Rule 62-550.315(a)</i>	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year: WP1 & WP2.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	4 locations 3rd quarter 2017	Collect 4 dual samples for TTHMs and HAA5s from L1-(1915 SW 80th Ave), L2 -(5400 SW College Rd), L3 -(4741 SE 19th Ave) and L4 - (4200 W Anthony Rd.). Report disinfectant residuals.
Asbestos	2020	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June - Sept. 2017	Test in accordance with the most recently approved sampling plan per 7/18/11 email guidance. Testing was last conducted in 2014.
Water Quality Parameters (WQPs)	June – Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at WP1 at least every two weeks per Optimal WQP Approval Letter. WP2 is to be tested at least every two weeks when well 6 is supplying water to the distribution system.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. **Reports should be submitted through our FTP site at****

ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. **Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421197

PWS NAME: SILVER SPRINGS SHORES (5 WPs)

POPULATION: 16,436

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* ev. year. 5 WPs in system.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	2 nd and 3 rd Quarter – 2017 <i>See Comments</i>	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L3 -(6455 E. Hwy. 40) during the 2nd quarter and 1 dual sample from L4 – (879 Oak Rd.) during the 3rd quarter . Report disinfectant residuals.
Asbestos	2020	May sample at site tested 3/19/02 if still suitable: 9433 SE MARICAMP RD. Use Asbestos Sampling Plan Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6421144

PWS NAME: MARION OAKS SUBDIVISION (5 WTPS)

POPULATION: 19,401

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 5 WPs in system.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 1 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Sept. - Dec. 2017 (annually)	<u>Reduced</u> (annual) testing. Collect 2 dual sample for TTHMs and HAA5s from L2 (21 Marion Oaks Ln.) and L4 – (13581 SW 17th Ct Lift Station @ Sonny's) locations. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424619

PWS NAME: ON TOP OF THE WORLD (2 WPS)

POPULATION: 10,195

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include info. about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* ev. yr. 2 active WPs in sys.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July - Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 2 dual sample for TTHMs and HAA5s from L1 -(7150 SW 96 th Ct.) and L2 – (8305 SW 79 th Cir.) location. Report disinfectant residuals.
Asbestos	2020	Test or asbestos free certification required. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424630

PWS NAME: OAK RUN ESTATES (6 WTPS)

POPULATION: 11,760

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 6 active WPs
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Special Monitoring <i>Heptachlor and Heptachlor Epoxide</i> (<i>Pine Run Estates WP2</i>)	2 nd Quarter 2017	Continue monitoring the Pine Run Estates WP annually for <i>Heptachlor and Heptachlor Epoxide</i> until there are 3 years without detections.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	2 nd and 4 th Quarter - 2017	Reduced (annual) testing. Collect 2 dual sample for TTHMs and HAA5s from L1 -(8585 SW SR 200) during the 4 th quarter and L4 – (5870 SW 95 th St.) during the 2 nd quarter. Report disinfectant residuals.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420419

PWS NAME: FORT KING FOREST

POPULATION: 316

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (400 SE 49 th Ave.). Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420456

PWS NAME: GOLDEN HOLIDAY MHP (2WPS)

POPULATION: 609

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year.
Primary Inorganics	2018-EA.WP	Sample at each POE every 3 years.
Secondaries	2018-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018-EA.WP	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1(2920 NW 18th St.) and L2 (Golden Holiday WWTF) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: **3420034**

PWS NAME: **ANTHONY ELEMENTARY SCHOOL**

POPULATION: **349**

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019 (triennially)	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Front Hall/Men’s Room) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420170

PWS NAME: ASSOCIATED GROCERS OF FLORIDA

POPULATION: 124

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Gator Tank Restroom Sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420323

PWS NAME: EAST MARION ELEMENTARY

POPULATION: 846

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 1 Room 134) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June - Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420374

PWS NAME: FESSENDEN ELEMENTARY

POPULATION: 639

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017 (annually)	Reduced (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 5 Room 4) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420718

PWS NAME: LAKE WALDENA RESORT

POPULATION: 154

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Special Monitoring <i>Dalapon</i>	Quarterly	Sample Dalapon quarterly until further notice due to detect in 9/2016.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT 153) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June- Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420719

PWS NAME: LAKE WEIR MIDDLE SCHOOL

POPULATION: 1,469

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017 (annually)	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 4 Room 123) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420884

PWS NAME: NORTH MARION HIGH SCHOOL

POPULATION: 1,701

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 1 Room 55) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420886

PWS NAME: NORTH MARION MIDDLE SCHOOL

POPULATION: 1,018

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 1 Room 82) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420927

PWS NAME: OCALA JAI-ALAI

POPULATION: 250

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (east downstairs men’s restroom) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420937

PWS NAME: OCKLAWAHA BRIDGE BAPTIST CHURCH

POPULATION: 68

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen big dish sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420965

PWS NAME: OUR LUCAYA MHP

POPULATION: 93

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July-Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT 11) location. Report disinfectant residuals.
Asbestos3420965	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan – June and July – Dec 2017	Collect 5 samples biannually due to lead exceedance in 2016. Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421124

PWS NAME: BELLEVIEW SANTOS ELEMENTARY

POPULATION: 837

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from 21 (Cafeteria Sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421240

PWS NAME: SPARR ELEMENTARY SCHOOL

POPULATION: 569

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 7 Room 3) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421494

PWS NAME: SHADY ACRES MOBILE HOME PARK

POPULATION: 33

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year..
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT 26) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan. Testing is required again in 2013 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424229

PWS NAME: BUILDING BLOCKS OF OCALA

POPULATION: 100

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan – June 2017	Collect 5 samples during January – June 2017 due to lead AL exceedance in September 2016. Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424623

PWS NAME: PHOENIX HOUSE

POPULATION: 120

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lobby’s Men’s room) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424634

PWS NAME: THE SPRINGS RV RESORT

POPULATION: 250

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT J40) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424661

PWS NAME: FOREST CENTER SHOPPING CENTER

POPULATION: 200

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Regions Bank Men’s room sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424663

PWS NAME: OCALA SPRINGS ELEMENTARY

POPULATION: 851

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 3 Room 12) and L2 (Bldg. 4 Room 7) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424670

PWS NAME: ADVANCED DISPOSAL

POPULATION: 107

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 0 Restroom sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June–Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424671

PWS NAME: SOULS HARBOR CHRISTIAN ACADEMY

POPULATION: 190

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424693

PWS NAME: SOUTHEAST MILK

POPULATION: 60

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Office restroom) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424694

PWS NAME: SHADY HILL ELEMENTARY

POPULATION: 745

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 3 Room 9) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424726

PWS NAME: DELTA LABORATORIES

POPULATION: 40

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Special Monitoring <i>Total Xylene</i>	Quarterly	Sample at each POE quarterly until further notice
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (QC lab sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424787

PWS NAME: RING POWER CORPORATION

POPULATION: 80

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Paint shop restroom sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424790

PWS NAME: BELLEVIEW PLAYLAND DAYCARE

POPULATION: 168

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424803

PWS NAME: TOWNLEY MANUFACTURING COMPANY

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Pattern shop restroom sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424812

PWS NAME: FORT MCCOY MIDDLE SCHOOL

POPULATION: 1273

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 13 Room 14) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424817

PWS NAME: ABC CHILDREN'S COUNTRY CLUB

POPULATION: 129

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen Sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424818

PWS NAME: RCMA ANTHONY DAYCARE

POPULATION: 50

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids</i> (5)	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424828

PWS NAME: FLORIDA STATE FIRE COLLEGE

POPULATION: 200

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Special Monitoring <i>Total Xylenes</i>	March - June 2017	Special annual monitoring for <i>total xylene</i>
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bookstore men’s restroom sin) location. Report disinfectant residuals
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424831

PWS NAME: LHOIST NORTH AMERICA

POPULATION: 56

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Men’s restroom sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424835

PWS NAME: WINGS OF FAITH FELLOWSHIP

POPULATION: 26

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. #2 SE H/B) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424851

PWS NAME: GOLDEN FLAKE SNACK FOODS

POPULATION: 100

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Warehouse Men’s RR) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424861

PWS NAME: LAKE GEORGE RANGER STATION

POPULATION: 60

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Special Monitoring <i>Di(2-ethylhexyl)phthalate</i>	Oct. – Dec. 2017	Special annual monitoring for <i>Di(2-ethylhexyl)phthalate</i> .
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Ranger’s office restroom) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424895

PWS NAME: HARBOUR VIEW ELEMENTARY

POPULATION: 785

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 3 Room 12) location. Report disinfectant residuals
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424902

PWS NAME: NORTH TRANSPORTATION CENTER

POPULATION: 339

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year..
Primary Inorganics	2019	Sample at each POE every 3 years.
Special Monitoring Lead	Quarterly	Special quarterly monitoring for Lead. Sample at each POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2016	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Office men’s restroom) location. Report disinfectant residuals. 1 dual sample. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424942

PWS NAME: AMERICAN PANEL CORPORATION

POPULATION: 100

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (“A” restroom sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424968

PWS NAME: REDDICK ELEMENTARY

POPULATION: 620

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Test 4 quarters in 2017	Sample at the POE.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 10 Room 3) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424972

PWS NAME: OCALA SPRINGS PLAZA

POPULATION: 59

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Ladies Room – Seafood restaurant) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424983

PWS NAME: SKATE MANIA

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Office outside hose bib) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424989

PWS NAME: MARION YOUTH ACADEMY

POPULATION: 60

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 - (Rear hose bib) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424996

PWS NAME: PETRO STOPPING CENTER

POPULATION: 318

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Wendy’s Restroom Sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424998

PWS NAME: HEART OF FLORIDA YOUTH RANCH

POPULATION: 54

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Admin Office Ladies Room) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425007

PWS NAME: SUNCOAST INSULATORS

POPULATION: 32

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (East hose bib) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425028

PWS NAME: BRIGHT BEGINNINGS LEARNING CENTER

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (First grade room sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425036

PWS NAME: THE REFUGE A HEALING PLACE

POPULATION: 90

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2025	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (The Hive- Front HB tap) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425042

PWS NAME: HARLEY DAVIDSON OF OCALA

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Ladies showroom sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425044

PWS NAME: GOOD SHEPHERD PRESBYTERIAN CHURCH

POPULATION: 230

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every year.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Room 8742 Science lab sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425056

PWS NAME: THE CHURCH TRIUMPHANT

POPULATION: 350

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Ladies room sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425069

PWS NAME: UNIV. OF FL. PLANT SCIENCE RESEARCH CENTER POPULATION: 27

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2025	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 7515 South hose bibb) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425071

PWS NAME: SUMMERFIELD POST OFFICE

POPULATION: 45

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (NW Outside tap) location. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June - Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425076

PWS NAME: PHOENIX WOOD PRODUCTS

POPULATION: 45

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Outside tap) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425109

PWS NAME: DECONNA ICE CREAM

POPULATION: 30

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Loading Dock w. H/B) location. Report disinfectant residuals
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425121

PWS NAME: RCMA DAYCARE

POPULATION: 85

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Preschool left sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	January-June 2017 and July- Dec. 2017	<u>Biannual Monitoring</u> . Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425150

PWS NAME: ADENA BEEF PROCESSING FACILITY

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	2022	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Gross Alpha reduced to every 9 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Mechanical room PPZ) location. Report disinfectant residuals
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	Jan. - June 2017 and July – Dec. 2017	<u>Biannual monitoring.</u> Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID: 3425163

PWS NAME: MARION COUNTY TRACK & CARD ROOM

POPULATION: 90

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each <u>POE</u> * every year.
Primary Inorganics	2019	Sample at each <u>POE</u> every 3 years.
Volatile Organic Contaminants (VOCs)	1-3/2017	Sample at each <u>POE</u> for 4 th consecutive quarter of initial monitoring.
Special VOC Monitoring <i>Total Xylene</i>	Quarterly	Test quarterly for <i>Total Xylene</i> until there are no detections for 4 consecutive quarters.
Special VOC Monitoring <i>Ethylbenzene</i>	Quarterly	Test quarterly for <i>Ethylbenzene</i> until there are no detections for 4 consecutive quarters.
Synthetic Organic Contaminants (SOCs)	1-3/2017	Sample at each <u>POE</u> for 4 th consecutive quarter of initial monitoring.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	1-3/2017	Sample at each <u>POE</u> for 4 th consecutive quarter of initial monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July- Sept. 2019	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bar sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or test results with plan due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling) Complete a Lead and Copper Sampling Plan	June – Sept 2019	Test in accordance with a recently <u>approved</u> sampling plan every three years.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6420818

PWS NAME: CLASSIC OAKS

POPULATION: 100

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Office Sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6421777

PWS NAME: OCALA NORTH RV PARK

POPULATION: 50

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (WWTF Hose Bib) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424622

PWS NAME: DUNNELLOH HIGH/ELEM SCHOOL

POPULATION: 1,000

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L2 (Bldg. 10 Room 6) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424633

PWS NAME: RIVERLAND BAPTIST CHURCH

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT 134) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424635

PWS NAME: CIRCLE SQUARE CENTER

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Doctor) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424636

PWS NAME: QUEEN OF PEACE CATHOLIC CHURCH

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Sacristy Sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Florida Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

PWS ID #: 6424662

PWS NAME: DUNNELLON AIRPORT

POPULATION: 65

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample for VOCs at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	2025	Sample at the POE.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019 (Triennially)	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 dual sample, both TTHM and HAA5 at L1 - 11611 SW 147 th Circle. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved <u>sampling plan</u> .

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424712

PWS NAME: U.S. POST OFFICE PADDOCK STATION

POPULATION: 90

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Break Room) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424726

PWS NAME: 103RD STREET PLAZA

POPULATION: 200

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2014 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Unit 11 (Quest Diagnostic)) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424729

PWS NAME: ROMEO ELEMENTARY SCHOOL

POPULATION: 100

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	2025	Sample at the POE every 9 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 3 Room 9) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424746

PWS NAME: KINDEROO CHILDREN'S ACADEMY

POPULATION: 137

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen Sink) location. Report disinfectant residuals
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District
2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424778

PWS NAME: RCMA (BLESSED TRINITY/GUADALUPANA)

POPULATION: 35

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. 4 laundry sink) location. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424798

PWS NAME: RAINBOW SPRINGS FIRE STA.

POPULATION: 32

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2006 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT 134) location. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan. June 2017 – July- Dec 2017	<u>Biannual monitoring</u> . Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424801

PWS NAME: KUNAL II, LLC

POPULATION: 125

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2022	Sample at each POE every 6 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (7890 NW 47th Ave L/S H/B) location. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Lead and Copper (Tap Sampling)	June—Sept. 2017	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420484

PWS NAME: MILL DAM MHP

POPULATION: 155

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 26 Hose Bib) Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420509

PWS NAME: HAZEL GARDENS MHP

POPULATION: 66

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 26 Hose Bib) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420531

PWS NAME: WANDERING OAKS RV RESORT

POPULATION: 122

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot#100) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420533

PWS NAME: HI – CLIFF ESTATES

POPULATION: 1008

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (740 S.R. 56th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June - Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420608

PWS NAME: FORE ACRES

POPULATION: 1,678

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Reduced (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L2 (5601 NE 22 Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021 (test)	May sample at site tested 7/10/03 if still suitable: 4713 NE 21ST CT. Use Asbestos Sampling Plan Form 62-555.900(10), F.A.C. Fill out Sections I & III; submit form with test results.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420761

PWS NAME: LITTLE LAKE WEIR SUBDIVISION

POPULATION: 963

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	<u>Reduced</u> (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L2 (9499 SE 140th PI.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420763

PWS NAME: LIVE OAKS MHP

POPULATION: 217

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (Triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT #882) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420781

PWS NAME: EDGEWOOD MHP

POPULATION: 42

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Special Monitoring <i>Heptachlor Epoxide</i>	2 nd Quarter 2017	Special annual sampling for heptachlor and heptachlor epoxide. Sample annually during the 2 nd quarter until further notice.
Special Monitoring <i>Picloram</i>	Quarterly	Special quarterly sampling for picloram. Test on the 1 st and 2 nd quarter of 2017.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (LOT 12) location. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan. All water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420805

PWS NAME: MARIE'S MHP

POPULATION: 88

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (Triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #19) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420870

PWS NAME: NELSON'S FISH CAMP

POPULATION: 210

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Special Monitoring <i>Total Xylenes</i>	3 rd Quarter 2017	Test annually during the 3 rd quarter (July – September) due to a detect in 2012.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes/ Haloacetic Acids (5)</i>	July-Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 19) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan. All systems are now testing per DEP's standard monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420904

PWS NAME: OAK PARK VILLAGE

POPULATION: 95

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (3145 SE 39 th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2016 & August 10, 2016	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420916

PWS NAME: OAKWOOD MOBILE MANOR

POPULATION: 220

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot# 22-A) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420924

PWS NAME: OCALA EAST VILLAS

POPULATION: 608

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L2 (6610 NE 66 Ct.) location. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3420939

PWS NAME: OCKLAWAHA WATER WORKS (2 WTPS)

POPULATION: 816

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years. It is recommended that both WPs be tested in the same year.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (14635 SE 134th St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421018

PWS NAME: PINE RIDGE ESTATES

POPULATION: 732

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (annual) testing Collect 2 dual sample for TTHMs and HAA5s from L1 (5225 NE 9th Ln.) AND L2 (4700NE 13th St) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421098

PWS NAME: ROLLING GREENS

POPULATION: 2,498

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year. System has 2 wells, 2 points of chlorination, and only 1 POE to dist. Collect sample at 1 POE at a time when both wells are contributing to the tank.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (1415 North Clubhouse) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421118

PWS NAME: SANDY ACRES

POPULATION: 570

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Reduced (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (1415 North Clubhouse) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421159

PWS NAME: SHARPES FERRY MANUFACTURED HOME CMNTY

POPULATION: 207

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #31A) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District
2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421201

PWS NAME: OAKCREST VILLAS

POPULATION: 386

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Increased Monitoring: <i>Nitrate</i>	Quarterly	Continue quarterly sampling for Nitrate at each POE until further notice.
Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (1630 NE 71st Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	New well cleared 12/2016. Begin routine (biannual monitoring for 2 consecutive 6-month monitoring periods). Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421283

PWS NAME: STONE OAKS MHP

POPULATION: 299

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	Quarterly	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (1195 NW 44 th St.) location. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept.2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421314

PWS NAME: SUN RAY ESTATES

POPULATION: 2050

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (3116 NE 22 nd Ct.) location. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept.2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421379

PWS NAME: MCINTOSH, TOWN OF

POPULATION: 484

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Ave. E & 6 th St. Hose Bib) location. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Use Asbestos Sampling Plan Form 62-555.900(10), F.A.C. Fill out Sections I & III; submit w/results.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421467

PWS NAME: WHISPERING OAKS MHP

POPULATION: 160

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #27) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2016 & August 10, 2016	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421490

PWS NAME: WOODS AND LAKES S/D

POPULATION: 275

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (17315 SE 65th Lane) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421495

PWS NAME: COUNTRY OAKS MHP

POPULATION: 95

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #13) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421520

PWS NAME: SUNLIGHT ACRES S/D

POPULATION: 198

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (13450 SE 32nd Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421528

PWS NAME: TALL TIMBER TRAVEL T/P

POPULATION: 95

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #A7) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421554

PWS NAME: OCALA GARDEN APARTMENTS

POPULATION: 48

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (2340 SW 6th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421559

PWS NAME: VICTORY MHP

POPULATION: 248

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #66) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421560

PWS NAME: OCALA OAKS SUBDIVISION (2 WPS)

POPULATION: 2202

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 2 WPs in system.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years. Test both WPs at the same time.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(4401 NE 46th Ln.) and L2-(3645 NE 17th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421573

PWS NAME: GOLDEN POND VILLAGE MHP

POPULATION: 135

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Special Monitoring <i>Dichloromethane</i>	2017	Special <u>annual</u> sampling for dichloromethane. First year of increased monitoring.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot A-29) location. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421574

PWS NAME: SERENITY OAKS MHP

POPULATION: 135

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite (NN)	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Special Monitoring <i>Pentachlorophenol</i>	Quarterly	Sample at each POE during January-March and April-June , 2017. Contact the office to check that no further testing is required.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (8712 SW 27th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3421576

PWS NAME: WINDGATE ESTATES

POPULATION: 504

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (265 NE 45th PI.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan. All water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

(Consecutive effective July 1, 2016)

PWS ID #: 3424000

PWS NAME: BELLEAIR SUBDIVISION

POPULATION: 763

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(5081 SE 20th St.) and L2-(2191 SE 50th Terr.) location. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	July – Dec 2016 & Jan – June 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424001

PWS NAME: MARION HILLS

POPULATION: 102

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(14249 SE 51st Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424009

PWS NAME: WHISPERING SANDS S/D

POPULATION: 406

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (5211 SE 29th St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424029

PWS NAME: CHAPPELL HILLS

POPULATION: 144

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (2357 NE 55th Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS (Consecutive system as of 2016)

PWS ID #: 3424030

PWS NAME: BELLEVIEW HILLS S/D

POPULATION: 378

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at each POE* every year.
Primary Inorganics	----	Sample at each POE every 3 years.
Secondaries	----	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(11984 95th Terr. St.). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424031

PWS NAME: FLORIDA HEIGHTS S/D

POPULATION: 347

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (6720 SE 52nd St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424032

PWS NAME: OAKHURST S/D

POPULATION: 299

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (5761 SE 24th St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424034

PWS NAME: VILLAGES OF OCALA

POPULATION: 130

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite (NN)	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #88) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

(Consecutive effective early 2017)

PWS ID #: 3424036

PWS NAME: WESTVIEW SUBDIVISION

POPULATION: 102

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Submit updated Stage 2 sampling plan. Collect dual sample for TTHM and HAA5s at one location. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	Jan – June & July – Dec 2017	Collect at least 5 tap samples. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424042

PWS NAME: FAIRFAX HILLS SUBDIVISION

POPULATION: 287

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (4508 SE 140TH Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424046

PWS NAME: QUAIL RUN SUBDIVISION

POPULATION: 230

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(1765 SW 107th Ln.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424061

PWS NAME: PARADISE MHP

POPULATION: 95

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #11) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424062

PWS NAME: PONDEROSA PINES (2WPS)

POPULATION: 465

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at each POE* every year. 2 WPs in system.
Primary Inorganics	2018-EA. WP	Sample at each POE every 3 years.
Secondaries	2018-EA. WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018-EA. WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018-EA. WP	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (1770 SE 183rd Terr.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424087

PWS NAME: OAK BEND MHP

POPULATION: 410

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(Lot 45-A) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424099

PWS NAME: ELEVEN OAKS SUBDIVISION

POPULATION: 126

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(5974 NE 26th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424106

PWS NAME: OAK HAVEN QUADRUPLEXES

POPULATION: 103

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (Triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(2060 NW 43rd St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424620

PWS NAME: TRADEWINDS VILLAGE

POPULATION: 1313

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(4121 NE 36th Ave) and L2-(3535 NE 42nd Pl) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424621

PWS NAME: BELLEVIEW OAKS ESTATES

POPULATION: 294

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (7415 SE 112th Ln.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424622

PWS NAME: SPRINGLAKE VILLAGE

POPULATION: 294

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (7415 SE 112th Ln.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424625

PWS NAME: RESIDENTIAL WATER SYSTEMS

POPULATION: 1796

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L2 -(4585 SE 60th St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424628

PWS NAME: SMITH LAKE SHORES VILLAGE

POPULATION: 368

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot# 235 Outside spigot) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424637

PWS NAME: SHERI OAKS SUBDIVISION

POPULATION: 70

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(1865 NE 127th Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424638

PWS NAME: OAK CREEK CAVERNS

POPULATION: 147

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 26 SW 44th Ln.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424643

PWS NAME: MCATEER ACRES

POPULATION: 234

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(41384 SE 54th Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424644

PWS NAME: FORE OAKS ESTATES

POPULATION: 462

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (5639 NE 6th Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

PWS ID #: 3424645

PWS NAME: WINDSTREAM & CARRIAGE HILL S/D

POPULATION: 301

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year. Missed 2016 NN, collected make up samples January 2017. Collect compliance NN during 2017.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect dual sample for TTHMs and HAA5s at L1 – 3366 SW 10 th Terrace. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS (Consecutive effective April, 2016)

PWS ID #: 3424646

PWS NAME: WOODBERRY FOREST S/D

POPULATION: 193

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	-----	Sample at each POE* every year.
Primary Inorganics	-----	Sample at each POE every 3 years.
Secondaries	-----	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	-----	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	-----	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	-----	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(9325 SE 119th Ln.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424648

PWS NAME: HILLTOP ESTATES MHP S/D

POPULATION: 230

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (9547 SE 165th Ln.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424649

PWS NAME: SUMMERFIELD PINES

POPULATION: 55

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 22) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424651

PWS NAME: OCALA HEIGHTS S/D

POPULATION: 1019

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (315 NE 72nd Terr.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424652

PWS NAME: SHADY ROAD VILLAS T/P

POPULATION: 183

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot D-17) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424654

PWS NAME: WILDERNESS RV PARK ESTATES

POPULATION: 60

Upgraded from TNC to CWS 4/2016

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (Triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L-1 (Town Park Clubhouse) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424655

PWS NAME: HIGH HOPES MHP

POPULATION: 68

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (6650 SE 139th St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424657

PWS NAME: COUNTRY WALK

POPULATION: 214

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(12473 SE 62nd Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424658

PWS NAME: PADDOCK PARK SOUTH MHP

POPULATION: 386

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot A-55) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2017	New well cleared 12/2016. Begin routine (biannual monitoring for 2 consecutive 6-month monitoring periods). Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424659

PWS NAME: TROPICANA VILLAGE S/D

POPULATION: 115

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (13350 SE 49th St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424662

PWS NAME: HILLTOP AT LAKE WEIR

POPULATION: 448

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (12727 SE 101 St. Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424664

PWS NAME: JACK MOBILE HOME PARK

POPULATION: 50

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(Lot A) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424685

PWS NAME: HAWKS POINT S/D

POPULATION: 462

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(4483 SE 109th Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424689

PWS NAME: SILVER SPRINGS WOODS

POPULATION: 1,141

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (17420 SE 24th Ln. Rd.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424690

PWS NAME: LANDFAIR S/D

POPULATION: 580

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine (annual) testing at 2 sites.</u> Collect 1 dual sample for TTHMs and HAA5s from L1-(7025 NE Jacksonville Rd, BP station) and L2-(Hilltop Apt. Rental Office Kitchen) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424691

PWS NAME: WINDING WATERS

POPULATION: 433

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (18801 SE 50th St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424789

PWS NAME: LAKEVIEW WOODS/TRAILS EAST S/D

POPULATION: 224

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly- 1 st , 2 nd & 3 rd quarter 2017	INCREASED (quarterly) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot A-55) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424808

PWS NAME: PONDEROSA M.H./SUBDIVISION

POPULATION: 67

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 18 SE 126th Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424827

PWS NAME: CITRA HIGHLANDS

POPULATION: 88

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(1458 NE 162nd St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424839

PWS NAME: BELLEVIEW HILLS ESTATES

POPULATION: 758

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (6381 SE 63rd Terr.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424841

PWS NAME: TURNING POINTE ESTATES

POPULATION: 263

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (13443 SW 2nd Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424857

PWS NAME: VETERANS OF FOREIGN WARS

POPULATION: 45

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 - (Kitchen sink) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3424962

PWS NAME: ASHLEY HEIGHTS S/D

POPULATION: 175

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (1080 NE 53rd St.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425006

PWS NAME: GREENFIELDS/INDIAN PINES

POPULATION: 1,618

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (3790 SE 38th St.) location. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425013

PWS NAME: SILVER SPRINGS REGIONAL

POPULATION: 2,471

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2016	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2016	<u>Routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Note: It may be possible for the system to qualify for a monitoring reduction. Refer to CFR 141.623(a). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2016 & August 10, 2016	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4141 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425029

PWS NAME: FOREST GREEN SUBDIVISION

POPULATION: 270

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kangaroo Station Pantry) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425039

PWS NAME: PLANTATION LANDING MHP

POPULATION: 36

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #66) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425108

PWS NAME: LEIGHTON ESTATES WATER SYSTEM

POPULATION: 104

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot Q1 SW 98th St. Rd.) location. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June - Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425111

PWS NAME: SUNSET HARBOR WATER SYSTEM

POPULATION: 25

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1-(15885 SE 105th Terr.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 3425127

PWS NAME: ASHLEY FARMS (2 WPS)

POPULATION: 1,540

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at each POE* every year. Ashley Farms & Quail Meadows WPs on system
Primary Inorganics	2018-EA. WP	Sample at each POE every 3 years.
Secondaries	2018-EA. WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018-EA. WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018- EA. WP	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (4513 NW 30th Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: **6420103**

PWS NAME: **BAHIA OAKS (CONSEC.)**

POPULATION: **1,200**

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at each POE* every year.
Primary Inorganics	----	Sample at each POE every 3 years.
Secondaries	----	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i> <i>System is a consecutive no-treatment system.</i>	July – Sept. 2017	<u>Routine</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Handyway blowoff) and L2 (7130 SW 64th Terr. blowoff) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6420467

PWS NAME: DOGWOOD ACRES

POPULATION: 181

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Clubhouse) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6420619

PWS NAME: FOXWOOD FARMS

POPULATION: 332

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Site #13 Lot 328) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6421041

PWS NAME: PALM LAKE APTS.

POPULATION: 60

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bulding A - Outside HB) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6421512

PWS NAME: RIO VISTA

POPULATION: 400

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at <u>each POE</u> * every year. System has 2 wells.
Primary Inorganics	2018	Sample at <u>each POE</u> every 3 years.
Secondaries	2018	Sample at <u>each POE</u> every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at <u>each POE</u> every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at <u>each POE</u> every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at <u>each POE</u> every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (10300 SW 186th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6421952

PWS NAME: WESTWOOD MHP

POPULATION: 150

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #50) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6422359

PWS NAME: OAK TREE VILLAGE APTS & CAMPGROUND

POPULATION: 412

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 125) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6422362

PWS NAME: ARROWHEAD CAMPSITES

POPULATION: 99

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Special Monitoring <i>Dichloromethane</i>	Annually- July-Sept. 2017	Special annual sampling (third year) for dichloromethane. Test on the 3 rd quarter of 2017.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #139) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6422679

PWS NAME: RAINBOW SPRINGS CC ESTATES

POPULATION: 1,826

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (Annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (9996 SW 188th Cir.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424073

PWS NAME: DUNNELLON, CITY OF

POPULATION: 1922

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. System has 2 WPs.
Primary Inorganics	2018-EA.WP	Sample at each POE every 3 years.
Secondaries	2018-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018-EA.WP	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (Annual) testing. Collect a sample for TTHMs and HAA5s from L1 (Chatmare-HAA5 only) and L2 (Indian Cove-TTHM only) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan. (Per SW comments: 1 sample in 2012 was repeated-sampled late.)
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424076

PWS NAME: GOLDEN HILLS GOLF & TURF WTP

POPULATION: 1,859

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 Split sampling, see comments	<u>Routine</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from L1 – 5896 NW 80 th Ave., and 1 HAA5 sample from L2 – 7613 NW 46 th Street. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424083

PWS NAME: RAINBOW LAKES ESTATES

POPULATION: 1810

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids</i> (5)	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAAs from L1 (Lombard Restaurant- 41) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424352

PWS NAME: COUNTRY OAKS

POPULATION: 92

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (4401 SW 44th Ln.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424371

PWS NAME: SATEKE VILLAGE

POPULATION: 86

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (18350 SW 102nd St. Rd.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424589

PWS NAME: INTERNATIONAL VILLAS

POPULATION: 95

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (5292 SW 21st Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424590

PWS NAME: LIBRA OAKS

POPULATION: 320

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Special Monitoring Chloride, Sulfate, TDS	Quarterly	Sample at each POE quarterly. Continue with this special monitoring until further notice.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (4580 SW 38th Pl.) location. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424591

PWS NAME: RIDGE MEADOWS

POPULATION: 228

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (764 NW 58th Ct) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424618

PWS NAME: PADDOCK DOWNS

POPULATION: 385

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (6736 SW 88th Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424620

PWS NAME: SADDLE OAK CLUB MHP

POPULATION: 650

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (5534 58th Pl.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424621

PWS NAME: OCALA JOCKEY CLUB SD

POPULATION: 100

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg. C Hose Bib) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424623

PWS NAME: GOLDEN HILLS MHP

POPULATION: 323

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 175) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424627

PWS NAME: MARION LANDING

POPULATION: 1,000

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L2 (8678 SW 65th Terr.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424629

PWS NAME: THE FALLS OF OCALA

POPULATION: 435

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (522 SW 79th Terr.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424632

PWS NAME: WOODS AND MEADOWS

POPULATION: 1,747

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (8530 SW St. Rd 200) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424653

PWS NAME: DEER CREEK MOBILE HOME SD

POPULATION: 165

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (8575 SW 70th Ave.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424673

PWS NAME: THE CENTERS

POPULATION: 100

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Bldg.5-Kitchen Sink) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424678

PWS NAME: MAJESTIC OAKS – PIGEON PARK

POPULATION: 1,445

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (7535 SW 62nd Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424689

PWS NAME: SWEETWATER OAKS

POPULATION: 240

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot #50) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424704

PWS NAME: FAIRFIELD VILLAGE

POPULATION: 500

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Lot 42A-5647 SW 57th Ct.) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: **6424706**

PWS NAME: **THE HAVEN HOUSE AT OCALA**

POPULATION: **50**

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Kitchen Sink) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424741

PWS NAME: THE HARBOR HOUSE AT OCALA

POPULATION: 75

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	<u>Reduced</u> (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Waiting Room Sink Bldg. 1) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424749

PWS NAME: SPRUCE CREEK PRESERVE

POPULATION: 1,456

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (11040 SW SR 200 Lift Station at old WTP) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks for pH and orthophosphate per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424768

PWS NAME: GOLDEN OCALA

POPULATION: 182

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year. Subregional WP is the only active plant in system. Interim WP was inactivated in 2012.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Special Monitoring (<i>Di(2-ethylhexyl)phthalate</i>)	Sept. - Dec. 2017	Second year of special monitoring for (Di(2-ethylhexyl)phthalate)
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (8450 NW US 27/Front Guard House) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June - Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424785

PWS NAME: OCALA PALMS (CONSEC.)

POPULATION: 2,015

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at each POE* every year.
Primary Inorganics	----	Sample at each POE every 3 years.
Secondaries	----	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Reduced</u> (annual) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (5000 US Hwy 27) location. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.



Department of Environmental Protection

Central District

2017 DRINKING WATER MONITORING REQUIREMENTS

PWS ID #: 6424804

PWS NAME: JULIETTE FALLS

POPULATION: 36

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each <u>POE</u> * every year.
Primary Inorganics	2018	Sample at each <u>POE</u> every 3 years.
Secondaries	2018	Sample at each <u>POE</u> every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each <u>POE</u> every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each <u>POE</u> every. Sample annually during 2017, 2018 and 2019.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each <u>POE</u> every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Jul. - Sept. 2018	Reduced (triennial) testing. Collect 1 dual sample for TTHMs and HAA5s from L1 (Sample Station NO 3 NO SW 179 Ct. Lot#211) location. Report disinfectant residuals.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling) Complete a Lead and Copper Sampling Plan.	June – Sept. 2018	Test in accordance with the most recently <u>approved</u> sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Reports should be submitted through our FTP site at ftp://ftp.dep.state.fl.us/pub/incoming/Central_District/Monthly%20Reporting%20Documents/. Failure to comply with deadlines may result in enforcement action.**

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-2919 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.