



# Department of Environmental Protection

Central District

PWS ID #: 3480114

PWS NAME: BRIGHTWOOD MANOR MHP

POPULATION: 343

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 9/15/11.
Lead and Copper (Tap Sampling)	June - Sept 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480226

PWS NAME: COLLEGE MOBILE HOME PARK

POPULATION: 90

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring Dalapon</i>	Quarterly	Sample at each POE quarterly.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Begin <u>triennial</u> testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480149

PWS NAME: PLURIS-WEDGEFIELD, INC.

POPULATION: 5,355

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly	System to continue quarterly monitoring at 2 locations for TTHMs/HAA5s. Report the disinfectant residual with test results.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481326

PWS NAME: TAFT WATER ASSOCIATION

POPULATION: 4,232

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly	Continue quarterly sampling at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-September 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480255

PWS NAME: CRESCENT HEIGHTS S/D (CONSEC.)

POPULATION: 969

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept. 2017	Testing to be conducted at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3480265

PWS NAME: OCU/DAETWYLER SHORES (CONSEC.)

POPULATION: 189

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept. 2018	Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Florida Department of Environmental Protection

Central District  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767

PWS ID #: 3424806

PWS NAME: OAK – GRINER BAPTIST CHURCH

POPULATION: 97

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July–Sept. 2019 (triennially)	Continue reduced (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2019	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
  
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480457

PWS NAME: SOUTH SHORE PARK, INC

POPULATION: 50

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)**NTNC**	2025	Sample at the POE.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2019	Begin reduced (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480470

PWS NAME: COSTA FARMS # 10.

POPULATION: 25

## 2016 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<b>Special Monitoring</b> <b>Di(2-Ethylhexyl)Phthalate</b>	Quarterly	Sample at POE each quarter until further notice.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480911

PWS NAME: HERMANN ENGELMANN #6

POPULATION: 69

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2017	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2017	Sample at each POE quarterly by 3/10 and 6/10.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July - Sept. 2019	Continue (triennial) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481052

PWS NAME: MONTEREY MUSHROOMS INC

POPULATION: 250

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification submitted 9/16/11.
Lead and Copper (Tap Sampling)	Biannual until further notice.	Sample Biannually beginning in July through December 2016 and continue until further notice.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3481480

PWS NAME: LOUIS DREYFUS CITRUS PRODUCTS

POPULATION: 143

## 2016 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If a well is reactivated or permitted for the water system, this schedule does not include additional monitoring which may be needed.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)**NTNC**	2025	Sample at the POE.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept 2019	Begin <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification submitted 2/9/12.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3484130

PWS NAME: STANTON ENERGY CENTER

POPULATION: 200

## 2016 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept 2017	Continue <u>routine</u> (annual) testing July – Sept. 2015. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept 2019	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3484228

PWS NAME: HAMPDEN DUBOSE ACADEMY

POPULATION: 90

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2016	Sample at each POE every 3 years.
Special Monitoring <i>Xylenes (total &amp; Ethylbenzene)</i>	2017	Sample at each POE annually during the second quarter of each calendar year until further notice.
Synthetic Organic Contaminants (SOCs)	2017	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2019	System qualifies for <u>reduced</u> (triennial) testing July – Sept. 2016. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3484250

PWS NAME: ROBERT'S BUSINESS CENTER

POPULATION: 25

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
<b>Special Monitoring for Lead</b>	Quarterly	Sample at each POE quarterly until further notice.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3484264

PWS NAME: CENTRAL FLORIDA RESEARCH PARK

POPULATION: 9129

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Sample monthly until March 31, 2016. After April 1, 2016, begin <u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
<b><i>Special Monitoring Di(2-ethylhexyl)Pthalate</i></b>	Quarterly	Sample at each POE quarterly until further notice.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly	Continue <u>quarterly</u> testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per 1/24/12 Revised Optimal WQP Approval Letter.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

\*\* NTNC  $\leq$  1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action**



# Department of Environmental Protection

Central District

PWS ID #: 3480200

PWS NAME: AOPKA, CITY OF (5 WTSPS)

POPULATION: 56,966

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at each POE* every year. 5 POEs now: Grossenb., S.Oaks., NW, Mt. Ply. Lks., & Ply. Reg.
Primary Inorganics	2017-EA. WP	Sample at each POE every 3 years.
Secondaries	2017-EA. WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017-EA. WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA. WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>  <i>EPA placed system on Schedule 3.</i>	Quarterly (every 90 days)	Continue routine (qtrly) testing at <u>4 sites</u> for both T/H (dual samples) –testing began October 2013. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2017	Distribution sites per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at <u>each POE</u> (5 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3480203

PWS NAME: MAITLAND, CITY OF (3 WPS)

POPULATION: 13,268

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at each POE* every year.
Primary Inorganics	2017-EA. WP	Sample at each POE every 3 years.
Secondaries	2017-EA. WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2020-EA. WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA. WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (Every 90 days)	Continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples) beginning October 2013. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3480204

PWS NAME: OCOEE, CITY OF (2 WPS)

POPULATION: 36,712

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at each POE* every year.
Primary Inorganics	2017-EA. WP	Sample at each POE every 3 years.
Secondaries	2017-EA. WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017-EA. WP	Sample at each POE every 3 years. It is recommended that <u>both</u> plants be tested in 2017.
Volatile Organic Contaminants (VOCs)	2017-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA. WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	For 2017: 706 Satin Leaf 2/17 706 Satin Leaf 11/17	System is on reduced monitoring in 2015. Test 706 Satin Leaf during 2/15 & during 11/15 for both TTHMs/HAA5s each time.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480409

PWS NAME: UNIVERSITY OF CENTRAL FLORIDA

POPULATION: 57,500

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2020	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Continue routine (qtrly) testing at 4 sites for both T/H (dual samples) beginning October 2013. Report disinfectant residuals.
Asbestos	2020	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2017	Distribution sites per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2016 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480962

PWS NAME: ORLANDO UTILITIES COMMISSION (7 WTPS)

POPULATION: 425,520

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (every 90 days) Same monitoring for 2017	Continue <u>routine</u> (qtrly) testing at <u>6 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Bromate	Monthly	Test each POE monthly of plants with ozonation. Submit bromate running annual averages quarterly.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June-Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at <u>each POE</u> (7 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481481

PWS NAME: WINTER GARDEN WATER DEPT (3 WPS)

POPULATION: 67,792

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 3 WPs: Palmetto St., Fuller’s Cross, and Woodlark WPs
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Annual (see Comments for details)	System qualifies for reduced (annual) monitoring in 2017 at two sites: Test 255 Zachery Wade St. during 2 <sup>nd</sup> quarter 2017 & test 1655 Victoria Way during 4 <sup>th</sup> quarter 2017. Test each site for both TTHMs/HAA5s. Record the disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June - Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2017	Distribution sites per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481482

PWS NAME: WINTER PARK, CITY OF (3 WPS)

POPULATION: 82,271

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 3 POEs in sys.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2020-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Special Monitoring <i>Dalapon</i>  <i>2016: 1AM/Dal-Swoope WP1 1Q’16.</i>	2nd Qtr 2017-WP1 3rd Qtr 2017-WP4, 1st Qtr 2017-WP6	2 <sup>nd</sup> annual dalapon POE WP1 due 1 <sup>st</sup> qtr 2017. 8 <sup>th</sup> annual dalapon POE WP 4 due 3 <sup>rd</sup> quarter 2017. 8 <sup>th</sup> annual dalapon POE WP 6 due 1 <sup>st</sup> quarter 2017.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (test every 90 days)	System will continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Bromate	Monthly	Test each POE monthly of plants with ozonation. Submit bromate running annual averages quarterly.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June - Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June - Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at <u>each POE</u> (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**



**9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481546

PWS NAME: OCU/WESTERN REGIONAL WTR SYS (4 WPS)

POPULATION: 119,708

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at <u>each</u> POE* every year. (4 WPs: Hidden Spgs., Oak Meadows, W. Regional, & C.R. 535)
Primary Inorganics	2017-EA. WP	Sample at <u>each</u> POE every 3 years.
Secondaries	2017-EA. WP	Sample at <u>each</u> POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017-EA. WP	Sample at <u>each</u> POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA. WP	Test at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA. WP.	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (every 90 days)	System will begin reduced (qtrly) 2 dual sample sets; at the locations with the highest TTHM and highest HAA5 LRAAs. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at <u>each POE</u> (4 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3484093

PWS NAME: RCID CENTRAL (4 WPS)

POPULATION: 136,500

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA. WP	Sample at each POE* every year.
Primary Inorganics	2017-EA. WP	Sample at each POE every 3 years.
Secondaries	2017-EA. WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2020-EA. WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA. WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (every 90 days)	System will continue <u>routine</u> (quarterly) testing at <u>6 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at <u>each POE</u> (4 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3484119

PWS NAME: OCU D SOUTHERN WATER SYS (5 WPs)

POP: 78,460

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 5WPs: Cypress Walk, Vistana, Orangewood, Hunters Crk, & S. Reg.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2020-Vistana, 2023-Other WPs	Sample at each POE every 3 years. Vistana WP must be tested in 2020 while the other WPs may be tested in 2023. It is highly recommended that all of the WPs be tested for rads at the same time.
Volatile Organic Contaminants (VOCs)	2017-EA.WP,	Sample at POE of S. Reg. WP annually in 2016. Test all of the WPs in 2017.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (test every 90 days or fewer)	System will continue <u>routine</u> (quarterly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Bromate <i>(for plants which use ozone – S. Regional WP)</i>	Monthly-Southern Regional WP	Test the POE of S. Regional WP monthly for bromate. Submit bromate <u>running annual averages</u> quarterly.
Asbestos	2020	Test results or asbestos-free certification due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at <u>each POE</u> (5 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2016 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3484132

PWS NAME: OCU/EASTERN WATER SYSTEM (2 POEs)

POPULATION: 290,878

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports. <b>Test the ASR well monthly.</b>
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-ASR POE, 2017-E. Reg.	Sample at each POE* every year. 2 POEs: E. Reg. WP POE & ASR Well POE directly to distribution. <b>ASR Well POE monitoring began 10/3/17. The ASR well was put into service during 4<sup>th</sup> Quarter 2016.</b>
Primary Inorganics	2017-ASR POE, 2017-E. Reg.	Sample at <u>each</u> POE every 3 years (treated water).
Secondaries	2017-ASR POE, 2017-E. Reg.	Sample at <u>each</u> POE every 3 years (treated water).
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2017-E. Reg. WP	Sample at E. Reg. WP POE every 3 years (treated).
Arsenic & Radiologicals ( <i>Gross Alpha &amp; Radium 228 minimum for rads</i> ) -- <i>Special Testing at ASR Well POE--</i>	2017-ASR POE Monthly/Qtrly (see Comments)	Sample at ASR POE <u>monthly</u> during recovery phases and <u>quarterly</u> when there is no recovery. (Monthly testing is recommended to cover all.)
Volatile Organic Contaminants (VOCs)	3/17, 6/17, & 9/17 Qtrs-ASR POE, 2017-E. Reg. WP	Sample at ASR POE <u>quarterly</u> 3/17, 6/17, & 9/17; samples should be at least 30 days apart. Sample at E. Reg. WP POE once in 2017.
Synthetic Organic Contaminants (SOCs)	3/17, 6/17, & 9/17 Qtrs-ASR POE, 2017–2 Qtrs E. Reg. WP	Sample at ASR POE <u>quarterly</u> 3/17, 6/17, & 9/17; samples should be at least 30 days apart. Sample at E. Reg. WP POE for 2 quarters in 2017; the 2 samples should be at least 60 days apart.
Special Monitoring <i>Di(2-ethylhexyl)phthalate</i> -- <i>Special Testing at E. Reg. WP &amp; ASR Well POE due to detections--</i>	2017-2nd Annual (3 <sup>rd</sup> Quarter 2017), 3/17, 6/17, & 9/17 Qtrs-ASR POE	Sample at POE of E. Regional WP <u>annually</u> during the 3 <sup>rd</sup> quarter of 2017 and 4 <sup>th</sup> quarter of 2018. Sample at ASR POE <u>quarterly</u> 3/17, 6/17, & 9/17; samples should be at least 30 days apart - The quarterly SOC testing conducted at the ASR POE during 3/17, 6/17, & 9/17 will cover this testing.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly (every 90 days)	System will continue <u>routine</u> (qtrly) testing at <u>6 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (must test)	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June-Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at <u>each POE</u> (2 POEs now since ASR is active) at least every 2 weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>



\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

## Central District

PWS ID #: 3480272

PWS NAME: DAVIS SHORES (CONSEC.)

POPULATION: 143

### 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept. 2018	Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C. Asbestos-free certification received on 2/1/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480289

PWS NAME: DE NEEF VILLAGE

POPULATION: 150

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480327

PWS NAME: TOWN OF EATONVILLE

POPULATION: 2,727

## 2016 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Annual	Begin <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) beginning 3rd quarter 2017. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480502

PWS NAME: VALLEY MHP

POPULATION: 239

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3480539

PWS NAME: HILLCREST MOBILE HOME VILLAGE

POPULATION: 50

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480555

PWS NAME: HOLIDAY ACRES MOBILE HOME PARK

POPULATION: 78

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Triennial	Begin triennial monitoring July-September 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480681

PWS NAME: HARRISON'S TRAILER PARK

POPULATION: 70

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2018	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 yrs. Note: The annual monitoring for dichloromethane may stop per Rule 62-550.515(3)(b). Results for the last 3 years have been below detection limits.
<i>Special Monitoring Dichloromethane</i>	Annual	Sample at POE 3 <sup>rd</sup> quarter 2017.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
<i>Special Monitoring Dalapon</i>	Quarterly	Sample at POE quarterly.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Quarterly	Continue <u>quarterly</u> testing. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480695

PWS NAME: LAKE DOWNEY MOBILE HOME PARK

POPULATION: 200

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at each POE in 2021.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Begin <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3480700

PWS NAME: OCUD/LAKE JOHN SHORES WTR SYS.

POPULATION: 67

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2015. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: **3480792**

PWS NAME: **OCUD/MAGNOLIA WOODS CONSEC. WTR SYSTEM**

POPULATION: **347**

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept. 2018	Continue reduced (triennial) testing July – Sept. 2015. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480913

PWS NAME: OAKLAND, TOWN OF

POPULATION: 2,828

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at each POE in 2021.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2017	Continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3480940

PWS NAME: OLA BEACH IMPROVEMENT ASSN

POPULATION: 145

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at each POE in 2021.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special Monitoring</i> <i>Total Xylene</i>	Quarterly	Sample at each POE quarterly
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3481016

PWS NAME: PINE ISLE MOBILE VILLA

POPULATION: 127

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at each POE in 2021.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
<i>Special monitoring Dalapon</i>	Quarterly	Sample at POE quarterly.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2015. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

**9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481093

PWS NAME: ROCK SPRINGS MHP

POPULATION: 1,338

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
<i>Special monitoring Total Xylene and Ethylbenzene</i>	Quarterly	Sample at each POE quarterly
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2017	Continue reduced annual testing at <u>1</u> site for both T/H (dual sample). Report the disinfectant residual.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481155

PWS NAME: SHADY OAKS TRAILER PARK

POPULATION: 38

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Combined Radium 228 and Radium 226</i> )	2021	Sample at POE in 2021.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-September 2018	Begin triennial monitoring July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481199

PWS NAME: SILVER STAR VILLAGE (2 WPS)

POPULATION: 639

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2016-EA.WP	Sample at <u>each</u> POE* every year. System has 2 water plants.
Primary Inorganics	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Secondaries	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021-EA.WP	Sample at <u>each</u> POE in 2021.
Volatile Organic Contaminants (VOCs)	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	Begin <u>routine</u> (annual) testing: 1 TTHM and 1 HAA5 sample: one at the location and during the quarter with the highest TTHM single measurement, one at the location and during the quarter with the highest HAA5 single measurement; 1 dual sample set per year if the highest TTHM and HAA5 measurements occurred at the same location and quarter. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**



- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481270

PWS NAME: STARLIGHT RANCH MOBILE HOME ESTATES

POPULATION: 1,221

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at each POE in 2021.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	Continue <u>routine</u> (annual) testing at <u>1 site</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3481329

PWS NAME: TANGERINE WATER COMPANY

POPULATION: 851

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	Continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481420

PWS NAME: VALENCIA ESTATES MHP

POPULATION: 305

## 2016 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at POE in 2021.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Total Xylene (VOC)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproduct (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Annual (2017)	Begin annual monitoring July-September 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481501

PWS NAME: CLARCONA RESORTS

POPULATION: 1,268

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	Begin regular (annual) testing July – Sept. 2017. Take 2 TTHM and 2 HAA5 sample: one location and during the quarter with the highest TTHM single measurement, one at the location and during the quarter with the highest HAA5 single measurement; 2 dual sample set per year if the highest TTHM and HAA5 measurements occurred at the same location and quarter. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3481506

PWS NAME: ZELLWOOD STATION (CONSEC.)

POPULATION: 2,571

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	Continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481507

PWS NAME: ZELLWOOD WATER USERS INC. (2 WPS)

POPULATION: 1,257

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at <u>each</u> POE* every year.
Primary Inorganics	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Secondaries	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018-King WP 2021-Jones WP	King WP-Sample at POE 2018 Jones WP-Sample at POE 2021.
Volatile Organic Contaminants (VOCs)	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018-EA.WP	Sample at <u>each</u> POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	Continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481518

PWS NAME: HIDDEN VALLEY MOBILE HOME PARK

POPULATION: 907

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017	<u>Routine</u> (annual) testing at <u>1 site</u> for both T/H. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481547

PWS NAME: OCU/D/PARTLOW ACRES (CONSEC.)

POPULATION: 102

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July-Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3481551

PWS NAME: CONESTOGA MOBILE HOME PARK

POPULATION: 62

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**





# Department of Environmental Protection

Central District

PWS ID #: 3481571

PWS NAME: BIG OAKS MOBILE HOME PARK

POPULATION: 125

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018 (Gross Alpha and Radium 228 minimum)	Sample at each POE every 3 years. Testing for Radium 226 will be required in 2015 if the total of the Gross Alpha result plus the Radium 228 result exceeds 5 pCi/L (as in 2013).
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Dalapon <i>Special monitoring, quarterly monitoring for Dalapon</i>	Quarterly	Sample at POE quarterly until further notice.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing 08/18. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**



- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



# Department of Environmental Protection

Central District

PWS ID #: 3484175

PWS NAME: J & C MHP

POPULATION: 62

## 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 228</i> )	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	July – Sept. 2017	Continue <u>routine</u> (annual) testing July – Sept. 2015. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: <a href="http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm">http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm</a>

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**