



Department of Environmental Protection

Central District

PWS ID #: 3490090

PWS NAME: BAY LAKE ESTATES

POPULATION: 229

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (January, April, July, October)	Continue increased quarterly sampling. Collect 1 dual sample during the fourth week of the first month of each quarter (22 nd -28 th). Report disinfectant residuals. Sample in accordance with your approved sampling plan.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	Bi-Annual Jan-June 2019 & July-Dec. 2019	Test in accordance with the most recently approved sampling plan. 10 Samples required.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490265

PWS NAME: COLONIAL MOBILE HOME PARK

POPULATION: 115

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
<i>Special Monitoring Di-(2-Ethylhexyl)Phthalate</i>	<i>Annual (During 2nd quarter)</i>	<i>Sample at POE annually during the 2nd quarter in 2019 and 2020</i>
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	January 2021	Begin reduced (triennial) sampling in 2021. Collect one dual sample for TTHMs and HAA5s during January at the car wash hose bib. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490293

PWS NAME: MILL CREEK RV RESORT

POPULATION: 120

2018 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2027	Sample at each POE every 3 years. For 2018 you only need to sample for Uranium and combined radium-226 and 228. Gross Alpha due 2021.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2021	Continue <u>reduced</u> (triennial) testing second week July 2021. Collect 1 dual sample for TTHM and HAA5 sample from lot 505. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490314

PWS NAME: CYPRESS COVE

POPULATION: 289

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2027	Sample at each POE.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2021 Sample July 8 th -15 th	Continue <u>reduced</u> (triennial) testing July – Sept. 2021. Collect 1 dual sample from WW treatment tap. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 3/14/11.
Lead and Copper (Tap Sampling) <i>10 Samples</i>	June-Sept. 2021	Test in accordance with the most recently approved sampling plan. Note: Number of samples required is based on seasonal average and not current population set.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490770

PWS NAME: LAKE RUNNYMEDE MOBILE HOME PARK

POPULATION: 222

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
<i>Special Monitoring Dalapon</i>	<i>Annual (during 4th quarter)</i>	<i>Sample at POE annually during the 4th quarter</i>
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Begin routine (annual) testing July – Sept. 2019. Collect 1 dual sample for TTHM and HAA5 at the north pavilion. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490816

PWS NAME: GREAT OAK R.V. RESORT

POPULATION: 35

2018 DRINKING WATER MONITORING REQUIREMENTS

Contact DEP for 2019 Monitoring Requirements. Requirements subject to change based on 2018 results with qualified lab data. DEP determining acceptability of that data

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2018	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 9 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2018 & August 10, 2018	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2018 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- It is important for you to provide this information to your operator and/or sampler.
- It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by **9/30/18** to provide time for revisions, re-tests, and/or corrections. **Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490986

PWS NAME: PLEASANT HILL VILLAGE

POPULATION: 165

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Special Monitoring <i>Total Xylene</i>	Quarterly	Sample quarterly until further notice due to detect in 2018
Synthetic Organic Contaminants (SOCs)	2019	Collect make-up samples for missed 2018.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Sept. 2019	Begin routine (annual) testing Sept. 2019. Collect 1 dual sample from the bibb at WWTP. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491002

PWS NAME: **KISSIMMEE RV PARK**

POPULATION: 43

2019 DRINKING WATER MONITORING REQUIREMENTS

(Changed from TNC to CWS effective 11/1/2016)

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228 minimum</i>)	2021	Sample at POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every year.
Synthetic Organic Contaminants (SOCs)	2021	Sample at POE every year 3 years
Di(2-Ethylhexyl)adipate (Special Monitoring)	Annual 3rd quarter	Begin annual monitoring during the 3rd quarter until further notice.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Sep. 2021	Begin <u>reduced</u> (triannual) testing at <u>1 site</u> for both T/H (dual samples) Sept. 2021. Report disinfectant residuals.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling) <i>Collect 5 samples</i>	June-Sept. 2021	Reduced to triannual. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491077

PWS NAME: **BOGGY CREEK RESORT AND RV PARK**

POPULATION: **94**

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly 2 nd week of the 2 nd month	Continue to test quarterly until further notice. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept 2019	Begin annual monitoring. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491298

PWS NAME: SHELTER COVE RESORT

POPULATION: 187

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	August 2019	Begin routine (annual) testing August 2019. Collect 1 dual sample at 805 Parkway East. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection Central District

PWS ID #: 3491702

PWS NAME: FLORIDIAN SANDALWOOD, MHC.

POPULATION: 450

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Primary Inorganics	2021	Sample at POE every 3 years.
Secondaries	2021	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2024	Sample at POE.
Volatile Organic Contaminants (VOCs)	2021	Sample at POE every 3 years
Synthetic Organic Contaminants (SOCs)	2021	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	August 2019	Begin routine (annual) testing August 2019. Collect 1 dual sample from the boat ramp. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491726

PWS NAME: SHARP'S MOBILE HOME PARK

POPULATION: 179

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Primary Inorganics	2021	Sample at POE every 3 years.
Secondaries	2021	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at POE every 3 years
Synthetic Organic Contaminants (SOCs)	2021	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	August 2021	Continue reduced (triennial) testing July – Sept. 2021. Collect 1 dual at Lot 47. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491904

PWS NAME: KING'S MOBILE HOME PARK

POPULATION: 43

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Primary Inorganics	2021	Sample at POE every 3 years.
Secondaries	2021	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	August 2021	Continue reduced (triennial) testing August 2018. Collect 1 dual sample from Lot 18. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District's website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491956

PWS NAME: LAKE AJAY VILLAGE S/D (CONSEC.)

POPULATION: 220

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Remain on quarterly testing until further notice. Collect dual samples for TTHM and HAA5s at L1: 3203 Whisperwind Drive. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494313

PWS NAME: WHISPERING PINES MHP

POPULATION: 465

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Special Monitoring <i>Dalapon</i>	Annual 4 th qtr	Test annually in the 4 th qtr in 2017, 2018 & 2019.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	August 2021	Continue <u>reduced</u> (triennial) testing August 2021. Collect 1 dual sample 1729 Grand Cypress Ave. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494316

PWS NAME: BERMUDA MOBILE HOME PARK

POPULATION: 48

2018 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample during the first quarter of 2018 due to new well installation.
Secondaries	2021	Sample at the POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2024	Sample at each POE.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE annually during 2019, 2020, and 2021 due to new well.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE.
Special Monitoring (SOCs) <i>Endothall, Dalapon, Picloram, Dinoseb, 2,4-d, 2,4,5-tp, pentachlorophenol</i>	Quarterly	Initiate quarterly monitoring due to unacceptable 2017 results.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	September 2021	Continue reduced triennial testing Sept. 2021. Collect one dual sample for TTHMs and HAA5s at L-1 Trailer #1. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 2/11/11.
Lead and Copper (Tap Sampling)	Jan – June and July – Dec 2019	Sample biannually due to missing 2018 samples. Collect 1 set of 5 lead and copper tap samples, twice per year. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/central/content/resources-drinking-water-facilities-and-operators-central-district

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/central/content/resources-drinking-water-facilities-and-operators-central-district> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494318

PWS NAME: LAKE MARIAN SHORES

POPULATION: 130

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2018	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
<i>Special Monitoring</i> for Fluoride	Quarterly	Sample at POE quarterly until further notice.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2024	Sample at POE every 6 years.
Volatile Organic Contaminants (VOCs)	2024	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue quarterly monitoring. Collect one dual sample for TTHMs and HAA5s at Lot 64. Sample in accordance with approved sampling plan. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494359

PWS NAME: HYATT FARMS

POPULATION: 40

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Special Monitoring <i>Antimony</i>	Quarterly	Sample at the POE quarterly until further notice.
Secondaries	20121	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Continue routine, <u>annual</u> testing Sept. 2019. Collect 1 dual sample at L1 – Red House. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 3/14/11.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494399

PWS NAME: DEER PARK

POPULATION: 85

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2024	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2021	Continue reduced (triennial) testing Sept. 2021. Collect 1 dual sample at 13245 Fawn Ln in September. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/18/11.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494400

PWS NAME: HAMMOCK POINTE UTILITY ASSOCIATION INC.

POPULATION: 515

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	1st Month, Week of the 23rd of each Quarter	Continue quarterly testing for 2018. Collect 1 dual sample for TTHMs and HAA5s at 5221 Hammock Pointe CT. and 2801 Deerfield St. Sample in accordance with approved sampling plan. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494416

PWS NAME: HIDDEN GLEN

POPULATION: 70

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2021	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2024	Sample at each POE.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July 2021	Continued <u>reduced</u> testing July 2018. Collect 1 dual sample at 6624 Ivy Mist. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494418

PWS NAME: SPRINGLAKE VILLAGE WTP

POPULATION: 3070

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2021	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Special Monitoring <i>Dalapon</i>	1 st Quarter 2021	Sample at POE during the 1 st quarter annually until further notice.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Sept. 2019 (annual)	Continue annual sampling during September. Collect dual samples at 3854 Wood Thrush Dr. and 3645 Lake Morning Circle. Report the disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	June-Sept. 2021	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2021 & August 10, 2021	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494427

PWS NAME: HARMONY CDD

POPULATION: 1,185

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2021	Sample at each POE every 3 years.
Secondaries	2021	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2024	Sample at each POE.
Volatile Organic Contaminants (VOCs)	2021	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2021	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July 2019	Begin reduced (annual) testing July 2019. Collect 1 dual sample at 3315 School House Rd. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	Jan. – June and July – Dec. 2019	Collect 20 samples, twice in 2019. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 349443

PWS NAME: TWA-NORTHEAST WATER SYSTEM (Consec)

POPULATION: 542

New PWS Changed to Active January 2019 2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	1 Distribution Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019 (annually)	System will begin routine (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals. Submit sample plan for approval prior to sampling. Sample plan must indicate <u>month</u> of sampling.
Asbestos	2019	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	July – Dec. 2019 and Jan. – June 2020	Submit sampling plan for approval prior to sampling; test in accordance with approved plan. Collect 20 samples for two consecutive biannual monitoring periods.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2020 & August 10, 2020	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central>

on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494428

PWS NAME: ENTERPRISE CDD (CONSECUTIVE)

POPULATION: 8,166

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July 2019	Continue on reduced (annual) monitoring: 1 dual sample from Celebration H.S. LS annually during July 2019. Report disinfectant residuals.
Asbestos	2020	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2020	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490184

PWS NAME: BUENAVENTURA LAKES

POPULATION: 16,569

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2020	Sample at each POE every 3 years.
Secondaries	2020	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2020	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2020	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	May 2019, & August 2019	Due to low results, testing has been reduced to two samples annually in two separate calendar quarters at <u>115 Windy Dune Ct.</u> During each sampling event, test for both TTHMs/HAA5s (dual samples). Report disinfectant residuals. Note: If TTHMs > 60 ug/L or if HAA5s >45 ug/L in either test, resume routine (quarterly) testing the following quarter at the same 4 sites tested just prior to the reduction. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2020	Test in accordance with the most recently approved sampling plan
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490751

PWS NAME: TOHO WATER AUTHORITY EASTERN

POPULATION: 110,102

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019-EA.WP	Sample at each POE* every year. 3 POEs: Richard McLaughlin WP, Parkway WP, Camelot West WP.
Primary Inorganics	2020-EA.WP	Sample at each POE every 3 years.
Secondaries	2020-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023-EA.WP	Sample at each POE.
Volatile Organic Contaminants (VOCs)	2020-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2020-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Continue <u>routine</u> (qtrly) testing at <u>6 sites</u> for both T/H (dual samples). Report disinfectant residuals. Test in accordance with Stage 2 D/DBP Monitoring Plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2020	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June-Sept. 2020	<u>Distribution sites</u> per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2019	Sample at each POE (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491011

PWS NAME: TOHO WATER AUTHORITY WESTERN

POPULATION: 40,330

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019-EA.WP	Sample at each POE* every year. 2 POEs: Northwest WP and Southwest WP.
Primary Inorganics	2020-EA.WP	Sample at each POE every 3 years.
Secondaries	2020-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023-EA.WP	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2020-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2020-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	2600 Emerald Isl. April 2019, & 17627 Bali Blvd. July 2019	Due to low results, testing has been reduced to two samples annually in two separate calendar quarters. During each sampling event, test for both TTHMs/HAA5s (dual samples). Report disinfectant residuals. Refer to 40 CFR Subpart U 141.605(c)(1) – (c)(8).
Bromate	Monthly	Test each POE monthly of plants with ozonation (Southwest WP). Submit bromate running annual averages quarterly.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2020	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2018 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491373

PWS NAME: ST. CLOUD, CITY OF (3 WPS)

POPULATION: 53,792

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite (NN)	2019-EA.WP	Sample at each POE* every year.
Primary Inorganics	2020-EA.WP	Sample at each POE every 3 years.
Secondaries	2020-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023-EA.WP	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2020-EA.WP	Sample at the POE of all 3 WPs in 2020.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2020-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System will continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals. Sample in accordance with approved sampling plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2020	Collect 30 tap samples. Test in accordance with the most recently approved sampling plan
Water Quality Parameters (WQPs) <i>WQP rqrmt added 3/27/15 due to pop. increase</i>	June-Sept. 2020	Distribution sites per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs) <i>WQP rqrmt added 3/27/15 due to pop. increase</i>	Jan.-June & July-Dec. 2019	Sample at each POE (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494429

PWS NAME: TOHO WATER AUTHORITY-POINCIANA SYSTEM

POPULATION: 69,447

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019-EA.WP	Sample at each POE* every year. 3 active WPs in system: Bella Lago (orig. WP6), Peabody (orig. WP2), & Huron (orig. WP5). Note: Country Club (orig. WP3), Wilderness (orig. WP4), and McLane (orig. WP1) were decommissioned in 2012.
Primary Inorganics	2020-EA.WP	Sample at each POE every 3 years.
Secondaries	2020-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023-EA.WP	Sample at each POE every 6 years.
Volatile Organic Contaminants (VOCs)	2020-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2020-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Continue routine (quarterly) testing at 4 sites for both T/H (dual samples). Report the disinfectant residuals. Test in accordance with the Stage 2 D/DBP Monitoring Plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	Jan—June July-Dec. 2019	Collect 60 samples. Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2020	Distribution sites per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2019	Sample at <u>each POE</u> at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2019 & August 10, 2019	Data for CCR can be obtained at: https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490633

PWS NAME: TROPICAL PALMS RESORT

POPULATION: 34

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2022	Sample at each POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	August 2019	Continue <u>reduced</u> (triennial) testing August 2019. Collect 1 dual sample at Lot 271. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491703

PWS NAME: CANOE CREEK SERVICE PLAZA

POPULATION: 68

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July 2019	Begin <u>reduced</u> (triennial) testing July 2019. Collect 1 dual sample at L1 – C Store Hand Sink. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491705

PWS NAME: GATE PRECAST

POPULATION: 106

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2022	Acceptable 2015 grandfathered data, qualified for sampling at POE in 6 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Special Monitoring <i>Carbon Tetrachloride</i>	Annual during 3 rd Quarter	Sample at POE during the 3 rd quarter, annually, until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	August 2019	Continue <u>reduced</u> (triennial) testing August 2019. Collect 1 dual TTHM and HAA5 sample at L1 – West Building. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491946

PWS NAME: ASPIRE HEALTH PARTNERS, INC.

POPULATION: 197

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Exempt
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) Total Trihalomethanes & Haloacetic Acids (5)	Sept. 2019	Continue reduced (triennial) testing Sept. 2019. Collect 1 dual sample at L1 – Maintenance Sink. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494409

PWS NAME: CANE ISLAND POWER PARK

POPULATION: 29

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July 2019	Begin <u>reduced</u> (triennial) testing July 2019. Collect 1 dual sample from L1 – Remote Recirc. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494431

PWS NAME: MACK FARMS

POPULATION: 32

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2022	Sample at each POE every 6 years.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Sept. 2019	Continue <u>reduced</u> (triennial) testing Sept. 2019. Collect 1 dual sample from L1 – Office kitchen sink. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 2/11/11.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494434

PWS NAME: CARROLL STREET STATION

POPULATION: 35

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Triennial August	Begin triennial testing August 2019. Collect 1 dual sample from L1 – East Sample Tap. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494435 PWS NAME: COMMUNITY OF FAITH UNITED METHODIST CHURCH POPULATION: 90

2019 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2019	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE annually every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July 2019	Continue <u>reduced</u> (triennial) testing July 2019. Collect 1 dual sample at L1 – NE side of bldg. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 5/10/11.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2019 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/19 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**