



Department of Environmental Protection

Central District

PWS ID #: 3490090

PWS NAME: BAY LAKE ESTATES

POPULATION: 229

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490265

PWS NAME: COLONIAL MOBILE HOME PARK

POPULATION: 115

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue <u>increased</u> (quarterly) testing in 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490293

PWS NAME: MILL CREEK RV RESORT

POPULATION: 120

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490314

PWS NAME: CYPRESS COVE

POPULATION: 289

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 3/14/11.
Lead and Copper (Tap Sampling) <i>10 Samples</i>	June-Sept. 2018	Test in accordance with the most recently approved sampling plan. Note: Number of samples required is based on seasonal average and not current population set.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490770

PWS NAME: LAKE RUNNYMEDE MOBILE HOME PARK

POPULATION: 222

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490816

PWS NAME: GREAT OAK R.V. RESORT

POPULATION: 35

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490986

PWS NAME: PLEASANT HILL VILLAGE

POPULATION: 165

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494428

PWS NAME: ENTERPRISE CDD (CONSECUTIVE)

POPULATION: 8,166

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2017	Continue on reduced (annual) monitoring: 1 dual sample from Celebration H.S. LS annually during 3 rd qtr 2017. Report disinfectant residuals.
Asbestos	2020	Asbestos-free certification or results due every 9 years. Use Asbestos Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491002

PWS NAME: **KISSIMMEE RV PARK**

POPULATION: 43

2017 DRINKING WATER MONITORING REQUIREMENTS

(Changed from TNC to CWS effective 11/1/2016)

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly (1 raw, 1 distribution)	Disinfectant residuals must be reported individually on bacte reports.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Secondaries	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228 minimum</i>)	1/17, 4/17, 7/17	Sample at POE for four consecutive quarters. 7/16 sample counts as the first quarter.
Volatile Organic Contaminants (VOCs)	1/17, 4/17, 7/17	Sample at POE for four consecutive quarters. 7/16 sample counts as the first quarter.
Synthetic Organic Contaminants (SOCs)	1/17, 4/17, 7/17	Sample at POE for four consecutive quarters. 7/16 sample counts as the first quarter.
Di(2-Ethylhexyl)phthalate (Special Monitoring)	Quarterly	Continue quarterly monitoring until further notice due to a detect during the 4th quarter of 2016.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Oct. – Dec. 2017	Begin <u>routine</u> (annual) testing at <u>1 site</u> for both T/H (dual samples) July - Sept. 2017. Report disinfectant residuals. Submit a Stage 2 Monitoring Plan for approval.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling) <i>Collect 5 samples</i>	Jan – Jun 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491077

PWS NAME: BOGGY CREEK RESORT AND RV PARK

POPULATION: 94

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue to test quarterly until further notice. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	Jan-June 2017 & July-Sept. 2017	System is on a 6-month testing schedule in 2017 due to corrosion control treatment installed in 2016. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491298

PWS NAME: SHELTER COVE RESORT

POPULATION: 187

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491576

PWS NAME: WINDSOR PROPERTIES OF KISSIMMEE

POPULATION: 135

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection Central District

PWS ID #: 3491702

PWS NAME: FLORIDIAN RV RESORT

POPULATION: 450

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE =*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491726

PWS NAME: SHARP'S MOBILE HOME PARK

POPULATION: 179

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491904

PWS NAME: KING'S MOBILE HOME PARK

POPULATION: 43

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491956

PWS NAME: LAKE AJAY VILLAGE S/D (CONSEC.)

POPULATION: 220

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July 2018	Qualified for reduced (triennial sampling). Collect dual samples for TTHM and HAA5s at 3203 Whisperwind Drive. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494313

PWS NAME: WHISPERING PINES MHP

POPULATION: 465

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Special Monitoring <i>Dalapon</i>	Annual	Test annually in the 4 th qtr in 2017, 2018 & 2019.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494316

PWS NAME: BERMUDA MOBILE HOME PARK

POPULATION: 48

2017 DRINKING WATER MONITORING REQUIREMENTS

New well cleared for service 1/2017

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	1/17, 4/17, 7/17, 10/17	Sample at each POE for four consecutive quarters.
Volatile Organic Contaminants (VOCs)	1/17, 4/17, 7/17, 10/17	Sample at each POE for four consecutive quarters.
Synthetic Organic Contaminants (SOCs)	1/17, 4/17, 7/17, 10/17	Sample at each POE for four consecutive quarters.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Begin <u>initial</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 2/11/11.
Lead and Copper (Tap Sampling)	Jan – Jun 2017 July – Dec 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494318

PWS NAME: LAKE MARIAN SHORES

POPULATION: 130

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
<i>Special Monitoring</i> for Fluoride	Quarterly	Sample at POE quarterly until further notice.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Special Monitoring <i>Xylenes (total)</i>	4 th qtr 2017	Test annually in the 4 th qtr in 2017, 2018 & 2019.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue routine (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494359

PWS NAME: HYATT FARMS

POPULATION: 40

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue <u>reduced</u> (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 3/14/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494399

PWS NAME: DEER PARK

POPULATION: 85

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Continue reduced (triennial) testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/18/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494400

PWS NAME: HAMMOCK POINTE UTILITY ASSOCIATION INC.

POPULATION: 515

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue <u>routine</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494416

PWS NAME: HIDDEN GLEN

POPULATION: 70

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin <u>reduced</u> testing July – Sept. 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494418

PWS NAME: SPRINGLAKE VILLAGE WTP

POPULATION: 3070

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Special Monitoring <i>Dalapon</i>	1 st Quarter 2017	Sample at POE during the 1 st quarter of 2017 for the 4 th annual dalapon test.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annual)	System is on annual (routine) testing now at 2 sites, dual samples. Test each site for both TTHMs/HAA5s during the 1 st week Sept. 2017. Report the disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494427

PWS NAME: HARMONY CDD

POPULATION: 1185

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2018	Sample at each POE every 3 years.
Secondaries	2018	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue <u>routine</u> (annual) testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 11/13/11.
Lead and Copper (Tap Sampling)	Jan-June 2017 & July-Dec. 2017	Continue biannual sampling until Department notifies otherwise. Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490184

PWS NAME: BUENAVENTURA LAKES

POPULATION: 16,569

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	April – June 2017, & July – Sept. 2017	Due to low results, testing has been reduced to two samples annually in two separate calendar quarters at <u>115 Windy Dune Ct.</u> During each sampling event, test for both TTHMs/HAA5s (dual samples). Report disinfectant residuals. Note: If TTHMs > 60 ug/L or if HAA5s >45 ug/L in either test, resume routine (quarterly) testing the following quarter at the same 4 sites tested just prior to the reduction. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490751

PWS NAME: TOHO WATER AUTHORITY EASTERN

POPULATION: 110,102

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 3 POEs: Richard McLaughlin WP, Parkway WP, Camelot West WP.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Continue <u>routine</u> (qtrly) testing at <u>6 sites</u> for both T/H (dual samples). Report disinfectant residuals. Test in accordance with Stage 2 D/DBP Monitoring Plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June-Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491011

PWS NAME: TOHO WATER AUTHORITY WESTERN

POPULATION: 40,330

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 2 POEs: Northwest WP and Southwest WP.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA. WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart. Note: The annual monitoring for di(2-ethylhexyl)phthalate for SW WP may stop per Rule 62-550.516(4)(b). Results for 3 yrs. have been below detection limits. Testing is not required in 2013 for “phthalate.”
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	2600 Emerald Isl. April – June 2017, & 17627 Bali Blvd. July – Sept. 2017	Due to low results, testing has been reduced to two samples annually in two separate calendar quarters. During each sampling event, test for both TTHMs/HAA5s (dual samples). Report disinfectant residuals. Refer to 40 CFR Subpart U 141.605(c)(1) – (c)(8).
Bromate	Monthly	Test each POE monthly of plants with ozonation (Southwest WP). Submit bromate running annual averages quarterly.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491373

PWS NAME: ST. CLOUD, CITY OF (3 WPS)

POPULATION: 50,454

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite (NN)	2017-EA.WP	Sample at each POE* every year.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at the POE of all 3 WPs in 2017.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Special Monitoring <i>Di(2-Ethylhexyl)Adipate</i> <i>Di(2-Ethylhexyl)Phthalate</i>	1 st QTR 2017	Sample at the POE at WTP4 during the 1 st QTR of 2017 and the 1 st QTR of 2018.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System will continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals. Refer to 40 CFR Subpart U 141.605(c)(1) – (c)(8). A System Specific Study was performed during IDSE phase for Stg. 2 sites.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan (new plan requested – to be sent by City after 3/27/15)
Water Quality Parameters (WQPs) <i>WQP reqmnt added 3/27/15 due to pop. increase</i>	June-Sept. 2017	Distribution sites per Optimal WQP Approval Letter (<i>letter to be sent after 3/27/15</i>).
Water Quality Parameters (WQPs) <i>WQP reqmnt added 3/27/15 due to pop. increase</i>	Jan.-June & July-Dec. 2017	Sample at each POE (3 POEs) at least every two weeks per Optimal WQP Approval Letter (<i>letter to be sent after 3/27/15</i>).
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494429

PWS NAME: TOHO WATER AUTHORITY-POINCIANA SYSTEM

POPULATION: 69,447

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 3 active WPs in system: Bella Lago (orig. WP6), Peabody (orig. WP2), & Huron (orig. WP5). Note: Country Club (orig. WP3), Wilderness (orig. WP4), and McLane (orig. WP1) were decommissioned in 2012.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Continue <u>routine</u> (quarterly) testing at 4 sites for both T/H (dual samples). Report the disinfectant residuals. Test in accordance with the Stage 2 D/DBP Monitoring Plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June – Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at <u>each POE</u> at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3490633

PWS NAME: TROPICAL PALMS RESORT

POPULATION: 34

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2025	Sample at each POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491703

PWS NAME: CANOE CREEK SERVICE PLAZA

POPULATION: 68

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Begin <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491705

PWS NAME: GATE PRECAST

POPULATION: 106

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2025	Sample at POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Special Monitoring <i>Carbon Tetrachloride</i>	Quarterly	Sample at POE quarterly until further notice.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3491946

PWS NAME: ASPIRE HEALTH PARTNERS, INC.

POPULATION: 197

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2025	Sample at POE every 9 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494409

PWS NAME: CANE ISLAND POWER PARK

POPULATION: 29

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Begin <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494431

PWS NAME: MACK FARMS

POPULATION: 32

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2022	Sample at each POE every 6 years.
Primary Inorganics	2019	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Special Monitoring <i>Di(2-ethylhexyl)phthalate</i>	Quarterly	Sample at POE quarterly until further notice.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 2/11/11.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494434

PWS NAME: CARROLL STREET STATION

POPULATION: 35

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Continue annual testing July – Sept. 2017. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3494435 PWS NAME: COMMUNITY OF FAITH UNITED METHODIST CHURCH POPULATION: 90

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2019	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at POE annually every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2019	Continue <u>reduced</u> (triennial) testing July – Sept. 2019. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2022	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 5/10/11.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**