

**Annual Summary on Underground Storage Tanks  
Federal Fiscal Year Ending September 30, 2018**

**General Information**

	<b>Total</b>
<b>Number of UST Facilities</b>	9,291
<b>Number of USTs</b>	21,081

Note: Tank, facility and on-site inspection information is based on compliance information found in the Florida Inspection for Storage Tanks (FIRST), and registration data located in the Storage Tank Contamination Monitoring (STCM) databases. These numbers are based on all, UST only and UST/AST co-mingled facilities. Only Annual Compliance Inspections completed during the timeframe noted are included.

**Summary Information for On-Site Inspections**

	<b>Total</b>
<b>UST Facilities Inspected</b>	3,600
<b>% Significant Compliance</b>	65.68%

Percent of UST facilities in Significant Operational Compliance with Release Detection and Prevention Measure Matrixes and compliant with Chapter 62-761, Florida Administrative Code.

**Summary Information for Releases**

	<b>Total</b>
<b>Confirmed UST Releases</b>	153*

\*Note: 51 of the 204 confirmed releases (reported on the STARS and in the Semi-Annual Narrative Report) were later determined to be from Aboveground Storage Tanks, or Office of Emergency Response actions. Initially, all spills are identified within our database, and until the time it is reviewed/inspected, it is not known whether the tank is AST, UST, or tankless.

**Summary Information for Releases – Source and Cause**

Source	Cause															
	Total		Spill		Overfill		Physical/ Mechanical Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
<b>Tank</b>	24	15.7					3	2.0	3	2.0			6	3.9	12	7.8
<b>Piping</b>	12	7.8					9	5.9	1	0.7			1	0.7	1	0.7
<b>Dispenser</b>	19	12.4			2	1.3	12	7.8					3	2.0	2	1.3
<b>STP Area</b>	4	2.6					4	2.6								
<b>Delivery Problem</b>	58	37.9	2	1.3	2	1.3	34	22.2					11	7.2	9	5.9
<b>Other</b>	36	23.5					9	5.9					8	5.2	19	12.4
<b>Total</b>	153		2		4		71		4		0		29		43	

# - number                      % - percent of total number

Note: The release source and cause information is based on confirmed releases in which the Florida DEP was notified by Discharge Report Form and/or accompanying information. This is continuously changing and is only representative of the particular query's date and time.

**Site-Specific Information for Public Acquisition**

Site-specific UST information may be accessed through Oculus at <https://depdms.dep.state.fl.us/Oculus/servlet/login>. Follow the instructions for username and password. Please have the Facility Identification Number (Fac. ID#) available. If the Fac. ID# is not known, you may search for it using [https://fldep.dep.state.fl.us/www\\_stcm/reports/STCM02.asp](https://fldep.dep.state.fl.us/www_stcm/reports/STCM02.asp). For assistance with Oculus, please contact [ServiceDesk@dep.state.fl.us](mailto:ServiceDesk@dep.state.fl.us). All other questions should be directed to Zachary Barrett at [Zachary.Barrett@dep.state.fl.us](mailto:Zachary.Barrett@dep.state.fl.us).