



Florida Department of Environmental Protection Northeast District

PWS ID: 2540058
PWS Name: BASS CAPITAL MHP

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Lot A-28 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	99
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540070

System Type: Community

PWS Name: BEECHER'S POINT S/D

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 156 Beecher's Pt for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	189
Monitoring Frequency	Monthly
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not** rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540239
PWS Name: CRESCENT CITY WTP

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at 800 Block of Read Avenue for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1800
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540482

System Type: Community

PWS Name: HERMITS COVE WATER SYSTEM

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at 215 Monroe for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	558
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540521

System Type: Non-Transient Non-Community

PWS Name: GEORGIA PACIFIC PAPER MILL

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially Annually	Full set 2019 2Q 2017 TCE	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially Annually	Full set 2019 2Q 2017 Dinoseb	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	2017 at Laser Spot Bldg & Bucket Shop Break Room for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1300
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540545

System Type: Community

PWS Name: INTERLACHEN LAKE ESTATES

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at L2 (102 Salam St.) for HAA5s only** Jul-Sep 2017 at L1 (139 Pridgeon St.) for TTHMs only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	717
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540631

System Type: Community

PWS Name: LAKE COMO WATER ASSOCIATION

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	Full set 2018	
			Annually	3Q 2017 Total Xylene	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Moose Lodge- 1982 US Hwy 17 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	450
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540865

System Type: Community

PWS Name: PALM PORT SUBDIVISION

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Apr-Jun 2018 at 115 Cow Creek for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	375
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540881

System Type: Non-Transient Non-Community

PWS Name: PENIEL BAPTIST ACADEMY

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at SOFTBALL FIELD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	250
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540905
PWS Name: POMONA PARK WATER SYSTEM

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	Triennially	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at 342 Broward Ave for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	672
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540911
PWS Name: PORT BUENA VISTA

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially Quarterly	Full set 2018 1 Q 2017 Dalapon (Last required Q, future monitoring TBD)	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2017 at Tap @ Rec Room for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	135
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540959

System Type: Community

PWS Name: RIVERGROVE SUBDIVISION WTP

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is *subject to change*. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 121 W St. Johns Terrace for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	375
Monitoring Frequency	Monthly
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. **Do not rely on the laboratory to submit monitoring results to the Department.**
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540964
PWS Name: RPUMA

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	<div style="background-color: yellow; padding: 2px;">Apr-Jun 2017 at 148 Hicks Street for TTHMs and HAA5s**</div> <div style="background-color: yellow; padding: 2px;">Apr-Jun 2017 at 210 South Hayes for HAA5s only**</div> <div style="background-color: yellow; padding: 2px;">Oct-Dec 2017 at 210 South Hayes for TTHMs only**</div>	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1000
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2540974

System Type: Community

PWS Name: RODEHEAVER BOYS RANCH

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at RANCH BLDG RESTROOM for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	75
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541008
PWS Name: SARATOGA HARBOR

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 126 River Drive for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	150
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541086
PWS Name: ST. JOHN'S HARBOR

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at BOWFIN DRIVE HYDRANT for TTHMs only Oct-Dec 2018 at BOWFIN DRIVE HYDRANT for HAA5s only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	325
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541087

System Type: Community

PWS Name: SAINT JOHNS CAMPGROUND

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Campsite #24 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541180
PWS Name: INTERLACHEN WTP

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at Site L2 (Hose Bibb @ Rec Facility Pavilion) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1260
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541200
PWS Name: RIVER VILLAS

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 141 River Villa Dr for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	95
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541242
PWS Name: WELAKA MHP

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2017 at 118 Cherokee Ln for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	318
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541280
PWS Name: WOOTEN'S MHP

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at 137 SUNSET DR for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	87
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2541450

System Type: Non-Transient Non-Community

PWS Name: SEMINOLE ELECTRIC COOPERATIVE INC.

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	9 years	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at EMPLOYEE PAVILION for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	400
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544255
PWS Name: MELROSE WTP

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at HYDRANT @ 5900 ISLAND ROAD for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1300
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544257

System Type: Community

PWS Name: CRESCENT HILLS SUBDIVISION

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 112 Pine Forest Cir for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	88
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544258

System Type: Community

PWS Name: SILVER LAKE OAKS MHV

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

The below reflects monitoring based on the current well and plant. We understand you are working to install a new well and the monitoring below would be affected. Please contact us.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2017	
		Secondary Contaminants	Triennially	2017	
		Volatile Organics (VOCs)	Quarterly	2017	
		Radionuclides	Quarterly	2017	
		Asbestos	Every 9 years	2017	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Quarterly	2017	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at LOT #9 - DUAL for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Annually	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	102
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544260
PWS Name: R. C. WILLIS WTP (CITY OF PALATKA)

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Annually	2017	
		Secondary Contaminants	Triennially	2017	
		Volatile Organics (VOCs)	Triennially	2017	
		Radionuclides	9 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2017	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	2017 at L1-L4 for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	11900
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	10

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection

Northeast District

PWS ID: 2544265

System Type: Community

PWS Name: MOUNT ROYAL COMMON PROPERTY LLC

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Annually	2018	
		Volatile Organics (VOCs)	Triennially Annually	Full set 2018 2Q 2017 Ethylbenzene and Total Xylene	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at Park B/W for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	86
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544266

System Type: Community

PWS Name: ST. JOHN'S RIVER CLUB UTILITIES

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at CLUBHOUSE 124 BAYOU DR for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	170
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544278
PWS Name: HIDE-A-WAY ACRES

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (Rica Rd. Blowoff) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	60
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544281

System Type: Non-Transient Non-Community

PWS Name: HWY 19 SOUTH WATER SYSTEM LLC.

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at US Fitness sample tap for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	32
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544295
PWS Name: JAN'S MODULAR ESTATES

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2017 at Men's restroom for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	112
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544298
PWS Name: GRASSY LAKE WTP

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (Fire Hydrant @ Duval Ave. & Sherman) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	140
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544392
PWS Name: TOWN OF WELAKA

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at 211 11th Ave for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	2382
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544416
PWS Name: OCHWILLA ELEMENTARY SCHOOL

System Type: Non-Transient Non-Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Xylene (VOC)	Annually	Jul-Sep 2017	
		Radionuclides	Waived	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at L1 (Drinking Fountain) for TTHMs and HAA5s** Jul-Sep 2017 at L2 (Hose Bibb @ Front Office) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	350
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544418

System Type: Non-Transient Non-Community

PWS Name: GEORGIA PACIFIC WFS LLC

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially Annually	Full set 2018 3Q 2017 Total Xylene & Ethylbenzene	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially Annually	Full set 2018 3Q 2017 Diquat	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Office Hosebibb for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	30
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544434

System Type: Community

PWS Name: WESTWOOD VILLAGE APARTMENTS

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (D-1 Hose Bibb) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	50
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544444
PWS Name: EAST PUTNAM REGIONAL

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2024	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at 744 US Hwy 17 South (Kangaroo Expresse) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	1500
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544454
PWS Name: WALKER HEAD START CENTER

System Type: Non-Transient Non-Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at L1 (Outside Hose Bibb) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	79
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544457

System Type: Non-Transient Non-Community

PWS Name: ALF OF POMONA PARK INC

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at S. Parking Lot Tap for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	36
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544460

System Type: Non-Transient Non-Community

PWS Name: CONTINENTAL BUILDING PRODUCTS LLC

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at FRONT OFFICE HOSE BIB for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	140
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544467

System Type: Non-Transient Non-Community

PWS Name: EDGAR MINERALS INC.

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Toluene (VOC)	Annually	Jul-Sep 2017	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Dalapon	Quarterly	Jan-Mar 2017	
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Quarterly 2017 at L1 (Front Office Hose Bibb) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	75
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544468
PWS Name: Q.I. ROBERTS MIDDLE SCHOOL

System Type: Non-Transient Non-Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2017 at OUTSIDE FOUNTAIN for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	505
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544487

System Type: Non-Transient Non-Community

PWS Name: CRESCENT CITY CHRISTIAN ACADEMY

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Immediately	2017	
		Volatile Organics (VOCs)	Annually	2017	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Annually Annually	Full set 2017 1Q 2017 DEHP 2Q 2017 Dalapon	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at Bldg 3 Sample Tap for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Biannually	Jan-Jun 2017	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	62
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2544488
PWS Name: KIRKWOOD ESTATES

System Type: Community

2017 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. **It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.** We encourage you to use the below tables to assist in scheduling and tracking your sampling events.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2017	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at 102 Miller Street for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	45
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pre-treatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.