

**STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION**



**PART II SUPPLEMENT TO
FLORIDA REGIONAL HAZE PLAN FOR
THE SECOND IMPLEMENTATION PERIOD FOR
FLORIDA CLASS I AREAS**

Final Submittal

October 28, 2024

State of Florida
Department of Environmental Protection

Part II Supplement to Florida’s Regional Haze Plan
for the Second Implementation Period for
Florida Class I Areas

Introduction

The Florida Department of Environmental Protection (Department) is proposing to supplement Florida’s pending Regional Haze Plan and proposed State Implementation Plan (SIP) Amendment under the federal Clean Air Act (CAA). Pursuant to the requirements of CAA sections 169A and 169B, and the U.S. Environmental Protection Agency’s (EPA) implementing regulations at 40 CFR 51.308, the Department has prepared this second supplement to Florida’s pending Regional Haze Plan and proposed SIP Amendment for EPA’s approval. This proposed supplement to Florida’s pending Regional Haze Plan and proposed SIP revision addresses commitments and enforceable actions that the state did not include in its submittals dated October 8, 2021, and June 14, 2024, but which the Department included in the Pre-Hearing Submittal of Florida’s Regional Haze SIP Revision (2024-01) package and Pre-Hearing Submittal of Florida’s Supplement to Florida’s Regional Haze Plan for the Second Implementation Period for Class I Areas, each of which were noticed for public comment on January 19, 2024. Florida’s pending Regional Haze Plan and proposed SIP revisions, together with this supplement, address all of the requirements of EPA’s Regional Haze regulations applicable to the second implementation period, from 2019 to 2028, towards the goal of attaining natural visibility conditions in Florida’s designated federal Class I areas.

SIP Submittal Package

On October 8, 2021, Florida submitted to EPA its Regional Haze Plan and associated proposed SIP revision for the second implementation period. This submittal included permits, technical analyses, and commitments addressing specific requirements of the applicable federal regulations.

This second supplement to Florida’s pending Regional Haze Plan and SIP revision addresses the following elements that were not included in Florida’s October 8, 2021, submittal:

- A four-factor analysis for Georgia-Pacific Foley Mill (see revised Section 7.8.4 and Appendix B-1); and
- An air construction permit for Georgia-Pacific Foley Mill (Permit No. 1230001-121-AC) based on the results of the four-factor analysis, which represents reasonable progress (see Appendix A); and

Appendix ID	Description and File Names
Appendix A	Air Construction Permit - Georgia-Pacific Foley Mill (Permit No. 1230001-121-AC)
Appendix B	Four Factor Analyses
B-1a through B-1d	Georgia-Pacific Foley Mill

This action completes the commitments that the Department made in Florida’s proposed Regional Haze Plan for the second Implementation Period, dated October 8, 2021. This submittal is organized to reflect

specific changes that the Department is making to various elements of Florida's 2021 submittal. The Department has not included in this document sections of the 2021 submittal that are complete and do not require any supplementation. The Department notes below the section headings in Florida's pending Regional Haze Plan under which the Department has added supplemental information or updates.

7.7 Evaluating the Four Statutory Factors for Specific Emissions Sources

Section 169A(g)(1) of the CAA and EPA's Regional Haze Rule at 40 CFR 51.308(f)(2)(i) require a state to evaluate the following four "statutory" factors when establishing the reasonable progress goal for any Class I area within a state: (1) cost of compliance; (2) time necessary for compliance; (3) energy and non-air quality environmental impacts of compliance; and (4) remaining useful life of any existing source subject to such requirements.

As noted in Florida's 2021 submittal, on August 20, 2019, EPA issued a memorandum entitled "Guidance on Regional Haze State Implementation Plan for the Second Implementation Period." This memorandum included guidance for characterizing the four statutory factors including which emission control measures to consider, selection of emission information for characterizing emissions-related factors, characterizing the cost of compliance, characterizing the time necessary for compliance, characterizing energy and non-air environmental impacts, characterizing remaining useful life of the source, characterizing visibility benefits, and reliance on previous analysis and previously approved approaches. The Department used this guidance evaluating the four statutory factors for facilities selected for reasonable progress analysis.

On July 8, 2021, EPA issued additional guidance for states to use in developing their Regional Haze SIPs. This guidance noted opportunities for states to leverage both ongoing and upcoming emission reductions under other CAA programs. EPA did reiterate, however, that it expected states to undertake reasonable progress analyses that identify opportunities to advance the national visibility goal consistent with the statutory and regulatory requirements. The guidance focused on factors to consider for source selection, noting that states should select sources for four-factor analysis while setting the threshold at a level that captures a meaningful portion of the state's total contribution to visibility impairment to Class I areas. EPA also discussed the process for refining existing effective controls and characterizing factors for emission control measures and reviewed what control measures were necessary to make reasonable progress. The Department used this guidance in developing this Amendment to Florida's pending Regional Haze Plan.

7.8 Control Measures Representing Reasonable Progress for Individual Sources to be Included in the Long-Term Strategy

The following summarizes the Department's process for determining reasonable progress for Florida sources and whether to implement reasonable progress controls or measures.

For Florida's 2021 submittal, the Department requested that eleven facilities in Florida complete a reasonable progress analysis. Pursuant to EPA's 2019 Regional Haze Guidance, the Department allowed these facilities either to demonstrate that units that are large sources of SO₂ (i.e., those with emissions greater than five tons per year) were already effectively controlled or to complete a four-factor analysis. Many of these facilities provided the Department an analysis demonstrating that units that were large sources of SO₂ at these facilities were effectively controlled. When necessary, these facilities applied for air construction permits to codify those controls as reasonable progress limits (these analyses are documented in Section 7.6.4.1 of Florida's 2021 submittal).

Four-factor analyses were completed for units at four facilities, consistent with EPA's Cost Control Manual and EPA's 2019 and 2021 Regional Haze guidance documents. The Department used these

analyses to determine whether a given control measure was cost-effective. Florida’s 2021 submittal included the results of the four-factor analyses for JEA Northside and WestRock Fernandina Beach.

This proposed second supplement to Florida’s pending Regional Haze Plan includes a four-factor analysis for emissions units at the Georgia-Pacific Foley Mill, which the Department included in the Pre-Hearing Submittal of Florida’s Regional Haze SIP Revision (2024-01) package and Pre-Hearing Submittal of Florida’s Supplement to Florida’s Regional Haze Plan for the Second Implementation Period for Class I Areas, each of which was noticed for public comment on January 19, 2024. The Department has summarized this four-factor analysis below and included supporting documentation in Appendix B to this supplemental submittal.

7.8.3 Georgia-Pacific Foley Mill Four-Factor Analysis

Georgia-Pacific Cellulose/Foley Cellulose, LLC, owns and operates a softwood Kraft pulp mill (referred to as the “Foley Mill”) located in Perry, Florida, which manufactures bleached market, fluff, and specialty dissolving cellulose pulp. The Foley Mill operates under a Title V Major Source Operating Permit (No. 1230001-126-AV), which the Department most recently issued on September 20, 2023. In September 2023, Georgia-Pacific announced that the Foley Mill will be shutdown. Georgia-Pacific has stated that it will explore selling of the mill to potential investors. Because Georgia-Pacific may sell the mill to investors who may restart the facility in the future, permanent retirement of the emissions units is not a feasible path forward at this point. As such, the Foley Mill will accept emission-limiting standards under the Regional Haze program that will apply to designated emissions units if the mill is restarted under new ownership.

Pursuant to EPA’s Regional Haze requirements under 40 CFR 51.308, on June 22, 2020, the Department requested that Georgia-Pacific conduct a four-factor analysis for SO₂ emissions from the following emissions units at the Foley Mill:

- Power Boiler No. 1 (EU-002);
- Bark Boilers No. 1 (EU-004) and No. 2 (EU-019); and
- Recovery Furnaces No. 2 (EU-006), No. 3 (EU-007), and No. 4 (EU-0011).

On October 20, 2020, Georgia-Pacific submitted to the Department a four-factor analysis assessing whether any cost-effective controls were available for the facility (**Appendix B-1a**). Georgia-Pacific’s four-factor analysis did not include a review of Bark Boiler No. 2. The Department determined that a four-factor analysis was not needed for Bark Boiler No. 2 because annual SO₂ emissions from this unit was significantly lower than five tons per year.

In March 2021, the Department sent Georgia-Pacific a Request for Additional Information (RAI) concerning SO₂ emissions from the facility’s recovery furnaces. The Department requested information comparing SO₂ emissions from the Foley Mill with SO₂ emissions from other Florida mills. Based on the factor of “SO₂ emissions per ton of black liquor fired,” it became evident that the recovery furnaces at the Foley Mill were much less efficient at recovering the “smelt” (sodium carbonate and sodium sulfide) needed for the Kraft pulping process. As a result, the Foley Mill had to purchase additional chemicals to replace the lost constituents. Discussions between Georgia-Pacific and the Department led to an agreement to certify the facility’s existing SO₂ CEMS for the recovery furnaces by conducting Relative Accuracy Test Assessments (RATAs). The updated emissions data would allow Georgia-Pacific to explore operational changes for the recovery furnaces that could reduce SO₂ emissions.

Although the existing SO₂ CEMS for the recovery furnaces were not considered “regulatory” CEMS, they were used for process feedback and reporting emissions. After conducting the RATAs, Georgia-Pacific identified two issues that required resolution to ensure the accuracy of recorded data. Specifically,

Georgia-Pacific determined that the span values and relative accuracy of the CEMS were not acceptable. These issues were resolved in August of 2021, and data collected since then are believed to be accurate. Based on this study, the Foley Mill developed SO₂ emissions factors for the three recovery furnaces:

- No. 2 Recovery Furnace: 0.359 lb/MMBtu
- No. 3 Recovery Furnace: 0.714 lb/MMBtu
- No. 4 Recovery Furnace: 0.421 lb/MMBtu

Georgia-Pacific believes that this range of SO₂ emissions factors is the result of the inherent design and age of each furnace.

On August 30, 2022, Georgia-Pacific submitted to the Department a supplemental four-factor analysis, which updated the control reviews and incorporated the more accurate SO₂ emissions that were discovered through the RAI process (**Appendix B-1b**).

On September 20, 2022, representatives from the Department and Georgia-Pacific met at the Foley Mill to discuss the four-factor analysis, cost data, guidance from EPA’s Cost Control Manual, and the inherent design of the recovery furnaces, as well as potential operational improvements that Georgia-Pacific could implement at the Foley Mill to reduce SO₂ emissions.

On November 16, 2022, Georgia-Pacific submitted to the Department a revised four-factor analysis (**Appendix B-1c**) from which the Department developed a final four-factor analysis (**Appendix B-1d**). **Table 7-35** shows the annual SO₂ emissions for the emissions units included in the latest four-factor analysis, which includes the corrected emissions from the recovery furnaces.

**Table 7-35. Actual SO₂ Emissions (Tons/Year) for 2012-2021
Based on Revised AORs**

Year	Total	PB No. 1	BB No. 1	RF No. 2	RF No. 3	RF No. 4	BB No. 2
2012	3896.4	15.2	730.9	785.8	1206.9	1143.5	14.1
2013	4010.1	23.7	728.8	805.6	1195.7	1242.5	13.8
2014	3848.9	32.1	902.2	693.3	1095.7	1092.2	33.4
2015	4072.5	52.5	863.6	721.2	1239.0	1183.1	13.1
2016	4050.4	105.9	677.1	790.2	1248.5	1143.2	85.4
2017	3145.4	60.2	192.4	698.0	1277.0	914.0	3.8
2018	3023.4	114.0	175.8	624.0	1087.0	1020.0	2.6
2019	2891.6	69.8	195.3	650.8	1135.5	837.4	2.8
2020	2310.1	29.3	155.2	332.1	948.4	842.6	2.5
2021	2767.6	49.0	172.5	627.2	1056.8	859.1	3.1

7.8.3.1 Power Boiler No. 1 (EU-002)

Power Boiler No. 1 is capable of producing 195,000 lb/hour of steam while firing a variety of fuels including natural gas, No. 6 fuel oil, on-specification used oil, and onsite/offsite-generated tall oil. The exhaust flue shares a common stack with Power Boiler No. 2 and Bark Boilers Nos. 1 and 2. Power Boiler No. 1 was designed by Babcock & Wilcox Company and constructed in 1953.

The liquid fuels share a common storage tank. The current Title V permit for the Foley Mill allows a maximum fuel sulfur content of 2.5% by weight for No. 6 fuel oil and tall oil. (NOTE: The sulfur content of facility-generated tall oil is typically 0.065 to 0.08% by weight as determined by a 2003 composite sample.)

The boiler also serves as a backup control system for Bark Boiler No. 1 to combust low-volume, high-concentration non-condensable gases (LVHC-NCGs) from the Pulping System (EU 046) for up to 2,800 hours per year. In accordance with the current Title V permit, the LVHC-NCGs are collected and routed to a TRS pre-scrubber prior to entering the boiler to control total reduced sulfur (TRS) compounds. The TRS pre-scrubber is required to remove 50% of the TRS compounds from the LVHC-NCGs.

Between 2016 and 2021, Power Boiler No. 1 fired no fuel oil, but averaged 65.5 tons SO₂ per year. The Department assumes the SO₂ emissions are primarily from firing LVHC-NCG as a backup control device. The Foley Mill identified a wet scrubber and a dry sorbent injection system as available and feasible controls.

7.8.3.1.1 Estimated Cost of Compliance

Table 7-35a summarizes the general costs for the analyses provided.

Table 7-35a. Foley Mill Power Boiler No. 1 Caustic Cost-Effective Analysis

Supporting Data for Control Device Cost Effectiveness Calculations

Parameter	Value	Note(s)
Operating Labor Cost	30.68 \$/hr	1
Maintenance Labor Cost	32.15 \$/hr	1
Caustic Cost	480 \$/ton	1
Electricity Cost	0.0755 \$/kWh	1
Water Cost	0.86 \$/Mgal	2
Wastewater Treatment Cost	0.64 \$/Mgal	1

1. Labor, caustic, electricity, and wastewater based on Foley specific data.
2. Water cost based on data from similar facilities.

Chemical, Energy, Water Use Basis

Amount of NaOH per SO ₂ , based on molar ratio	1.25 lb/lb SO ₂ Removed
NaOH solution, 50%	2.5 lb/lb SO ₂ Removed
Data for Recovery Furnace	
Electricity per AFPA data	440.92 kW/MMlb BLS
Freshwater use per AFPA Data	40.00 gpm/(MMlb BLS/day)
Wastewater disposal per AFPA Data	4.00 gpm/(MMlb BLS/day)
Data for Boiler	
Electricity per previous BART Control data	Reference is 420,000 acfm 0.00175 KWhr/acfm
Freshwater use per previous BART Data	0.233 Mgal/acfm
Wastewater disposal per Previous BART data	0.082 Mgal/acfm

1. Caustic use based on $2\text{NaOH} + \text{SO}_2 \rightarrow \text{Na}_2\text{SO}_3 + \text{H}_2\text{O}$
2. Usage of electricity, water, and waste based on reference cost estimates for controls.
AFPA data basis is <http://www.nescaum.org/documents/bart-resource-guide/be-k-capital-operating-cost-estimate-9-20-01.pdf>
Previous BART Data is based on a 2008 BART control submittal for a similar GP unit.

Wet Scrubber – The Foley Mill used a recent cost estimate developed in 2020 for a wet scrubber to control exhaust from a lime kiln at a facility in Oregon. This cost estimate was adjusted for the Power Boiler No. 1 by ratioing the flow rates to the 0.6 power (an engineering estimating technique known as the Rule of Six Tenths). Caustic use was based on the molar ratio of sodium hydroxide to SO₂ emitted with an assumed 10% loss. Electricity requirements, water use, and waste generation costs were based on a detailed vendor quote for a similar system at a facility in Georgia. These usage rates were scaled again based on air flow rates. Facility costs for labor, water, waste, and caustic were based on the Foley Mill’s site-specific data or data from other similar facilities as identified in **Table 7-35a** for general costs.

Capital costs were annualized based on a 30-year life span and 5% interest rate as outlined in EPA’s *DRAFT EPA SO₂ and Acid Gas Control Cost Manual*. The actual SO₂ emissions were estimated based on an average of 81.35 tons/year (2015 – 2019) and a wet scrubber removal efficiency of 98%.

Table 7-35b summarizes the capital, operating, and estimated cost-effectiveness to install and operate a wet scrubber. Based on this analysis, a total capital investment of almost \$7 million and the accompanying annual operating costs result in an estimated cost effectiveness of \$13,547/ton to reduce actual SO₂ emissions by approximately 80 tons. The Department determined that installation of a wet scrubber on Power Boiler No. 1 at the Foley Mill is not cost effective.

Table 7-35b. Foley Mill Power Boiler No. 1 Wet Scrubber Cost Effective Analysis

Capital & Operating Cost Evaluation for SO ₂ Scrubber for PB1		
Cost Category	Value	Notes ¹
Vendor Quoted System Costs (S) =	\$7,200,000	Based on 2020 cost estimate for Lime Kiln for similar 4-factor Analysis
Vendor Quoted System (cfm) =	124,500	
CFM analyzed	115,770	
Engineering Factor =	1.0	
Total Capital Investment (TCI)	\$6,892,686	Prorated from previous vendor quote based on capacity ratio raised to the power of
Capital Recovery		
Capital Recovery Factor (CRF) ²	0.0651	CRF = 5% interest and 30-yr equipment life based on July 2020 Draft Section 5 Contr
Capital Recovery Cost (CRC)	\$448,714	
Operating Costs		
<i>Direct Operating Costs (DOC)</i>		
Operating Labor	\$16,797	A = Based on 0.5 hour per shift, 3 shifts per day
Supervisory Labor	\$2,520	B = 15% of operating labor
Maintenance Labor	\$17,602	C = Based on 0.5 hour per shift, 3 shifts per day
Maintenance Materials	\$17,602	D = Equivalent to maintenance labor
Caustic Costs	\$105,230	E = Mass of NaOH to neutralize SO ₂ times chemical cost plus 10% waste (based on example in July 2020 Draft Section 5 Control Cost Manual)
Electricity Usage	202	Power (kWh) ratioed based on similar boiler cost estimate values.
Cost of Electricity Usage	\$133,793	F = E × Electricity Cost
Fresh Water	\$23,199	G = Freshwater use * water cost
Water Disposal	\$6,065	H = Water disposal amount * disposal cost
Total Direct Operating Costs (DOC)	\$322,808	DOC = A + B + C + D + E + F + G + H
<i>Indirect Operating Costs (IOC)</i>		
Overhead	\$32,713	H = 60% × (A + B + C + D)
Property Tax	\$68,927	I = 1% × TCI
Insurance	\$68,927	J = 1% × TCI
Administrative Charges	\$137,854	K = 2% × TCI
Total Indirect Operating Costs (IOC)	\$308,420	IOC = H + I + J + K
Total Annualized Cost (AC) =	\$1,079,942	AC = CRC + DOC + IOC
SO ₂ Uncontrolled Emissions (tpy)	81.35	
SO ₂ Removed (tpy)	79.72	98.0% Removal Efficiency
Cost per ton of SO₂ Removed (\$/ton)	\$13,547	\$/ton = AC / Pollutant Removed

1. TCI per 2020 Envitech estimate for Lime Kiln scrubber at another GP facility.
2. U.S. EPA OAQPS, EPA Air Pollution Control Cost Manual Draft, July 2020, Section 5 SO₂ and Acid Gas Controls.

Dry Sorbent Injection System – The Foley Mill also estimated the capital cost for a system to inject milled trona using an April 2017 Sargent and Lundy report prepared under a U.S. EPA contract. Facility labor, chemical, and utility costs were used to estimate the capital and annualized costs of operating the system (see **Table 7-35c**). The Sargent and Lundy report indicates that 90% SO₂ control can be achieved when injecting trona prior to a fabric filter. Approximately 73 tons/year of actual SO₂ emissions could be removed based on an average of 81.3 tons of SO₂/year (2015 – 2019) and a removal efficiency of 90%. The capital recovery factor for annualizing the capital costs was based on 5% interest and 30-year life for the boiler.

**Table 7-35c. Foley Mill Power Boiler No. 1
Dry Sorbent Injection System Cost Effective Analysis**

Foley PB1
Capital and Annual Costs Associated with Trona Injection

Variable	Designation	Units	Value	Calculation
Heat Input		MMBtu/hr	151.3	
Unit Size	A	MW	13	Based on 3-year average actual, assumes 30% efficiency to convert to equivalent MW output
Retrofit Factor	B	-	1	
Gross Heat Rate	C	Btu/kWh	37,944	Assumes 30% efficiency
SO ₂ Rate (uncontrolled)	D	lb/MMBtu	0.124	Based on 3-year average actual
Type of Coal	E	-		
Particulate Capture	F	-	Fabric filter	
Sorbent	G	-	Milled Trona	
Removal Target	H	%	90	Per the Sargent and Lundy document, 90% reduction can be achieved using milled trona with a fabric filter.
Heat Input	J	Btu/hr	1.51E+08	151.33 MMBtu/hr
NSR	K	-	2.61	Milled Trona w/ FF = 0.208e ^A (0.0281 ^H)
Sorbent Feed Rate	M	ton/hr	0.20	Trona = (1.2011*10 ^{A-06}) ^K *A ^C *D
Estimated HCl Removal	V	%	98.85	Milled or Unmilled Trona w/ FF = 84.598 ^H *A ^{0.0346}
Sorbent Waste Rate	N	ton/hr	0.16	Trona = (0.7387+0.00185 ^H /K)*M
Fly Ash Waste Rate	P	ton/hr	0.00	Ash in Bark = 0.05; Boiler Ash Removal = 0.2; HHV = 4600 (A ^C)*Ash*(1-Boiler Ash Removal)/(2*HHV; fires primarily natural gas, set to zero.
Aux Power	Q	%	0.30	Milled Trona M ²⁰ /A
Sorbent Cost	R	\$/ton	170	Default value in report
Waste Disposal Cost	S	\$/ton	100	Default value for disposal without fly ash
Aux Power Cost	T	\$/kWh	0.06	Default value in report
Operating Labor Rate	U	\$/hr	49.09	Typical labor cost, includes 60% overhead cost

SO ₂ Control Efficiency:	90%
Representative Emissions	81.3
Controlled SO ₂ Emissions:	73.2

Capital Costs				
Direct Costs				
BM (Base Module) scaled to 2019 dollars		\$	\$	5,864,531 Milled Trona if (M>25, 820000 ^B *M, 8300000 ^B *(M ^{0.284}))
Indirect Costs				
Engineering & Construction Management	A1	\$	\$	586,453 10% BM
Labor adjustment	A2	\$	\$	293,227 5% BM
Contractor profit and fees	A3	\$	\$	293,227 5% BM
Capital, engineering and construction cost subtotal	CECC	\$	\$	7,037,438 BM+A1+A2+A3
Owner costs including all "home office" costs	B1	\$	\$	351,872 5% CEC
Total project cost w/out AFUDC	TPC	\$	\$	7,389,309 B1+CEC
AFUDC (0 for <1 year engineering and construction cycle)	B2	\$		0 0% of (CECC+B1)
Total Capital Investment	TCI	\$	\$	7,389,309 CECC+B1+B2

Annualized Costs				
Fixed O&M Cost				
Additional operating labor costs	FOMO	\$	\$	204,206 (2 additional operator)*2080*U
Additional maintenance material and labor costs	FOMM	\$	\$	58,645 BM*0.01/B
Additional administrative labor costs	FOMA	\$	\$	6,830 0.03*(FOMO+0.4*FOMM)
Total Fixed O&M Costs	FOM	\$	\$	269,681 FOMO+FOMM+FOMA
Variable O&M Cost				
Cost for Sorbent	VOMR	\$	\$	292,753 M*R
Cost for waste disposal that includes both sorbent & fly ash waste not removed prior to sorbent injection	VOMW	\$	\$	138,202 (N+P)*S
Additional auxiliary power required	VOMP	\$	\$	113,801 Q*T*10*ton SO ₂
Total Variable O&M Cost	VOM	\$	\$	544,756 VOMR+VOMW+VOMP
Indirect Annual Costs				
General and Administrative	2%	of TCI	\$	147,786
Property Tax	1%	of TCI	\$	73,893
Insurance	1%	of TCI	\$	73,893
Capital Recovery	6.51%	x TCI	\$	480,685
Total Indirect Annual Costs			\$	776,258
Life of the Control:		30 years		5.00% interest
Total Annual Costs			\$	1,590,695
Total Annual Costs/SO₂ Emissions			\$	21,727

⁽¹⁾Cost information based on the April 2017 "Dry Sorbent Injection for SO₂/HCl Control Cost Development Methodology" study by Sargent & Lundy for a milled Trona system. 2016 costs scaled to 2019 costs using the CEPCI.

Based on this analysis, a total capital investment of more than \$7 million to install a dry sorbent injection system and the accompanying operating costs result in an annualized cost effectiveness of \$21,727/ton to reduce actual SO₂ emissions by approximately 73 tons/year.

Foley Mill's initial cost effectiveness values were:

- Installing and operating a wet scrubber - \$13,547/ton of SO₂ removed;
- Using a dry sorbent injection system - \$21,727/ton of SO₂ removed.

The Department determined that neither of these values were cost effective. EPA's Regional Haze Guidance requires states to impose SIP emission limits that reduce the unit's potential to emit to levels that are slightly higher than the historical emission levels. Since the evaluated controls were not cost-effective, the Department is proposing to impose low-sulfur fuel restrictions on this unit as a practical means of reducing SO₂ emissions.

7.8.3.1.2 Time Necessary for Compliance

Installation of wet scrubbers and dry sorbent injection systems at power boiler systems can require up to four years to secure funding, make the required technical changes, and perform testing and monitoring to ensure proper system operation. Power Boiler No. 1 has fired only natural gas during the last six years, and permit restrictions requiring low-sulfur fuels could be implemented immediately. Also, the reduction in maximum fuel oil sulfur content of No. 6 fuel oil could be implemented for future purchases.

7.8.3.1.3 Energy and Non-Air Quality Impacts of Compliance

Typical energy and non-air quality impacts of compliance include sorbent, caustic, and sulfuric acid costs, additional electrical costs associated with scrubber and dry sorbent injection operation, additional fresh water for scrubber needs and wastewater disposal. There are no energy impacts associated with using lower sulfur fuel oil since the heating value is expected to remain the same with lower sulfur content. Use of lower sulfur fuel oil also does not result in any non-air quality environmental impacts.

7.8.3.1.4 Remaining Useful Life

Power Boiler No. 1 was assumed to have a remaining useful life of 30 years or more.

7.8.3.1.5 Summary of Findings for No. 1 Power Boiler

The Department determined that there were no cost-effective emission reductions for Power Boiler No. 1. The Department has not included revised calculations for the wet scrubber or DSI because the updated costs remain an order of magnitude above a reasonable cost-effectiveness threshold. EPA's Regional Haze Guidance requires states to impose SIP emission limits that reduce the unit's potential to emit to levels that are slightly higher than the historic emissions for that unit. The Department has determined that the existing measures at the No. 1 Power Boiler *are necessary* for reasonable progress and emissions limits and associated supporting conditions are required to be adopted into the SIP. Therefore, the Department is proposing to impose low-sulfur fuel restrictions on Power Boiler No. 1 and a requirement that the unit fires only natural gas except under certain limited circumstances.

Permit No. 1230001-121-AC (see Appendix A) sets the following requirements for Foley Mill's Power Boiler No. 1:

- Shall fire only natural gas except for periods of natural gas curtailment, pipeline disruptions or physical mill problems that otherwise prevent the firing of natural gas in this unit. When necessary, liquid fuels may be fired during these exceptional periods.
- For future additions of No. 6 fuel oil to the common tank, the maximum sulfur content shall be 1.02% by weight with compliance determined by maintaining records of fuel deliveries, analytical methods and results of analysis.
- Tall oil is no longer an authorized fuel.
- The No. 1 Power Boiler shall only combust the LVHC-NCG gases when the No. 1 Bark Boiler is offline, unavailable to burn NCG gases, or as necessary for compliance with the requirements of 40 CFR 63, Subpart S or other rules such as monitoring for detectable leaks in a closed vent system.

The Department notes that setting a maximum fuel sulfur specification of 1.02% by weight will likely result in fuel purchases well below 1% sulfur. The Department considers switching to a lower sulfur No. 6 fuel oil (1.0% or less) to be cost-effective and necessary for reasonable progress. Permit No. 1230001-121-AC (see Appendix A) includes the following permit conditions, which the Department proposes to add to Florida's Regional Haze SIP:

- Power Boiler No. 1 shall fire only natural gas except for periods of natural gas curtailment, pipeline disruptions, or physical mill problems that otherwise prevent the firing of natural gas in this unit. When necessary, liquid fuels from the common tank may be fired during these exceptional periods.
- For future additions of No. 6 fuel oil to the common tank, the maximum sulfur content shall be 1.02% by weight with compliance determined by maintaining records of fuel delivery receipts and/or sampling and analysis.
- Tall oil is no longer an authorized fuel for this unit.

These permit conditions represent reasonable progress for SO₂ reduction. These requirements will be included in Florida's Regional Haze SIP.

7.8.3.2 Bark Boiler No. 1 (EU004)

Bark Boiler No. 1 is capable of producing 200,000 lb/hour of steam while firing a variety of fuels including wood materials (bark, chips, sawdust, etc.), natural gas, No. 6 fuel oil, facility generated on-specification used oil, and onsite/offsite-generated tall oil. The exhaust flue shares a common stack with Power Boiler Nos. 1 and 2 and Bark Boiler No. 2.

Bark Boiler No. 1 is the primary control device for combusting LVHC-NCG from the Pulping System (EU 046). The LVHC-NCG are collected and routed through the spray nozzle-type TRS pre-scrubber prior to this boiler for destruction. As previously described, Power Boiler No. 1 is used as the backup control system for the Pulping System (EU 046). Particulate matter emissions are controlled by a cyclone collector and a wet venturi scrubber. Particles collected by the cyclone collector are recirculated back to the boiler. Although some control of SO₂ emissions results from absorption onto fly ash and particle removal through the wet venturi scrubber, caustic can also be added to the wet scrubbing media to adjust the pH level to further control SO₂ emissions. The current permit conditions for Bark Boiler No. 1 requires adding caustic to the wet venturi scrubber only when the TRS pre-scrubber is not operational. Following the scrubber is a chevron type demister to trap and remove entrained water droplets.

Over the last five years, SO₂ emissions have averaged about 178 tons/year. Since the annual average No. 6 fuel oil firing rate has been less than 1000 gallons per year, most of the SO₂ emissions are likely from combusting LVHC-NCG from the Pulping System (EU 046). Foley Mill has proposed cost-effective operational changes to the Bark Boiler No. 1. Specifically, the Foley Mill has proposed to run the existing wet venturi scrubber with added caustic at all times NCG gases are being combusted in the Bark Boiler No. 1, not just when the TRS pre-scrubber is unavailable.

7.8.3.2.1 Estimated Costs of Compliance

Increasing the amount of time caustic is added to the wet scrubber to maintain the pH level at 8.0 for SO₂ control also requires addition of an antiscalant to minimize fouling and scaling due to caustic buildup in the boiler. The Foley Mill used current caustic and antiscalant costs with the molar ratio of sodium hydroxide to SO₂ emissions to estimate the costs (see **Table 7-35d**). The achievable control efficiency for this change was estimated to be approximately 51% reduction from the average SO₂ emissions of 188 tons/year (2017 – 2019).

Table 7-35d. Foley Mill Bark Boiler No. 1 Caustic Cost-Effective Analysis

Operating Cost Evaluation for SO₂ Caustic Addition for BB1

Emission Rate with Caustic (lb/ADTUBP)	1.74
Emission Rate without Caustic and with Pre-scrubber (lb/ADTUBP)	3.54
% Control - caustic	51%
Caustic Use	2.5 lb NaOH per lb SO ₂ removed
Caustic Loss	10%
Caustic Cost	480 \$/ton Caustic
Anti-scaler	\$125,000 per year
Cost per ton of SO ₂ removed, Caustic	\$1,320 \$/ton
Cost per ton of SO ₂ removed, Anti-Scaler	\$1,307 \$/ton
Total tons reduced	96 tons
Total cost per ton	\$2,627

1. Emissions rates based on stack test data and % control represents improvement over operation with pre-scrubber.
2. Caustic use based on molar ratio.
3. Anti-scaler based on estimated cost of using caustic full time and improved caustic control.

This operational change results in an estimated annualized cost effectiveness of \$2,627/ton to remove approximately 96 tons/year of SO₂ emissions, which the Department determined to be cost effective for this Regional Haze analysis. The estimate of a 51 percent control was determined through engineering tests that demonstrated that use of the wet venturi scrubber with caustic was a more effective control device for SO₂ than the use of the TRS pre-scrubber.

7.8.3.2.2 Time Necessary for Compliance

The Foley Mill currently adds weak wash to the existing wet scrubber media as an SO₂ control measure under a Title V Compliance Assurance Monitoring Plan. Caustic and scalant could be added to the scrubber control system within 12 months.

7.8.3.2.3 Energy and Non-Air Quality Impacts of Compliance

The existing wet scrubber would continue to operate in the same general manner without any significant energy or non-air quality impacts from implementing this control measure.

7.8.3.2.4 Remaining Useful Life

Bark Boiler No. 1 was assumed to have a remaining useful life of 30 years or more.

7.8.3.2.5 Summary of Findings for Bark Boiler No. 1

The primary factor that the Department used to determine whether a control measure is necessary for reasonable progress was the cost of compliance. The Department then further considered the other three factors (time necessary for compliance, energy and non-air quality impacts, and remaining useful life). Remaining useful life in this case is already considered in the costs factor through annualizing the costs of compliance. For the Bark Boiler No. 1, the Department has determined that adding caustic and scalant to the scrubber system is cost-effective and, therefore, the Department has determined that these controls are necessary for reasonable progress. The Department is also proposing to impose low-sulfur fuel restrictions on Bark Boiler No. 1.

The Department has determined that the existing measures at the Number 1 Bark Boiler *are necessary* for reasonable progress and emissions limits and associated supporting conditions are required to be adopted into the SIP. Permit No. 1230001-121-AC (see Appendix A) sets the following requirements for Foley Mill's Bark Boiler No. 1:

- Bark Boiler No. 1 shall fire only wood materials and natural gas except for periods of natural gas curtailment, pipeline disruptions, system readiness testing or physical mill problems that otherwise prevent the firing of natural gas in this unit. When necessary, liquid fuels from the common tank may be fired during these exceptional periods.
- For future additions of No. 6 fuel oil to the common tank, the maximum sulfur content shall be 1.02% by weight with compliance determined by maintaining records of fuel delivery receipts and/or sampling and analysis.
- Tall oil is no longer an authorized fuel for this unit.
- At all times that LVHC-NCG or No. 6 fuel oil is fired, the Wet Venturi Scrubber shall be operational. Caustic or weak wash shall be added to the wet venturi scrubbing media to maintain a pH level of at least 8.0 (3-hour block average) and a wet scrubber flow rate of 1,000 gpm (3-hour block average) for the control of SO₂ emissions. Recordkeeping and reporting requirements for this condition are included in the permit.

These permit conditions represent reasonable progress for SO₂ reduction. Florida proposes that these requirements, together with associated monitoring, reporting, and recordkeeping requirements (Permit No. No. 1230001-121-AC) be included as a component of Florida's Regional Haze SIP.

7.8.3.3 Recovery Furnaces Nos. 2, 3, and 4 (EU006, EU007, EU011)

Recovery Furnace No. 2 is a low-odor, non-direct contact evaporator unit that produces a nominal 380,000 lb/hour of steam by firing black liquor. The furnace was originally constructed by Babcock & Wilcox in 1957 as a direct-contact evaporator design recovery furnace and later modified. Particulate matter emissions are controlled by an electrostatic precipitator. The exhaust stack is equipped with a CEMS to continuously monitor CO, NO_x, SO₂ and TRS. Opacity is continuously monitored by a COMS.

Recovery Furnace No. 3 is a low-odor non-direct contact evaporator unit that produces approximately 325,000 lb/hour of steam by firing black liquor. The furnace was originally constructed by Combustion Engineering in 1964 as a direct-contact evaporator design recovery furnace. Particulate matter emissions are controlled by an electrostatic precipitator. The exhaust stack is equipped with a CEMS to continuously monitor CO, NO_x, SO₂ and TRS. Opacity is continuously monitored by a COMS.

Recovery Furnace No. 4 is a low-odor non-direct contact evaporator unit that produces approximately 450,000 lb/hour of steam by firing black liquor. The furnace was originally constructed by Babcock & Wilcox in 1973 with a membrane wall construction to minimize air in-leakage. Particulate matter emissions are controlled by an electrostatic precipitator. The exhaust stack is equipped with a CEMS to continuously monitor SO₂ and TRS. Opacity is continuously monitored by a COMS.

In addition to black liquor with a solids content of approximately 65-72%, each boiler is authorized to fire the following fuels for startup, shutdown, and as a supplemental fuel to maintain flame stability in the furnace: No. 6 fuel oil, No. 2 distillate oil, onsite or offsite-generated tall oil, on-specification used oil that meets the applicable requirements of 40 CFR Part 279; natural gas; ultra-low sulfur distillate oil and methanol (No. 2 Recovery Furnace only).

Recovery furnaces fire black liquor as the primary fuel for recovery operations. Black liquor contains lignin (solids) from previously processed wood. This process recovers inorganic chemicals as smelt (sodium carbonate and sodium sulfide), combusts the organic chemicals so they are not discharged as pollutants, and recovers the heat of combustion in the form of steam. Particles captured in the furnace exhaust by the electrostatic precipitator also contain sodium carbonate and sodium sulfide and are returned to the recovery furnace. The chemicals recovered in the smelt are dissolved in water to make green liquor which is typically reacted with lime to regenerate white liquor. White liquor is used in the pulping process to separate lignin and hemicellulose from the cellulose fiber in wood chips for the production of pulp. Inefficient recovery furnaces require the purchase of raw materials to make up for the lost chemicals.

Sulfur dioxide forms during combustion when some of the sulfur in the black liquor is oxidized. High bed temperatures cause sodium fuming which retains sulfur in the bed. A higher solids content and firing rate of black liquor generates higher bed temperatures. A higher solids content can be achieved by increasing the capacity of evaporator equipment. Proper air distribution will also drive sulfur to the smelt, reducing SO₂ emissions. Fuels containing sulfur may also generate SO₂ emissions.

Although modern recovery furnaces operate with a black liquor solids content of 75% or more, which reduces the generation of SO₂ emissions, the three existing recovery furnaces were designed for a maximum solids content of only 70% solids. Modern furnaces also employ air systems that distribute air at three levels to ensure that sulfur is driven to the smelt and not released in the fume. The existing units at the Foley Mill do not have this air distribution system.

In 2017, the Foley Mill installed the No. 5 black liquor evaporator designed to produce 70% solids and match requirements of the existing recovery furnaces. Increasing the solids content above about 72% is not practical and results in issues with the current firing system, liquor heater system, and existing storage

capacities. For units constructed in the 1950s, increasing the firing rate and temperatures to the existing recovery furnaces can exceed the mechanical design of the lower furnace and result in premature failure of the lower furnace tubes.

Other design limitations for Recovery Furnaces Nos. 2 and 3 are the “short” furnace design that is common for this vintage of direct-contact furnaces, despite the modifications to non-direct contact evaporator units. A short furnace design results in a low residence time over the nose arch of the furnace (i.e., there is less contact time with sodium fumes that capture the sulfur in the lower furnace). As the black liquor rate and bed temperature increase, carryover will plug the furnace, reducing the capability to sustain operation at a given rate and increasing SO₂ emissions.

The Department requested that Georgia Pacific consider improving operational characteristics that may, on their own or in combination, contribute to a reduction in SO₂ emissions and increased recovery efficiency. Such operational characteristics could include increasing the solids content for black liquor to increase the bed temperature, sulfidity (sulfur-to-sodium ratio), air distribution, or stack oxygen content. Typically, SO₂ emissions from recovery furnaces are minimized by equipment design and operational considerations.

Georgia-Pacific concluded that the existing recovery furnaces are physically limited by the inherent “short” furnace design, original metals used in the 1950s, and designed metal thickness. For example, attempting to increase the narrow nose arch could increase the exhaust retention time but also cause more fouling. More fouling requires more shutdowns to conduct washes, which add thermal stress cycles to the unit. For recovery furnaces, safety is a critical concern when considering major physical changes to such vintage units because the combination of molten smelt and large quantities of water in the heat exchanger tubes make these furnaces potentially explosive, a critical concern at all times.

Georgia-Pacific considered the potential application of several common flue gas desulfurization systems to the recovery furnaces, including spray dryer absorbers, dry sorbent injection, and conventional wet scrubbers. Each of the recovery furnaces currently use electrostatic precipitators (ESP) to control particulate matter, which is common in the industry. To be cost effective, the spray dryer absorber and dry sorbent injection systems would inject caustic materials upstream of the ESP to neutralize sulfur dioxide and remove the resulting solids formed as well as any excess caustic materials. This would, however, contaminate and adversely impact the recovery process such that these systems are not considered feasible for recovery furnaces. The Foley Mill evaluated a wet scrubber installed after the ESP for each existing unit as described in a revised four-factor analysis submitted November 16, 2022, with the following changes:

- A unit-specific wet scrubber capital cost was provided by an equipment vendor for each recovery furnace that reflects its size and configuration.
- The property tax, insurance, and administrative costs were removed from the analysis.
- Capital recovery factor was updated to reflect an interest rate of 7% and a 30-year remaining useful life.
- Maintenance costs were updated to reflect the most recent control cost manual guidance and confirmed with internal engineering resources.
- Material costs were updated with the most current data.

7.8.3.3.1 Estimated Costs of Compliance – Recovery Furnaces Nos. 2, 3, and 4

For each recovery furnace, the tables below summarize the total capital investment, the annualized capital and operating costs, and the cost-effectiveness in terms of dollars per ton of SO₂ removed.

**Table 7-35e-1. Foley Mill Recovery Furnace No. 2
Scrubber Cost Effective Analysis**

Total Capital Investment (TCI) - No. 2 Recovery Furnace

Total Project Cost	Cost Category	Cost
		\$22,000,000
<hr/>		
Equipment		
	Andritz SO2 Scrubber Package	\$5,735,000
	RO System	\$900,000
	Chemical Skids	\$175,000
	Freight	<u>\$544,800</u>
		\$7,354,800
<hr/>		
Installation		
	Demolition for Construction	\$150,000
	Civil Structural Scrubber Adjustment	\$525,000
	Mechanical Installation on RO System	\$800,000
	Scrubber Electrical OSBL	\$1,100,000
	Mechanical Installation Scrubber OSBL	<u>\$5,250,000</u>
		\$7,825,000
<hr/>		
	Balance of Plant (7%)	\$1,062,586
<hr/>		
Project Costs		
	Engineering (10%)	\$1,624,239
	Project Management (5%)	\$812,119
	Construction Management (2.5%)	\$406,060
	Escalation (8%)	\$1,299,391
	Contingency (10%)	<u>\$1,624,239</u>
		\$5,766,047

Table 7-35e-2. Foley Mill Recovery Furnace No. 2 Scrubber Cost Effective Analysis

Capital & Operating Cost Evaluation for 502 Scrubber for No. 2 Recovery Furnace

Cost Category	Value	Notes
BLS Analyzed (ton BLS/day) =	1,171	Permitted Capacity
Total Capital Investment (TCI)	\$22,000,000	Andritz/GP estimate provided August 15, 2022
Capital Recovery		
Capital Recovery Factor (CRF)	0.0806	CRF = 7% interest and 30-yr equipment life
Capital Recovery Cost {CRC}	\$1,772,901	CRC = TC / x CRF
Operating Costs		
<i>Direct Operating Costs (DOC)</i>		
Operating Labor	\$15,306	A= Based on 0.5 hour per shift, 3 shifts per day
Supervisory Labor	\$2,296	B = 15% of operating labor
Maintenance Costs	\$330,000	C = Based 0.015 TCI, per May 2021FGD control cost manual
Caustic Cost ^t	\$1,201,657	E = Mass of NaOH to neutralize 502 times chemical cost plus 10% waste (based on example in July 2020 Draft Section 5 Control Cost Manual)
Sulfuric Acid Costs (for Neutralization)	\$265,339	E = Mass of H2SO4 to neutralize NaOH times chemical cost plus 10% waste
Electricity Usage	1,033 kWh	Power (kWh) ratioed based on AFPA values.
Cost of Electricity Usage	\$766,504	F = E x Electricity Cost
Fresh Water	\$38,334	G = Freshwater use • water cost
Water Disposal	\$3,139	H = Water disposal amount• disposal cost
Total Direct Operating Costs (DOC)	\$2,622,575	DOC = A + B + C + D + E + F + G + H
<i>Indirect Operating Costs (IOC)</i>		
Overhead	\$208,561	H = 60% x (A + B + C + D)
Property Tax		I = 1% x TCI
Insurance		J = 1% x TCI
Administrative Charges		K = 2% x TCI
Total Indirect Operating Costs (IOC)	\$208,561	IOC = H + I + J + K
Total Annualized Cost (AC)=	\$4,604,037	AC = CRC + DOC + IOC
50 ₂ Uncontrolled Emissions (tpy)	657.59	
50 ₂ Removed (tpy)	591.83	90% Removal Efficiency
Cost per ton of 50 ₂ Removed (\$/ton)	\$7,779	\$/ton = AC / Pollutant Removed

• U.S. EPA OAQPS, EPA Air Pollution Control Cost Manual Draft, July 2020, Section 5 50₂ and Acid Gas Controls.

^t Caustic costs are highly variable in the current market. The basis of the value shown is the actual average cost for the Foley Mill for the 12-month period ending October 2022. During this timeframe, the monthly values have varied from \$460/ton to \$920/ton.

**Table 7-35f-1. Foley Mill Recovery Furnace No. 3
Scrubber Cost Effective Analysis**

Total Capital Investment (TCI) - No. 3 Recovery Furnace

Total Project Cost	Cost Category	Cost
		\$20,500,000
<hr/>		
Equipment		
	Andritz SO2 Scrubber Package	\$4,998,000
	RO System	\$900,000
	Chemical Skids	\$175,000
	Freight	<u>\$485,840</u>
		\$6,558,840
<hr/>		
Installation		
	Demolition for Construction	\$150,000
	Civil Structural Scrubber Adjustment	\$505,200
	Mechanical Installation on RO System	\$800,000
	Scrubber Electrical OSBL	\$1,100,000
	Mechanical Installation Scrubber OSBL	<u>\$5,052,000</u>
		\$7,607,200
<hr/>		
Balance of Plant (7%)		\$991,623
<hr/>		
Project Costs		
	Engineering (10%)	\$1,515,766
	Project Management (5%)	\$757,883
	Construction Management (2.5%)	\$378,942
	Escalation (8%)	\$1,212,613
	Contingency (10%)	<u>\$1,515,766</u>
		\$5,380,970

Table 7-35f-2. Foley Mill Recovery Furnace No. 3 Scrubber Cost Effective Analysis

Capital & Operating Cost Evaluation for SO₂ Scrubber for No. 3 Recovery Furnace

Cost Category	Value	Notes
BLS Analyzed (ton BLS/day) =	988	Permitted Capacity
Total Capital Investment (TCI)	\$20,500,000	Andritz/GP estimate provided August 15, 2022
Capital Recovery		
Capital Recovery Factor (CRF)	0.0806	CRF = 7% interest and 30-yr equipment life
Capital Recovery Cost (CRC)	\$1,652,021	CRC= TC / x CRF
Operating Costs		
<i>Direct Operating Costs (DOC)</i>		
Operating Labor	\$15,306	A= Based on 0.5 hour per shift, 3 shifts per day
Supervisory Labor	\$2,296	B = 15% of operating labor
Maintenance Costs	\$307,500	C = Based 0.015 TCI, per May 2021FGD control cost manual
Caustic Costst	\$2,131,633	E= Mass of NaOH to neutralize SO ₂ times chemical cost plus 10% waste (based on example in July 2020 Draft Section 5 Control Cost Manual)
Sulfuric Acid Costs (for Neutralization)	\$470,687	E= Mass of H ₂ SO ₄ to neutralize NaOH times chemical cost plus 10% waste
Electricity Usage	871 kWh	Power (kWh) ratioed based on AFPA values.
Cost of Electricity Usage	\$646,738	F= E x Electricity Cost
Fresh Water	\$32,344	G= Freshwater use • water cost
Water Disposal	\$2,648	H = Water disposal amount• disposal cost
Total Direct Operating Costs /DOC)	\$3,609,153	DOC=A + B+ C+D +E+ F+ G+ H
<i>Indirect Operating Costs /IOC)</i>		
Overhead	\$195,061	H = 60% x (A+ B + C+ D)
Property Tax		I= 1% x TCI
Insurance		J= 1% x TCI
Administrative Charges		K= 2% x TCI
Total Indirect Operating Costs (JDC)	\$195,061	JDC= H+ I+J+ K
Total Annualized Cost (AC) =	\$5,456,235	AC= CRC+ DOC+ /DC
SO ₂ Uncontrolled Emissions (tpy)	1,167	
SO ₂ Removed (tpy)	1,050	90% Removal Efficiency
Cost per ton of SO₂ Removed (\$/ton)	\$5,197	\$/ton= AC/ Pollutant Removed

- U.S. EPA OAQPS, EPA Air Pollution Control Cost Manual Draft, July 2020, Section S 50₂ and Acid Gas Controls.
- t Caustic costs are highly variable in the current market. The basis of the value shown is the actual average cost for the Foley Mill for the 12-month period ending October 2022. During this time frame, the monthly values have varied from \$460/ton to \$920/ton.

**Table 7-35g-1. Foley Mill Recovery Furnace No. 4
Scrubber Cost Effective Analysis**

Total Capital Investment (TCI) - No. 4 Recovery Furnace

Total Project Cost	Cost Category	Cost
		\$21,800,000
Equipment		
	Andrtiz 502 Scrubber Package	\$5,614,000
	RO System	\$900,000
	Chemical Skids	\$175,000
	Freight	<u>\$535,120</u>
		\$7,224,120
Installation		
	Demolition for Construction	\$150,000
	Civil Structural Scrubber Adjustment	\$521,800
	Mechanical Installation on RO System	\$800,000
	Scrubber Electrical OSBL	\$1,100,000
	Mechanical Installation Scrubber OSBL	\$5,218,000
		\$7,789,800
Balance of Plant (7%)		\$1,050,974
Project Costs		
	Engineering (10%)	\$1,606,489
	Project Management (5%)	\$803,245
	Construction Management (2.5%)	\$401,622
	Escalation (8%)	\$1,285,192
	Contingency (10%)	<u>\$1,606,489</u>
		\$5,703,038

Table 7-35g-2. Foley Mill Recovery Furnace No. 4 Scrubber Cost Effective Analysis

Capital & Operating Cost Evaluation for SO₂ Scrubber for No. 4 Recovery Furnace

Cost Category	Value	Notes
BLS Analyzed (ton BLS/day) =	1,606	Permitted Capacity
Total Capital Investment (TCI)	\$21,800,000	Andritz/GP estimate provided August 15, 2022
Capital Recovery		
Capital Recovery Factor (CRF)	0.0806	CRF = 7% interest and 30-yr equipment life
Capital Recovery Cost (CRC)	<i>\$1,756,784</i>	<i>CRC = TCI * CRF</i>
Operating Costs		
<i>Direct Operating Costs (DOC)</i>		
Operating Labor	\$15,306	A = Based on 0.5 hour per shift, 3 shifts per day
Supervisory Labor	\$2,296	B = 15% of operating labor
Maintenance Costs	\$327,000	C = Based 0.015 TCI, per May 2021 FGD control cost manual
Caustic Costst	\$1,688,129	E = Mass of NaOH to neutralize SO ₂ times chemical cost plus 10% waste (based on example in July 2020 Draft Section 5 Control Cost Manual)
Sulfuric Acid Costs (for Neutralization)	\$372,757	E = Mass of H ₂ SO ₄ to neutralize NaOH times chemical cost plus 10% waste
Electricity Usage	1,416 kWh	Power (kWh) ratioed based on AFPA values.
Cost of Electricity Usage	\$1,050,998	F = E x Electricity Cost
Fresh Water	\$52,562	G = Freshwater use * water cost
Water Disposal	\$4,304	H = Water disposal amount * disposal cost
Total Direct Operating Costs (DOC)	<i>\$3,513,352</i>	<i>DOC = A + B + C + D + E + F + G + H</i>
<i>Indirect Operating Costs (IOC)</i>		
Overhead	\$206,761	H = 60% x (A + B + C + D)
Property Tax		I = 1% x TCI
Insurance		J = 1% x TCI
Administrative Charges		K = 2% x TCI
Total Indirect Operating Costs (IOC)	<i>\$206,761</i>	<i>IOC = H + I + J + K</i>
Total Annualized Cost (AC)=	\$5,476,896	AC = CRC + DOC + IOC
SO ₂ Uncontrolled Emissions (tpy)	924	
SO ₂ Removed (tpy)	831	90% Removal Efficiency
Cost per ton of SO ₂ Removed (\$/ton)	\$6,587	\$/ton = AC / Pollutant Removed

* U.S. EPA OAQPS, EPA Air Pollution Control Cost Manual Draft, July 2020, Section 5 SO₂ and Acid Gas Controls.

t Caustic costs are highly variable in the current market. The basis of the value shown is the actual average cost for the Foley Mill for the 12-month period ending October 2022. During this timeframe, the monthly values have varied from \$460/ton to \$920/ton.

The Department is unaware of any facility with a wet scrubber installed for SO₂ control on a recovery furnace. In its Region Haze Plan, the Department of Ecology for the State of Washington indicated, “The cost of installing a wet scrubber is not considered cost effective for any mill as the cost effectiveness values are in excess of \$27,000/ton of pollutant removed. (We note that the estimated costs are less than those included in the 2016 Ecology RACT analysis and may be lower than the true cost needed to install such a control device.)”

The cost effectiveness values for installing a wet scrubber on each recovery furnace were:

- No. 2 Recovery Furnace - \$7,779/ton of SO₂ removed;
- No. 3 Recovery Furnace - \$5,197/ton of SO₂ removed;
- No. 4 Recovery Furnace - \$6,587/ton of SO₂ removed.

Based on the estimated high capital and operating costs, the Foley Mill does not consider the installation of a wet scrubber to be cost effective. After conducting a site visit, discussing the physical constraints, and reviewing the costs, the Department did not revise the cost effectiveness values and agrees that the wet scrubber option is not cost effective for this regional haze analysis.

7.8.3.3.2 Time Necessary for Compliance – Recovery Furnace Nos. 2, 3, and 4

Installation of wet scrubbers at recovery furnaces can require up to four years to secure funding, make the required technical changes, and perform testing and monitoring to ensure proper system operation.

7.8.3.3.3 Energy and Non-Air Quality Impacts of Compliance – Recovery Furnaces Nos. 2, 3 and 4

Typical energy and non-air quality impacts of compliance include caustic and sulfuric acid costs, additional electrical costs associated with scrubber operation, additional fresh water for scrubber needs and wastewater disposal.

7.8.3.3.4 Remaining Useful Life - Recovery Furnaces Nos. 2, 3, and 4

The analysis assumed a remaining useful life of at least 30 years for the recovery furnaces.

7.8.3.3.5 Summary of Findings - Recovery Furnaces Nos. 2, 3, and 4

The primary factor that the Department used to determine whether a control or measure is necessary for reasonable progress was the cost of compliance. The Department then further considered the other three factors (time necessary for compliance, energy and non-air quality impacts, and remaining useful life). Remaining useful life in this case is already considered in the costs factor through annualizing the costs of compliance. For the Nos. 2, 3 and 4 Recovery Furnaces, the Department does not consider installation of a wet scrubber located after the ESP to be cost-effective. The Department determined, therefore, that these controls are not necessary for reasonable progress.

The Department has determined that the existing measures at the Nos. 2, 3 and 4 Recovery Furnaces *are necessary* for reasonable progress and emissions limits and associated supporting conditions are required to be adopted into the SIP. In order to establish reasonable progress limits for these three units, the Department has established by permit (Permit No. 1230001-121-AC) emission limits that require:

- The recovery furnaces shall fire black liquor as the primary fuel for recovery operations. Natural gas and authorized liquid fuels may be fired to supplement recovery operations when necessary. Tall oil is no longer an authorized fuel.
- All future additions of No. 6 fuel oil to the common tank shall have a maximum sulfur content of 1.02% by weight with compliance determined by maintaining records of fuel deliveries, analytical methods, and results of analysis.
- At least once per month, a representative sample shall be taken from the common tank and analyzed to determine the fuel sulfur content. The sample shall be analyzed for the sulfur content using the methods specified in this permit. A certified vendor analysis of the sulfur content may be used to satisfy these requirements.
- Combined SO₂ emissions from Recovery Furnace Nos. 2, 3 and 4 are capped at 3,200 tons per

consecutive twelve (12) operating months, rolled monthly, beginning January 1, 2024. An operating month is defined as a month where one, two, or all three furnaces operate for a minimum of one cumulative hour.

- The permittee shall continue to use, calibrate, maintain, and operate continuous emissions monitoring systems (CEMS) installed on each of the three recovery furnaces to measure and record SO₂ emissions. Each CEMS shall be calibrated and maintained to meet the quality assurance requirements specified in Appendix D of this permit including conducting the required periodic Relative Accuracy Test Assessments (RATA). Each certified CEMS shall be used to determine compliance with the SO₂ emissions cap and to report emissions for the purposes of Title V annual fees.

These permit conditions represent reasonable progress for SO₂ reduction. Florida proposes that these requirements, together with associated monitoring, reporting, and recordkeeping requirements (as reflected in Permit No. No. 1230001-121-AC, and attached to this submittal as **Appendix A**) be included as components of Florida's Regional Haze SIP.

10.4 State and Federal Land Manager Consultation

EPA's Regional Haze Rule requires states to provide opportunity for consultation with Federal Land Managers early in the SIP development process (40 CFR 51.308(i)(2)):

The State must provide the Federal Land Manager with an opportunity for consultation, in person at a point early enough in the State's policy analyses of its long-term strategy emission reduction obligation so that information and recommendations provided by the Federal Land Manager can meaningfully inform the State's decisions on the long-term strategy. The opportunity for consultation will be deemed to have been early enough if the consultation has taken place at least 120 days prior to holding any public hearing or other public comment opportunity on an implementation plan (or plan revision) for regional haze required by this subpart. The opportunity for consultation on an implementation plan (or plan revision) or on a progress report must be provided no less than 60 days prior to said public hearing or public comment opportunity. This consultation must include the opportunity for the affected Federal Land Managers to discuss their:

- (i) Assessment of impairment of visibility in any mandatory Class I Federal area; and
- (ii) Recommendations on the development and implementation of strategies to address visibility impairment.

10.4.1 Federal Land Manager 60-day Comment Period

On June 8, 2023, the Department sent consultation letters to the U.S. Fish and Wildlife Service (FWS), the U.S. Forest Service (FS), and the U.S. National Park Service (NPS) Federal Land Managers together with a preliminary copy of the draft proposed Amendments to Florida's Regional Haze Plan for the Second Implementation Period for a 60-day comment period (copies of the consultation letters were provided in Florida's SIP Submittal Number 2024-01 (Part I Supplement to Florida Regional Haze Plan), which the Department noticed for public comment on January 19, 2024, and which the Department submitted to EPA in its final format on June 14, 2024.

Continuing Consultation

40 CFR 51.308(i)(4) requires that each state's Regional Haze SIP include procedures for continuing consultation between the state and FLMs on the implementation of the visibility protection program. Florida commits to ongoing consultation with the FLMs. Florida will follow the consultation

requirements in 40 CFR 51.308(i)(3) on any future plan revisions or progress reports, and Florida will engage with the FLMs upon request on any matters related to regional haze affected by Florida sources.

* * *