



Department of Environmental Protection

Central District

PWS ID #: 3590039

PWS NAME: APPLE VALLEY (Consec)

POPULATION: 2,954

Consecutive to Altamonte Springs 3590026 as of 6/2015 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System will continue routine (annual) testing at <u>2</u> sites for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 3/30/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590069

PWS NAME: BEAR LAKE MANOR

POPULATION: 777

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Sample during the 2 nd week of August 2017 (annual)	System will continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) the second week of August 2017. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 5/12/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan in 2018.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590111

PWS NAME: DRUID HILLS

POPULATION: 661

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System will continue routine (annual) testing at <u>2</u> sites for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 3/30/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan. System will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590338

PWS NAME: ELDER SPRINGS MOBILE HOME PARK

POPULATION: 62

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
SOC Special Monitoring <i>2,4-D</i>	Annual (Oct-Dec)	Sample 2, 4-D in the 4 th Quarter 2017, 2018, 2019.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Routine reduced (triennial) testing the second week of July 2018. Report disinfectant residuals
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan. The system will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590497

PWS NAME: HARMONY HOMES

POPULATION: 234

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
<i>Special Monitoring</i> Xylenes (total) & Ethylbenzene	2nd quarter 2017	Sample at POE annually during the 2 nd quarter (April-May-June). Continue annual monitoring for at least 3 more years. (last detect in 2016).
<i>Special Monitoring</i> 1,2-dichloropropane	4 th quarter 2017	Sample at POE annually during the 4 th quarter (Oct-Nov-Dec.). Continue annual monitoring for at least 3 more years. (last detect in 2016).
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018 (annually)	System is on reduced (triennial) testing during the 3 rd week of August 2018. Collect 1 TTHM sample from the highest TTHM site and 1 HAA5 sample from the highest HAA5 site. If your highest TTHM and HAA5 sites are at the same location, you may collect 1 dual sample. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 9/22/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan. Testing is required again in 2018 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

➤ **It is important for you to provide this information to your operator and/or sampler.**

- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590615

PWS NAME: JANSEN S/D

POPULATION: 868

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Sample during the 2 nd week of August 2017 (annual)	Continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 5/12/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan. All water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590685

PWS NAME: LAKE BRANTLEY (CONSECUTIVE)

POPULATION: 182

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year. <i>Note: Water system became consecutive to Sanlando Utilities Corporation 3591121 approx. 10/4/11.</i>
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	System is on reduced (triennial) testing during 2018. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590186

PWS NAME: CHULUOTA WATER ASSOCIATION

POPULATION: 3,863

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2017	Sample at POE every 3 years.
Secondaries	2017	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228 required, Radium 226 is highly recommended</i>)	2017	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System is testing quarterly at 2 sites. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3591451

PWS NAME: WEATHERSFIELD

POPULATION: 4,221

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System will continue <u>increased</u> (quarterly) testing at <u>2 sites</u> for both T/H (dual samples) – for at least 3 quarters. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594214

PWS NAME: CHASE GROVES (CONSEC.)

POPULATION: 3,488

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	Continue quarterly testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590443

PWS NAME: GENEVA ELEMENTARY SCHOOL

POPULATION: 750

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	<u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Acceptable 2015 historic data meets criteria of 62-550.519(1)(e)1. Exempt from further monitoring.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i> <i>Revised 9/30/15 because > 500 in population</i>	July–Sept. 2017	System qualifies for reduced (annual) testing July – Sept. 2017 for system >500 in population. Collect TTHM/HAA5 samples at only 1 site, BLDG 5 Room 509, during August 2017. This site tested highest for TTHMs/HAA5s in 2014. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

** NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594180

PWS NAME: DOUBLE R SCHOOL

POPULATION: 160

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Radium-228 and Radium-226)	2025	Gross Alpha and Radium-228 acceptable grandfathered data in 2015. System is exempt from further GA monitoring. Sample at the POE for Radium-228 and Radium-226 in 6 years.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years. **Special monitoring for Dichloromethane will be included in the VOCs and can be credited towards the special monitoring listed below <i>if</i> VOCs are collected in the 3 rd Qtr.
**Special Monitoring Dichloromethane	3 rd Qtr 2017 (July-Aug-Sept. 2017)	Sample at the pt. of entry to the distribution system annually for dichloromethane during the 3 rd qtr of 2017. May return to reduced sampling if no detects in 2017.
**Special Monitoring Xylene	1 st Qtr 2017 (Jan-Feb-Mar), 2 nd Qtr of 2017 (Apr-May-June)	Sample at the pt. of entry to the distribution system quarterly for Xylene. Sample annually if 4 consecutive quarters below MCL (3 rd Qtr 2018).
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019	Test during the 2 nd week of September 2019 at the same site, Gym Fountain. Report disinfectant residuals.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	2017*	Test in accordance with the most recently approved sampling plan. Additional sampling required in 2017 (10 sampling locations) due to missed 2016 sampling. Make up samples received in Q4, 2016. *Contact Department to determine 2017 sampling frequency.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

** NTNC ≤ 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2016.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594221

PWS NAME: ORLANDO FREIGHTLINER

POPULATION: 75

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Quarterly	<u>routine</u> quarterly monitoring. Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. <i>Note: If you are due to sample for primary inorganics, nitrate and nitrite are included in that group.</i>
Primary Inorganics	2019	Sample at each POE every 3 years.
Radiologicals (Gross Alpha & Radium 228)	Exempt	Qualified for grandfathered data in 2015. Results low enough that the system is exempt from further Rads testing.
Volatile Organic Contaminants (VOCs)	2019	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2019	Sample at each POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July–Sept. 2019 (triennially)	System is on reduced (triennial) testing July – Sept. 2019. Test at Adminis. Men’s Restroom (upstairs) during the 3 rd week of Aug. 2019. Report the disinfectant residual.
Asbestos	2020-2022	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2019	Test in accordance with the most recently approved sampling plan.

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

** NTNC \leq 1,000 population sample quarterly due to Revised Total Coliform Rule becoming effective April 1, 2017.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590698

PWS NAME: LAKE HARNEY WATER ASSOCIATION

POPULATION: 700

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System will be tested at <u>2 sites</u> for both T/H (dual samples) July 2017. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 9/7/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 5 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590026

PWS NAME: ALTAMONTE SPRINGS WATER DEPT (2 WPs)

POPULATION: 55,576

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every yr. 2 POEs: WP 2+5
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	System is on routine (qtrly) testing at 4 sites for both T/H (dual samples). Report disinfectant residuals. Sample in accordance with Stage 2 D/DBP Monitoring Plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June-Sept. 2017	Distribution sites per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE (2 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590159

PWS NAME: CASSELBERRY, CITY OF (3 WPS)

POPULATION: 54,747

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year: H.Pk., N., & S.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs) (Special VOC testing for North WP reduced to annually in 2010.)	2017-N.WP, 2017-EA.WP	The special annual testing for the North WP shall continue until further notice. Sample at POE. Sample at <u>each</u> POE in 2017 for VOCs.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017- EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	System is on <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals. Sample in accordance with your Stage 2 Monitoring Plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June-Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at <u>each POE</u> (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590201

PWS NAME: LAKE MARY, CITY OF

POPULATION: 17,589

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE every year*.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years. The special monthly monitoring for 1,1-dichloroethylene from influent and effluent shall continue.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	System is on <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals. Sample in accordance with Stage 2 D/DBP Monitoring Plan.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590202

PWS NAME: LONGWOOD, CITY OF (2 WPs)

POPULATION: 20,332

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590205

PWS NAME: SANFORD, CITY OF (2 WPS)

POPULATION: 62,444

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 2 POEs: Main WP1 & Auxiliary WP2. Aux. WP has ozonation.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020-Main WP	Sample at Main WP POE every 3 years.
Arsenic & Radiologicals (<i>Gross Alpha and Radium 228 minimum for rads</i>) --Special Testing at Auxiliary WP due to ASR well--	2017-Auxiliary WP Monthly/Qtrly	Sample at Aux. WP POE <u>monthly</u> during recovery phases and <u>quarterly</u> when there is no recovery. (Monthly testing is recommended to cover all.)
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Special Monitoring <i>EDB for six Golf Course wells 1 - 6</i>	By June 2017 (annually)	Collect raw samples annually from Golf Course wells 1-6 and test for ethylene dibromide (EDB).
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i> <i>EPA placed system on Schedule 3.</i>	Quarterly (every 90 days)	Continue <u>routine</u> (qtrly) testing at 4 sites for both T/H (dual samples). Report the disinfectant residuals.
Bromate	Monthly for WPs with ozonation	Test the POE monthly of each water plant with ozonation (Aux. WP has ozonation currently). Submit bromate running annual averages quarterly.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan in per 7/19/11 email.
Water Quality Parameters (WQPs)	June – Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter. These WQPs are to be tested at the same time that the Lead and Copper testing is done.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2017	Sample at <u>each POE</u> (2 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590473

PWS NAME: SEMINOLE COUNTY NORTHEAST

POPULATION: 18,462

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 1 POE in sys (Country Club Estates).
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Special Monitoring Dalapon	1 st Qtr 2017 - Country Club WP	Sample at POE C.C. WP during the 1 st quarter of 2017. This is the 3 rd annual monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual (Oct-Dec)	System is on reduced (annual) testing at 2 sites (4267 Shades Crest Ln and 1606 Willow Oaks Ln) for both T/H (dual samples). Sample in the 4 th Quarter of 2017. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590571

PWS NAME: SEMINOLE COUNTY SOUTHEAST

POPULATION: 62,012

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year: 2 POEs in sys: Southeast (Consumers) and Indian Hills.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Special Monitoring <i>Di(2-ethylhexyl)phthalate</i>	1 st Qtr 2017 – Indian Hills WP	Sample at POE of the Indian Hills WP during the 1 st Qtr of 2017. This is the 3rd annual monitoring.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	System is on <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	June-Sept. 2017	<u>Distribution sites</u> per Optimal WQP Approval Letter.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at <u>each POE</u> (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590785

PWS NAME: SEMINOLE COUNTY SOUTHWEST

POPULATION: 10,435

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annual (Jan-March)	System is on reduced (annual) testing at <u>2 sites</u> for both T/H (dual samples). Sample in 1 st quarter of 2017. Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan. 30 tap samples required.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590879

PWS NAME: WINTER SPRINGS, CITY OF (3 WPS)

POPULATION: 35,996

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* ev. yr. 3 POEs: Tusawilla WP1, Sheoah Blvd. WP2, Bahama Blvd. WP3
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Special Monitoring <i>VOC chemical 2380: cis-1,2-dichloroethylene</i>	Jan. – Mar. 2017 - WP3 (Bahama Blvd WP)	8th annual cis-1,2-dichloroethylene due 1 st quarter 2017. Continued annual monitoring is required due to a borderline detection in 2014. If no detection in 2017, may return to one sample per compliance period (triennial)
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Special Monitoring <i>SOC chemical 2039: di(2-ethylhexyl)phthalate</i>	Apr. – June 2017 - WP1 (Tusawilla WP)	The quarterly testing for “phthalate” stopped after the 1/13/15 test. Annual monitoring is required for a minimum of 2 more years with no detect. Test WP1 during 2Q 2017.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Continue <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at <u>each POE</u> (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by**

9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590970

PWS NAME: OVIEDO, CITY OF

POPULATION: 41,713

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 1 POE in system
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2020	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	April – June 2017 (annual)	System began reduced (annual) monitoring 10/1/14. Test annually at <u>2 sites</u> for both T/H (dual samples). Test 1223 Twin Rivers Blvd. and 804 Palmetto Terrace on or near May 13, 2017 for both TTHMs/HAA5s. Report the disinfectant residuals.
Asbestos	2020	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June – Sept. 2017	Test in accordance with the most recently approved sampling plan. System is on reduced monitoring now. 30 samples must be collected (not 60).
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17**
- **to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3591121

PWS NAME: SANLANDO UTILITIES CORPORATION (3 WTPs)

POPULATION: 36,953

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017-EA.WP	Sample at each POE* every year. 3 POEs in sys.
Primary Inorganics	2017-EA.WP	Sample at each POE every 3 years.
Secondaries	2017-EA.WP	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2017-EA.WP	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017-EA.WP	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017-EA.WP	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Jul-Sep 2017	System qualifies for reduced annual monitoring. Sample <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at <u>each POE</u> (3 POEs) at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594107

PWS NAME: SEMINOLE COUNTY NORTHWEST

POPULATION: 25,811

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually on bacte reports.
Disinfectant Residual Reports	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at each POE* every year. 3 POEs in sys: Heathrow, Lake Monroe, Markham Regional WPs. Hanover Woods WP decommissioned 7/6/11.
Primary Inorganics	2017	Sample at each POE every 3 years.
Secondaries	2017	Sample at each POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2023	Sample at each POE every 3 years.
Volatile Organic Contaminants (VOCs)	2017	Sample at each POE every 3 years.
Special Monitoring <i>1,1-Dichloroethylene & Trichloroethylene(TCE)</i>	Quarterly	Sample at Markham WTP quarterly due to known sites with elevated contam. levels.
Arsenic & Radiologicals <i>(Gross Alpha and Radium 228 minimum for rads) --Special Testing at Markham Regional WTP due to ASR well--If the ASR well is in use.</i>	Monthly/Qtrly (if ASR is reactivated)	Sample at Markham Regional WTP POE <u>monthly</u> during recovery phases and <u>quarterly</u> when there is no recovery. (Monthly testing is recommended to cover all.)
Synthetic Organic Contaminants (SOCs)	2 Quarters 2017	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly	System is on <u>routine</u> (qtrly) testing at <u>4 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Bromate	Monthly for WPs with ozonation	Test the POE monthly of each water plant with ozonation (Aux. WP has ozonation currently). Submit bromate running annual averages quarterly.
Lead and Copper (Tap Sampling)	June-Sept. 2017	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District's website. Click on "Monitoring Schedules and Forms" under "Highlights" in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590707

PWS NAME: LAKE OF THE WOODS TRAILER PARK

POPULATION: 98

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
SOC Special Monitoring <i>Di(2-Ethylhexyl)phthalate</i>	Annual	Sample at POE annually during the 4 th quarter (Oct-Dec) of 2017 due to detect in 7/2015.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Begin reduced (triennial) testing but must test July – Sept. 2018
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling) <i>(revised from Jan.-June 2015 to 2013)</i>	June – Sept. 2018	Test in accordance with the most recently approved sampling plan. Refer to the 10/19/11 Lead action level exceedance letter from the Department; WQP testing is needed if action level(s) are exceeded again.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590762

PWS NAME: LITTLE WEKIVA ESTATES

POPULATION: 214

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance is based on a running annual avg.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Routine reduced (triennial) testing the second week of July 2018. Report disinfectant residuals
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 5/12/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590823

PWS NAME: MEREDITH MANOR (CONSEC.)

POPULATION: 1,686

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System is on reduced monitoring in 2017. Test 1 site, 130 Gum St. for both TTHMs/HAA5s, during the 2 nd week of July 2017. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 3/30/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590865

PWS NAME: MULLET LAKE WATER ASSOCIATION

POPULATION: 920

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Special Monitoring <i>Xylene</i>	Annual	Sample at POE annually during the 3rd quarter (July-Sep) of 2017
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System is on reduced (annual) testing at 1 site (1860 Marsh Rd) for both T/H (dual sample) Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. Asbestos-free certification received 6/28/11.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590912

PWS NAME: OAKLAND SHORES

POPULATION: 788

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
SOC Special Monitoring <i>di(2-ethylhexyl)adipate (2035) and di(2-ethylhexyl)phthalate (2039)</i>	2017	Sample at POE annually during the 1 st quarter (Jan-Mar). 2017 results (2AM) rec’d on 2/8/17 with no detects. 3AM due 1 st quarter of 2018.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	Continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) beginning week two of August 2017. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 5/12/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590988

PWS NAME: PALM VALLEY MOBILE HOME PARK

POPULATION: 1,476

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	7at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Quarterly (every 90 days)	Test quarterly both sites, dual samples until further notice.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan. A test is needed only if there is asbestos-cement pipe in the water system.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3590993

PWS NAME: PARK RIDGE

POPULATION: 246

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>) <i>Revised 4/12/13</i>	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	Annually*	*Test TTHM during the 2 nd quarter (Apr-Jun) and HAA5 during the 4 th quarter (Oct-Dec) at 1 location
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 5/12/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June – Sept. 2018	Test in accordance with the most recently approved sampling. Testing is returning to 6-month monitoring due to the recent change in disinfection from chlorines to chloramines.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2016	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2016 & August 10, 2016	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2016 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3591008

PWS NAME: PHILLIPS SECTION

POPULATION: 273

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	Reduced (triennial) testing July – Sept. 2018. Collect 1 dual sample at L1 (108 Par Ct). Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 5/12/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan per 7/29/11 email guidance.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3591061

PWS NAME: RAVENNA PARK

POPULATION: 1,187

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System will remain on <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples) - test the second week of August 2017. Report disinfectant residuals
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 5/12/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan per 7/29/11 email guidance. Testing is required again in 2012 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3591248

PWS NAME: SPRING HAMMOCK MHP

POPULATION: 175

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	Annual testing July – Sept. 2017 due to missed sampling. Collect sample approx. August 15, 2017. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan
Lead and Copper (Tap Sampling)	July-Sep 2018	Sample in 2018 to get on standard monitoring framework. Test in accordance with the most recently approved sampling plan. Refer to the 9/28/11 Lead action level exceedance letter from the Department; WQP testing is needed if action level(s) are exceeded again.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3591395

PWS NAME: TWELVE OAKS R.V. RESORT

POPULATION: 500

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2021	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i> <i>Revised 5/20/16 (reduced from 2 sites to 1 site)</i>	July – Sept. 2017 (annually)	System qualifies to go to <u>reduced</u> (annual) testing at <u>1 site</u> for both T/H - sample Aug 11-15, 2017, at Lot 122 only. Report the disinfectant residual.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan. All water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594050

PWS NAME: SEMINOLE WOODS

POPULATION: 780

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	2017	Sample at POE* every year.
Primary Inorganics	2018	Sample at POE every 3 years.
Secondaries	2018	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	2018	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	2018	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2018	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	On <u>reduced</u> (annual) monitoring at <u>1</u> site (#1-221) for both T/H (dual sample) during the 3 rd quarter. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan per 7/29/11 email guidance. Testing is required again in 2018 because all water systems will be sampling for lead and copper in line with the DEP standardized monitoring framework.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594186

PWS NAME: BLACK HAMMOCK-MSBU (CONSEC.)

POPULATION: 735

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017	System is on <u>reduced</u> (annual) testing for both T/H (dual samples) at 1 site 2364 Genova Dr. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 1/1/11 asbestos-free certification was received.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4131 or (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594216

PWS NAME: SUNSHADOWS APARTMENTS (CONSEC.)

POPULATION: 983

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. If required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July-Sept. 2017	System is on routine (annual) testing at <u>2 sites</u> for both T/H (dual samples). Test 3 rd week of August. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan. Asbestos-free certifications submitted in 1994 and 2002. Asbestos test submitted 2011. Pls. clarify whether or not the distribution system has asbestos-cement pipe.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 201	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594230

PWS NAME: MIDWAY-CANAAN WATER ASSOCIATION (CONSEC.)

POPULATION: 1,500

2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System will continue <u>routine</u> (annual) testing at <u>2</u> sites for both T/H (dual samples) during third week August 2017. Report disinfectant residuals.
Asbestos	2021	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594240

PWS NAME: DOVERA (CONSEC.)

POPULATION: 150

2017 DRINKING WATER MONITORING REQUIREMENTS NTNC > COMMUNITY 8/14

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly at 2 distribution sites	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2018	System is on reduced (triennial) testing. – at one site: 1 st floor men’s bathroom sink (L1). Sample approx. 9/2/18. Report disinfectant residuals.
Asbestos	2020-2021	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	June-Sept. 2018	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: 3594241

PWS NAME: OVIEDO MARKETPLACE (Consec)

POPULATION: 689

Consecutive to SCES SE Regional 3590571 as of 5/2016 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System will continue <u>routine</u> (annual) testing at <u>2 sites</u> for both T/H (dual samples). Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C. 3/30/11 asbestos test result & plan submitted.
Lead and Copper (Tap Sampling)	June-Sept 2018	Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July-Dec. 2017	Sample at each POE at least every two weeks per Optimal WQP Approval Letter.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2017 & August 10, 2017	Data for CCR can be obtained at: http://www.dep.state.fl.us/central/Home/DrinkingWater/Compliance/CCR/default.htm

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4142. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/16 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**

- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**



Department of Environmental Protection

Central District

PWS ID #: **TBD**

PWS NAME: **RIVERVIEWTOWNHOMES (Consec)**

POPULATION: 450

Consecutive to City of Sanford 3590205 – discovered 2/2017 2017 DRINKING WATER MONITORING REQUIREMENTS

MONITORING & REPORTS	DUE	COMMENTS
Microbiological (“Bacte”)	1 sample Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports. Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. if required.
Nitrate and Nitrite	----	Sample at POE* every year.
Primary Inorganics	----	Sample at POE every 3 years.
Secondaries	----	Sample at POE every 3 years.
Radiologicals (<i>Gross Alpha & Radium 228</i>)	----	Sample at POE every 3 years.
Volatile Organic Contaminants (VOCs)	----	Sample at POE every 3 years.
Synthetic Organic Contaminants (SOCs)	----	Sample at POE every 3 years.
Stage 2 Disinfection Byproducts (DBPs) <i>Total Trihalomethanes & Haloacetic Acids (5)</i>	July – Sept. 2017 (annually)	System will begin routine (annual) testing at <u>2 sites</u> for both T/H (dual samples). Sample in accordance with approved plan. Report disinfectant residuals.
Asbestos	2020-2021 (test)	Asbestos-Free Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C.
Lead and Copper (Tap Sampling)	Jan – Jun & July – Dec 2017	Submit sample plan for approval. Test in accordance with the most recently approved sampling plan.
Water Quality Parameters (WQPs)	Jan.-June & July–Dec. 2016	Sample at each POE (from Sanford) at least every two weeks.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2018 & August 10, 2018	Contact Department if you have questions about 2017 data

*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

This is a good faith assessment of monitoring requirements for the above-referenced public water system for calendar year 2017 and may not include additional sampling required during the year due to special circumstances. If you have questions, please contact the appropriate personnel at (407) 897-4100. This chart shall not relieve any person from any requirement of Florida law.

This schedule and state forms can be found at <http://www.dep.state.fl.us/central/Home/DrinkingWater/default.htm> on the Central District’s website. Click on “Monitoring Schedules and Forms” under “Highlights” in the right-hand column.

- **It is important for you to provide this information to your operator and/or sampler.**
- **It is strongly recommended that testing be conducted early in the monitoring period to allow time for retests due to possible sampling or lab errors. Annual and triennial sampling should be completed by 9/30/17 to provide time for revisions, re-tests, and/or corrections. Failure to sample within the required monitoring periods may result in enforcement action.**
- **Test results must be submitted to DEP within the first 10 days following the end of the required monitoring period, or the first 10 days following the month in which the sample results were received, whichever time is the shortest. Failure to comply with deadlines may result in enforcement action.**