



Florida Department of Environmental Protection Northeast District

PWS ID: 2550210
PWS Name: ST. AUGUSTINE WS

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Apr-Jun 2018 at L6 (St. Augustine Airport, 4900 US 1 North for TTHMs and HAA5s** and Oct-Dec 2018 at L2 (St. Joseph's Academy, 155 SR207) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	45470
Monitoring Frequency	Monthly
Raw Sampling	4-log: Raw not required, recommend quarterly
Distribution Sampling	50

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2550250

System Type: Community

PWS Name: CYPRESS LANDING WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (108 Cypress Landing) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	38
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2550396

System Type: Community

PWS Name: SJC-FRUIT COVE OAKS WS

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at L3 (1194 Harmony Drive North) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	463
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.

- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2550476
PWS Name: HASTINGS WTP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at L1 (Juvenile Detention Center) for HAA5s only** and at L2 (Wastewater Plant) for TTHMs only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	682
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2550812

System Type: Community

PWS Name: NORTH BEACH UTILITIES

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	6 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at L1 (54 Ferrol Rd) for TTHMs and HAA5s** and at L2 (Surfside 4th St.) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	3585
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	4

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2550866
PWS Name: JEA: PALM VALLEY WS

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at PA10 – 415 N Roscoe Blvd for TTHMs and HAA5s** Jul-Sep 2018 at PA1 – 299 S Roscoe Blvd for TTHMs only** Jan-Mar 2018 at PA1 – 299 S Roscoe Blvd for HAA5s only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	835
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2550908

System Type: Community

PWS Name: JEA: PONTE VEDRA GRID

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		WTP 1 Radionuclides	9 years	2026	
		WTP 2 Radionuclides	6 years	GA in 2023, rest in 2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jan-Mar 2018 at 801 Ponte Vedra Blvd for TTHMs and HAA5s Jan-Mar 2018 at 332 State A1A N for HAA5s only** Oct-Dec 2018 at 332 State A1A N for TTHMs only**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	5223
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	6

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2551004
PWS Name: SJCUC-SAWGRASS GRID

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Jan-Mar, Apr-Jun, Jul-Sep & Oct-Dec 2018 at L1 (Hallmark Condos), L2 (236 Canal Blvd.), L3 (1240 ponte Vedra Blvd.) & L4 (613 Timber Pond Court) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	12133
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	10

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2551120

System Type: Community

PWS Name: SJCUC-BARTRAM OAKS WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2019	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2021	
		Secondary Contaminants	Triennially	2021	
		Sulfate & TDS	Confirmation	Immediately	
		Volatile Organics (VOCs)	Triennially	2021	
		Radionuclides	9 years	2027	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2021	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (325 Shady Oak Circle) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	150
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2551228
PWS Name: WAGON WHEEL MHP

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Carbon Tetrachloride	Annually	Oct-Dec 2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (Lot #1, 2605 US 1 South) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	50
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2551370
PWS Name: WILDWOOD WATER SYSTEM

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially Annually	Full set - 2018 Dalapon 3Q 2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at 1001 Cheyenne Drive for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	858
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2551459

System Type: Community

PWS Name: ST. AUGUSTINE RV PARK LLC (FKA SHAMROCK)

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (Lot 10) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	110
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554166
PWS Name: CAMACHEE ISLAND WATER SYSTEM

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	Triennially	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Jan-Mar, Apr-Jun, Jul-Sep & Oct-Dec 2018 at L1 (End of Lands End Sample Tap) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	411
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554332
PWS Name: OAK HAVEN

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300).
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (Lot #13) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	40
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554334

System Type: Community

PWS Name: PONCE DE LEON GRID

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Plants 1 and 3 Radionuclides	6 years	2018	
		Plant 2 Radionuclides	9 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	At 125 Tides Edge for TTHMs and HAA5s** At 2371 S. Ponte Vedra Blvd for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	2249
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	2

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554337

System Type: Community

PWS Name: HOMEOWNERS UTILITIES INC.

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	6 years	2021	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (Hydrant @ End of Porpoise Pt Drive) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	285
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554343
PWS Name: SJCUC-PONTE VEDRA WS

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	9 years	2026	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Apr-Jun 2018 at L1 (24762 Harbour Estates Dr.), for TTHMs and HAA5s** and Oct-Dec 2018 at L3 (12433 Deer Trace Dr.) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Biannually	Jan-Jun 2018	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	12948
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	15

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554344
PWS Name: BAYSIDE ESTATES

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (Lot 36) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	180
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554346
PWS Name: OAKS AT WILDWOOD

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2018	
		Secondary Contaminants	Triennially	2018	
		Volatile Organics (VOCs)	Triennially	2018	
		Radionuclides	9 years	2018	
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2018	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2018 at L1 (4420 Carter Road, Apt. 61) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	153
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554353
PWS Name: SJCUC-EAGLE CREEK WS

System Type: Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2021	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually		Jul-Sep 2018 at L1 (129 Marsh Island Drive) for TTHMs only** and at L2 (201 River Island Circle) for HAA5s only**
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	655
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.

- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554360

System Type: Non-Transient Non-Community

PWS Name: LIGHTHOUSE CHURCH OF GOD

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Total Xylenes	Annually	Jul – Sep 2018	
		Radionuclides	Waived	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at L1 (Restroom Next to A/V Room) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2020	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	200
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554419

System Type: Non-Transient Non-Community

PWS Name: BETHUNE-COOKMAN COL. CONT. ED.

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Sodium	Annually	2018	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	6 years	2022	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at L1 (Lab Sink) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	40
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554447

System Type: Community

PWS Name: SJCUCR214 MAINLAND WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Radionuclides	6 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Apr-Jun 2018 at L2 (Flying J (950 SR206 West) for TTHMs and HAA5s** and Jul-Sep 2018 at L4 (5900 A1A South [Riverside Park]) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Biannually	Jan-Jun 2018 Jul-Dec 2018	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	52338
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	60

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection

Northeast District

PWS ID: 2554471

System Type: Community

PWS Name: SJC-NORTHWEST UTILITIES WTP

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2020	
		Secondary Contaminants	Triennially	2020	
		Volatile Organics (VOCs)	Triennially	2020	
		Dichloromethane	Annually	Jan- Mar 2019	
		Radionuclides	6 years	2023	
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2020	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Quarterly	Apr-Jun, Jul-Sep & Oct-Dec 2018 at L1 (21 World Golf Place), L2 (1928 River Lagoon Trace), L3 (Pacetti Rd Pointed Creek Dr.) & L4 (301 Royal St. Augustine Pkwy - Pro Shop) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites
		Water Quality Parameters (WQPs)	Every 2 weeks		Sample at <u>each</u> Point of Entry to the distribution

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	18435
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	20

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554472

System Type: Non-Transient Non-Community

PWS Name: ST. JOHNS GRAMMAR SCHOOL

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waived	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at L1 (Middle Kitchen Sink) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	140
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554475

System Type: Community

PWS Name: SJC-NORTHEAST UTILITIES WS

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Asbestos	Every 9 years	2020	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at L2 (St. Marks Pond Blvd. Intl Golf Parkway) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	4978
Monitoring Frequency	Monthly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	6

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.

- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554480
PWS Name: ELKTON ACADEMY

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	9 years	2025	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Triennially	Jul-Sep 2019 at L1 (West Bathroom) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2019	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	50
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.



Florida Department of Environmental Protection Northeast District

PWS ID: 2554489
PWS Name: SOUTH WOODS ELEMENTARY SCHOOL

System Type: Non-Transient Non-Community

2018 Drinking Water Chemical Monitoring Requirements

This below table summarizes the current monitoring requirements for the above facility and is subject to change. This information is a good faith assessment of the monitoring requirements for your system and we have sought to provide accurate information. Any errors in the table below does not exempt your system from state or federal monitoring requirements. If you are unsure or believe the information below is incorrect, please contact your inspector immediately. *We encourage you to use the below tables to assist in scheduling and tracking your sampling events.*

It is ultimately the responsibility of the facility owners to ensure all monitoring is completed and results are submitted timely to the Department.

Chemical monitoring requirements can be found under Rule 62-550 of the Florida Administrative Code (Fla. Admin. Code), available at www.flrules.org.

Chemical Monitoring					
Date Scheduled	Date Sampled	Contaminant	Frequency	Next Due	Location & Comments
		Nitrate & Nitrite	Annually	2018	Sample at <u>each</u> Point of Entry to the distribution (Raw/Well samples will not be accepted for compliance)
		Primary Inorganics	Triennially	2019	
		Volatile Organics (VOCs)	Triennially	2019	
		Radionuclides	Waived	N/A	
		Asbestos	Every 9 years	2022	Sample within distribution or certification if no asbestos pipes within the system, use Form 62-555.900(10) for Asbestos Free Certification or Asbestos Sampling Plan*
		Synthetic Organics (SOCs)	Triennially	2019	Sample at <u>each</u> Point of Entry to the distribution (2 quarterly samples required if population >3,300) or submit a request to waive samples using Form 62-560.545(2)*
		Stage 2 Disinfection Byproducts (S2 DBPs)	Annually	Jul-Sep 2018 at L2 (Room 141 Sink) for TTHMs and HAA5s**	
		Lead and Copper (tap samples)	Triennially	Jun-Sept 2018	Sample at pre-approved sample plan sites

***Note on Asbestos Free Certification and SOC Waiver:** Submit certification/waiver requests by October 31st to allow time for department review. Form submittal does not automatically waive sampling, which will be required if the request is not approved.

****Note on DBPs:** TTHMs = Total Trihalomethanes and HAA5s = Haloacetic Acids. Locations indicated are the pre-approved sample plan sites. If sites need to be altered, a new plan and justification should be submitted for review.

Bacteriological requirements can be found in Rules 62-550.310, 62-550.828, and 62-550.830, Fla. Admin. Code.

Bacteriological Monitoring	
Current Population on Record	660
Monitoring Frequency	Quarterly
Raw Sampling	1 Raw (pretreatment) per well
Distribution Sampling	1

When you receive results from the laboratory, **review the report immediately** to verify the information is complete, verify all contaminants were analyzed, and results are below levels requiring additional monitoring under 62-550, Fla. Admin. Code.

Important Reminders:

- Please take samples early in the monitoring period to allow for possible lab delays and unforeseen events.
- Reports must include system cover page, lab cover page, chains of custody, results page, and lab certification pages.
- Reports are due to the Department *within 10 days* following the end of sample period or following your receipt of the laboratory report, whichever time is less. We recommend submitting reports as soon as available. Do not rely on the laboratory to submit monitoring results to the Department.
- All samples must be taken during the required monitoring period and from the correct location(s) to be accepted for compliance.
- Failure to sample in accordance with rule requirements may result in enforcement action.
-