

## TIMELINE OF ACTIVITIES

### Pasco County Fire Rescue Training Facility

<b>DATE</b>	<b>ACTIONS</b>	<b>Program or Agency Involved</b>	<b>NOTES</b>
<b>1/30/19</b>	Facility outreach conducted.	DEP	DEP contacted the Fire Chief. DEP site number: ERIC_7395.
<b>2/19/19</b>	Conducted general visit with facility leadership.	DEP	DEP staff performed a reconnaissance of facility and spoke with facility leadership to identify areas of foam usage.
<b>2/21/19</b>	Sample Collection at Pasco Fire Rescue Training Facility.	DEP	Water and soil samples collected.

<b>3/19/19</b>	Certified Pasco County Sampling Results Received.	DEP Central Laboratory	<p>Concentrations of perfluorooctanoate acid (PFOA) and perfluorooctanesulfonic acid (PFOS) has been detected above the Health Advisory Level (HAL).</p> <p>DEP will work with Pasco County on the completion of the assessment and development of a cleanup plan to remove or contain the contamination to prevent environmental impact and human exposure.</p>
<b>3/20/19</b>	Results shared with Pasco County and DOH.	DEP	DOH has been directed to develop and implement a community sampling plan.
<b>3/29/19</b>	Letter provided to Pasco County	DEP Southwest District	DEP provided a letter to Pasco County indicating that they may be responsible for further assessment and remediation.
<b>5/16/19</b>	DEP Central Laboratory certified DOH private supply well results	DOH	DWASTEWELL-2019-05-03-05. Ten supply well results. No PFOA/PFOS HAL exceedances.

<b>5/16/19</b>	Ten private wells have been sampled by DOH within ½ miles of facility. No groundwater exceedances above the HAL.	DOH	DOH completed potable well sampling. No HAL exceedances.
<b>7/3/19</b>	DEP Central Laboratory certified DOH private supply well results	DOH	DWASTEWELL-2019-06-25-01. Three supply well results. No PFOA/PFOS HAL exceedances.
<b>7/5/19</b>	DEP Central Laboratory certified DOH private supply well results	DOH	DWASTEWELL-2019-06-25-01. Five supply well results. No PFOA/PFOS HAL exceedances.